

2015 RBES

Vermont Residential Building Energy Standards

Based on the: ®

2015 IECC
INTERNATIONAL

Energy Conservation Code®

CODE ALERT!

Sign up now to receive critical code updates and free access to videos,
book excerpts and training resources.

Signup is easy, subscribe now! www.iccsafe.org/alerts



DRAFT



2015 ~~International Energy Conservation Code~~[®] Vermont Residential Building Energy Standards

First ~~Printing~~^{Draft}: ~~May~~^{June} 2014

ISBN: ~~978-1-60983-486-9 (soft cover edition)~~

COPYRIGHT © 2014
by
INTERNATIONAL CODE COUNCIL, INC.

Date of First Publication: ~~May 30~~^{XX}, 2014

ALL RIGHTS RESERVED. This 2015 ~~This [VT Code]~~, contains substantial copyrighted material from the ~~[International Code]~~, which is a copyrighted work owned by the International Code Council, Inc. and which has been reproduced by [VT] with the written permission of the International Code Council. Vermont specific additions and changes are designated through markings in the margin. The ICC copyright does not pertain to the Vermont specific additions. Without advance written permission from the copyright owner, the ICC portion of this book may not be reproduced, distributed or transmitted in any form or by any means, including, without limitation, electronic, optical or mechanical means (by way of example and not limitation, photocopying, or recording by or in an information storage retrieval system). ~~International Energy Conservation Code~~[®] is a copyrighted work owned by the International Code Council, Inc. Without advance written permission from the copyright owner, no part of this book may be reproduced, distributed or transmitted in any form or by any means, including, without limitation, electronic, optical or mechanical means (by way of example, and not limitation, photocopying, or recording by or in an information storage retrieval system). For information on permission to copy material exceeding fair use, please contact: Publications, 4051 West Flossmoor Road, Country Club Hills, IL 60478. Phone 1-888-ICC-SAFE (422-7233).


Trademarks: “International Code Council,” the “International Code Council” logo and the “International Energy Conservation Code” are trademarks of the International Code Council, Inc.

To receive free copies of the [VT Code] please contact the Vermont Department of Public Service at 1-802-828-2811.

|

PRINTED IN THE U.S.A.

DRAFT



PREFACE

Introduction

Internationally, code officials recognize the need for a modern, up-to-date energy conservation code addressing the design of energy-efficient building envelopes and installation of energy efficient mechanical, lighting and power systems through requirements emphasizing performance. The 2015 *Vermont Residential Building Energy Standards* (RBES) is based on the *International Energy Conservation Code*® 2015 edition, and is designed to meet these needs through model code regulations that will result in the optimal utilization of fossil fuel and non-depletable resources in all communities, large and small.

This comprehensive energy conservation code establishes minimum regulations for energy efficient buildings using prescriptive and performance-related provisions. It is founded on broad-based principles that make possible the use of new materials and new energy efficient designs.

The *International Energy Conservation Code* provisions provide many benefits, among which is the model code development process that offers an international forum for energy professionals to discuss performance and prescriptive code requirements. This forum provides an excellent arena to debate proposed revisions. The model code also encourages international consistency in the application of provisions. Internationally, code officials recognize the need for a modern, up-to-date energy conservation code addressing the design of energy efficient building envelopes and installation of energy efficient mechanical, lighting and power systems through requirements emphasizing performance. The *International Energy Conservation Code*®, in this 2015 edition, is designed to meet these needs through model code regulations that will result in the optimal utilization of fossil fuel and non-depletable resources in all communities, large and small.

This code contains separate provisions for commercial buildings and for low-rise residential buildings (3 stories or less in height above grade). Each set of provisions, IECC—Commercial Provisions and IECC—Residential Provisions, is separately applied to buildings within their respective scopes. Each set of provisions is to be treated separately. Each contains a Scope and Administration chapter, a Definitions chapter, a General Requirements chapter, a chapter containing energy efficiency requirements and existing building provisions applicable to buildings within its scope.

This comprehensive energy conservation code establishes minimum regulations for energy efficient buildings using prescriptive and performance related provisions. It is founded on broad-based principles that make possible the use of new materials and new energy efficient designs. This 2015 edition is fully compatible with all of the *International Codes*® (I-Codes®) published by the International Code Council (ICC)®, including: the *International Building Code*®, *International Existing Building Code*®, *International Fire Code*®, *International Fuel Gas Code*®, *International Green Construction Code*®, *International Mechanical Code*®, *ICC Performance Code*®, *International Plumbing Code*®, *International Private Sewage Disposal Code*®, *International Property Maintenance Code*®, *International Residential Code*®, *International Swimming Pool and Spa Code*™, *International Wildland-Urban Interface Code*® and *International Zoning Code*®.

The *International Energy Conservation Code* provisions provide many benefits, among which is the model code development process that offers an international forum for energy professionals to discuss performance and prescriptive code requirements. This forum provides an excellent arena to debate proposed revisions. This model code also encourages international consistency in the application of provisions.

Development

The first edition of the *International Energy Conservation Code* (1998) was based on the 1995 edition of the *Model Energy Code* promulgated by the Council of American Building Officials (CABO) and included changes approved through the CABO Code Development Procedures through 1997. CABO assigned all rights and responsibilities to the International Code Council and its three statutory members at that time, including Building Officials and Code Administrators International, Inc. (BOCA), International Conference of Building Officials (ICBO) and Southern Building Code Congress International (SBCCI). This 2015 edition presents the code as originally issued, with changes reflected in the 2000 through 2012 editions and with changes approved through the ICC Code Development Process through 2014. A new edition such as this is promulgated every 3 years.

This [code-2015 RBES](#) is founded on principles intended to establish provisions consistent with the scope of an energy conservation code that adequately conserves energy; provisions that do not unnecessarily increase construction costs; provisions that do not restrict the use of new materials, products or methods of construction; and provisions that do not give preferential treatment to particular types or classes of materials, products or methods of construction.

Background

[During the 1995 legislative session, identical bills addressing the issue of energy efficiency standards in new residential construction were introduced in both the Vermont House and the Senate. Although neither bill was voted upon, considerable committee work was devoted to the bills.](#)

[At the end of the 1995 legislative session, there was a consensus among the parties involved in working on this issue that the creation of a Task Force to examine the issues related to a proposed energy efficiency standard might offer an opportunity to address the concerns of all interested parties. To this end, the Governor's Task Force on Energy Efficiency Standards for New Residential Construction was created by Governor Howard Dean in late September of 1995 and was charged with developing a specific legislative proposal prior to the 1996 legislative session.](#)

[The Governor's Task Force included stakeholders from many different perspectives on this issue. After three months of intensive committee and subcommittee work, this Task Force reached a consensus that the legislature should adopt a code and they agreed that this code should include the following provisions:](#)

- [• The code should be kept current by establishing a three-year cycle for revision and modification of the code through rule making. This should be established via a partnership between the DPS and the Department of Labor and Industry;](#)
- [• Compliance with the residential code should be given the presumption of compliance with Act 250 Criterion 9\(f\), Energy conservation;](#)
- [• To demonstrate compliance, builders should be required to complete a form self-certifying that the energy efficiency requirements of the code have been met for each new home that is built;](#)
- [• Owner/builders should be allowed to build a home that does not comply with the code as long as they disclose how that home is deficient to subsequent prospective buyers; and](#)
- [• In order to address indoor air quality, a requirement for automatic, mechanical ventilation systems should be included in the first update of the code three years from adoption.](#)

[Act 20, the *Vermont Residential Building Energy Standards* \(RBES\), was adopted by statute in 1997 and incorporated virtually all of the Task Force's recommendations. Since that time, an Energy Code Assistance Center has been established to provide builders and consumers with information on the code and answers to their questions. Workshops have also been held throughout the state to train builders, architects and trade allies about the code requirements and how to comply.](#)

[Act 89 was adopted by statute in 2013 and established a Stretch Code, a building energy code for residential buildings that achieves greater energy savings than the RBES. The stretch code shall be available for adoption by municipalities under 24 V.S.A. chapter 117, and shall apply in proceedings under 10 V.S.A. chapter 151 \(Act 250\).](#)

Update Process

[The RBES Statute, Act 20, called for the code to be updated every three years beginning in 1999. The DPS is required by the statute to form an advisory committee of stakeholders similar to the original Task Force to provide the Commissioner of Labor and Industry with recommendations prior to that agency conducting a formal rule-making process to update the standards.](#)

[The statute reads:](#)

[“\(c\) Revision and interpretation of energy standards. On or about January 1, 1999, and at least every three years thereafter, the commissioner of labor and industry shall amend and update the RBES, by means of administrative rules adopted in accordance with 3 V.S.A. Chapter 25. The department of public service shall provide technical assistance and expert advice to the commissioner in the interpretation of the RBES and in the formulation of specific proposals for amending the RBES. At least a year prior to final adoption of each required revision of the RBES, the DPS shall convene an advisory committee to include one or more mortgage lenders, builders, building designers, utility representatives and other persons with experience and expertise, such as consumer advocates and energy conservation experts. The advisory committee may provide the commissioner with additional recommendations for revision of the RBES.”](#)

[The Vermont Energy Act of 2009 \(Act 45\), called for the commissioner of public service to amend and update the RBES to](#)

ensure that residential construction be designed and constructed in a manner that complies with the 2009 edition of the IECC. These amendments must be effective on final adoption, by means of administrative rules, no later than January 1, 2011.

The Vermont DPS held a series of six stakeholder meetings in 2010 to gather feedback on proposed changes to RBES. The Vermont DPS also convened an advisory committee of interested stakeholders to review the current code and make recommendations for changes and improvements. The revisions to the 2009 edition of the International Energy Conservation Code presented in this document were drafted based on input received from these meetings.

Effective Use of the 2011 Residential Building Energy Standards

The 2015 *Vermont Residential Building Energy Standards* (RBES) is a code that regulates minimum energy conservation requirements for new buildings. The 2015 RBES addresses energy conservation requirements for all aspects of energy uses in residential construction, including heating and ventilating, lighting, water heating, and power usage for appliances and building systems.

The 2015 RBES is a design document. For example, before one constructs a building, the designer must determine the minimum insulation *R*-values and fenestration *U*-factors for the building exterior envelope. The RBES sets forth minimum requirements for exterior envelope insulation, and window and door *U*-factors, duct insulation, lighting and power efficiency, mechanical ventilation, and water distribution insulation.

Adoption

The International Code Council maintains a copyright in all of its codes and standards. Maintaining copyright allows the ICC to fund its mission through sales of books, in both print and electronic formats. The *International Energy Conservation Code* is designed for adoption and use by jurisdictions that recognize and acknowledge the ICC's copyright in the code, and further acknowledge the substantial shared value of the public/private partnership for code development between jurisdictions and the ICC.

The ICC also recognizes the need for jurisdictions to make laws available to the public. All ICC codes and ICC standards, along with the laws of many jurisdictions, are available for free in a non-downloadable form on the ICC's website. Jurisdictions should contact the ICC at adoptions@icc-safe.org to learn how to adopt and distribute laws based on the *International Energy Conservation Code* in a manner that provides necessary access, while maintaining the ICC's copyright.

Maintenance

The *International Energy Conservation Code* is kept up to date through the review of proposed changes submitted by code enforcing officials, industry representatives, design professionals and other interested parties. Proposed changes are carefully considered through an open code development process in which all interested and affected parties may participate.

The contents of this work are subject to change through both the code development cycles and the governmental body that enacts the code into law. For more information regarding the code development process, contact the Codes and Standards Development Department of the International Code Council.

While the development procedure of the *International Energy Conservation Code* assures the highest degree of care, the ICC, its members and those participating in the development of this code do not accept any liability resulting from compliance or noncompliance with the provisions because the ICC does not have the power or authority to police or enforce compliance with the contents of this code. Only the governmental body that enacts the code into law has such authority.

Code Development Committee Responsibilities (Letter Designations in Front of Section Numbers)

In each code development cycle, proposed changes to the code are considered at the Committee Action Hearings by the applicable International Code Development Committee. The IECC—Commercial Provisions (sections designated with a "C" prior to the section number) are primarily maintained by the Commercial Energy Code Development Committee. The IECC—Residential Provisions (sections designated with an "R" prior to the section number) are maintained by the Residential Energy Code Development Committee. This is designated in the chapter headings by a [CE] and [RE], respectively.

Maintenance responsibilities for the IECC are designated as follows:—

[CE] — Commercial Energy Code Development Committee

[RE] — Residential Energy Code Development Committee

For the development of the 2018 edition of the I Codes, there will be three groups of code development committees and they will meet in separate years. Note that these are tentative groupings.

DRAFT

Group A Codes (Heard in 2015, Code Change Proposals Deadline: January 12, 2015)	Group B Codes (Heard in 2016, Code Change Proposals Deadline: January 11, 2016)	Group C Codes (Heard in 2017, Code Change Proposals Deadline: January 11, 2017)
International Building Code —Fire Safety (Chapters 7, 8, 9, 14, 26) —Means of Egress (Chapters 10, 11, Appendix E) —General (Chapters 2-6, 12, 27-33, Appendices A, B, C, D, K)	Administrative Provisions (Chapter 1 of all codes except IRC and IECC, adminis- trative updates to currently referenced standards, and designated definitions)	International Green Construction Code
International Fuel Gas Code	International Building Code —Structural (Chapters 15-25, Appendices F, G, H, I, J, L, M)	
International Existing Building Code	International Energy Conservation Code	
International Mechanical Code	International Fire Code	
International Plumbing Code	International Residential Code —IRC Building (Chapters 1-10, Appendices E, F, H, J, K, L, M, O, R, S, T, U)	
International Private Sewage- Disposal Code	International Wildland-Urban Interface Code	
International Property Maintenance- Code		
International Residential Code —IRC Mechanical (Chapters 12-24) —IRC Plumbing (Chapters 25-33, Appendices G, I, N, P)		
International Swimming Pool and Spa- Code		
International Zoning Code		

Note: Proposed changes to the ICC Performance Code will be heard by the code development committee noted in brackets [] in the text of the code.

Marginal Markings

Solid vertical lines in the margins within the body of the code indicate a technical change from the requirements of the 2012 edition. Deletion indicators in the form of an arrow (➡) are provided in the margin where an entire section, paragraph, exception or table has been deleted or an item in a list of items or a table has been deleted.

A single asterisk [*] placed in the margin indicates that text or a table has been relocated within the code. A double asterisk [**] placed in the margin indicates that the text or table immediately following it has been relocated there from elsewhere in the code. The following table indicates such relocations in the 2015 edition of the *International Energy Conservation Code*.

2015 LOCATION	2012 LOCATION
C501	C101.4.1
C501.6	C101.4.2
C502 through C504	C101.4.3
C505	C101.4.4
C503.2	C101.4.5

C402.1.1	C101.5.2
C402.3	C402.2.1.1

DRAFT

2015 LOCATION	2012 LOCATION
R501	R101.4.1
R501.6	R101.4.2
R502 through R504	R101.4.3
R505	R101.4.4
R503.2	R101.4.5
R402.1	R101.5.2
R503.1.1.1	R402.3.6

Arrangement and Format of the 2015 IECC RBES

The IECC contains two separate sets of provisions—one for commercial buildings and one for residential buildings. Each set of provisions is applied separately to buildings within their scope. The IECC—Commercial Provisions apply to all buildings except for residential buildings three stories or less in height. The IECC—Residential Provisions apply to detached one- and two-family dwellings—and multiple single-family dwellings as well as Group R-2, R-3 and R-4 buildings three stories or less in height. These scopes are based on the definitions of “Commercial building” and “Residential building,” respectively, in Chapter 2 of each set of provisions. Note that the IECC—Commercial Provisions therefore contain provisions for residential buildings five stories or greater in height. Each set of provisions is divided into five different parts:

Before applying the requirements of the 2015 RBES it is beneficial to understand its arrangement and format. The 2015 RBES, like other codes published by ICC, is arranged and organized to follow sequential steps that generally occur during a plan review or inspection. The 2015 RBES is divided into six different parts:

Chapters	Subjects
1-2	Administration and definitions
3	Climate zones and general materials requirements
4	Energy efficiency requirements
5	Existing buildings
6	Referenced standards

Italicized Terms

Selected terms set forth in Chapter 2, Definitions, are italicized where they appear in code text. Such terms are not italicized where the definition set forth in Chapter 2 does not impart the intended meaning in the use of the term. The terms selected have definitions that the user should read carefully to facilitate better understanding of the code.

DRAFT

EFFECTIVE USE OF THE INTERNATIONAL ENERGY CONSERVATION CODE

The *International Energy Conservation Code* (IECC) is a model code that regulates minimum energy conservation requirements for new buildings. The IECC addresses energy conservation requirements for all aspects of energy uses in both commercial and residential construction, including heating and ventilating, lighting, water heating, and power usage for appliances and building systems.

The IECC is a design document. For example, before one constructs a building, the designer must determine the minimum insulation *R* values and fenestration *U* factors for the building exterior envelope. Depending on whether the building is for residential use or for commercial use, the IECC sets forth minimum requirements for exterior envelope insulation, window and door *U* factors, and SHGC ratings, duct insulation, lighting and power efficiency, and water distribution insulation.

Arrangement and Format of the 2015 IECC

The IECC contains two separate sets of provisions—one for commercial buildings and one for residential buildings. Each set of provisions is applied separately to buildings within their scope. The IECC Commercial Provisions apply to all buildings except for residential buildings three stories or less in height. The IECC Residential Provisions apply to detached one- and two-family dwellings and multiple single-family dwellings as well as Group R-2, R-3 and R-4 buildings three stories or less in height. These scopes are based on the definitions of “Commercial building” and “Residential building,” respectively, in Chapter 2 of each set of provisions. Note that the IECC Commercial Provisions therefore contain provisions for residential buildings five stories or greater in height. Each set of provisions is divided into five different parts:

Chapters	Subjects
1-2	Administration and definitions
3	Climate zones and general materials requirements
4	Energy efficiency requirements
5	Existing buildings
6	Referenced standards

The following is a chapter-by-chapter synopsis of the scope and intent of the provisions of the *International Energy Conservation Code* and applies to both the commercial and residential energy provisions:

Chapter 1 Scope and Administration. This chapter contains provisions for the application, enforcement and administration of subsequent requirements of the code. In addition to establishing the scope of the code, Chapter 1 identifies which buildings and structures come under its purview. Chapter 1 is largely concerned with maintaining “due process of law” in enforcing the energy conservation criteria contained in the body of this code. Only through careful observation of the administrative provisions can the [code official](#) or [other authority having jurisdiction](#) reasonably expect to demonstrate that “equal protection under the law” has been provided.

DRAFT

Chapter 2 Definitions. Chapter 2 is the repository of the definitions of terms used in the body of the code. Codes are technical documents and every word, term and punctuation mark can impact the meaning of the code text and the intended results. The code often uses terms that have a unique meaning in the code and the code meaning can differ substantially from the ordinarily understood meaning of the term as used outside of the code.

The terms defined in Chapter 2 are deemed to be of prime importance in establishing the meaning and intent of the code text. The user of the code should be familiar with and consult this chapter because the definitions are essential to the correct interpretation of the code and the user may not be aware that a term is defined.

Additional definitions regarding climate zones are found in Tables 301.3(1) and (2). These are not listed in Chapter 2.

Where understanding of a term's definition is especially key to or necessary for understanding of a particular code provision, the term is shown in *italics* wherever it appears in the code. This is true only for those terms that have a meaning that is unique to the code. In other words, the generally understood meaning of a term or phrase might not be sufficient or consistent with the meaning prescribed by the code; therefore, it is essential that the code-defined meaning be known.

Guidance regarding tense, gender and plurality of defined terms as well as guidance regarding terms not defined in this code is provided.

Chapter 3 General Requirements. Chapter 3 specifies the climate zones that will serve to establish the exterior design conditions. In addition, Chapter 3 provides interior design conditions that are used as a basis for assumptions in heating and cooling load calculations, and provides basic material requirements for insulation materials and fenestration materials.

Climate has a major impact on the energy use of most buildings. The code establishes many requirements such as wall and roof insulation *R*-values, window and door thermal transmittance requirement (*U*-factors) as well as provisions that affect the mechanical systems based upon the climate where the building is located. This chapter contains information that will be used to properly assign the building location into the correct climate zone and is used as the basis for establishing requirements or elimination of requirements.

Chapter 4 Energy Efficiency. Chapter 4 of each set of provisions contains the technical requirements for energy efficiency.

Commercial Energy Efficiency. Chapter 4 of the IECC—Commercial Provisions contains the energy-efficiency-related requirements for the design and construction of most types of commercial buildings and residential buildings greater than three stories in height above grade. Residential buildings, townhouses and garden apartments three stories or less in height are covered in the IECC—Residential Provisions. This chapter defines requirements for the portions of the building and building systems that impact energy use in new commercial construction and new residential construction greater than three stories in height, and promotes the effective use of energy. The provisions within the chapter promote energy efficiency in the building envelope, the heating and cooling system and the service water heating system of the building. [This section does not pertain to residential buildings in Vermont, but is left in for explanatory purposes.](#)

Residential Energy Efficiency. Chapter 4 of the IECC—Residential Provisions contains the energy-efficiency-related requirements for the design and construction of residential buildings regulated under this code. It should be noted that the definition of a *residential building* in this code is unique for this code. In this code, a *residential building* is a detached one- and two-family dwelling and multiple single-family dwellings as well as R-2, R-3 or R-4 buildings three stories or less in height. All other buildings, including residential buildings greater than three stories in height, are regulated by the energy conservation requirements in the IECC—Commercial Provisions. The applicable portions of a residential building must comply with the provisions within this chapter for energy efficiency. This chapter defines requirements for the portions of the building and building systems that impact energy use in new residential construction and promotes the effective use of energy. The provisions within the chapter promote energy efficiency in the building envelope, the heating and cooling system, [lighting](#) and the service water heating system of the building. [Vermont has adopted a two-tiered code structure with a "base" code that applies statewide, and a "Stretch Code" that is more stringent. The Stretch Code applies to all Act 250 development projects and is also available for municipalities that choose to adopt a higher energy standard.](#)

DRAFT

Chapter 5 Existing Buildings. Chapter 5 of each set of provisions contains the technical energy efficiency requirements for existing buildings. Chapter 5 provisions address the maintenance of buildings in compliance with the code as well as how additions, alterations, repairs and changes of occupancy need to be addressed from the standpoint of energy efficiency. Specific provisions are provided for historic buildings.

Chapter 6 Referenced Standards. The code contains numerous references to standards that are used to regulate materials and methods of construction. Chapter 6 contains a comprehensive list of all standards that are referenced in the code. The standards are part of the code to the extent of the reference to the standard. Compliance with the referenced standard is necessary for compliance with this code. By providing specifically adopted standards, the construction and installation requirements necessary for compliance with the code can be readily determined. The basis for code compliance is, therefore, established and available on an equal basis to the [code official](#), [code official or other authority having jurisdiction](#), contractor, designer and owner.

Chapter 6 is organized in a manner that makes it easy to locate specific standards. It lists all of the referenced standards, alphabetically, by acronym of the promulgating agency of the standard. Each agency's standards are then listed in either alphabetical or numeric order based upon the standard identification. The list also contains the title of the standard; the edition (date) of the standard referenced; any addenda included as part of the ICC adoption; and the section or sections of this code that reference the standard.

Marginal Markings

[Solid vertical lines in the margins within the body of the code indicate a technical change from the requirements of the 2012 IECC edition. Deletion indicators in the form of an arrow \(➡\) are provided in the margin where an entire section, paragraph, exception or table has been deleted or an item in a list of items or a table has been deleted.](#)

Abbreviations and Notations

The following is a list of common abbreviations and units of measurement used in this code. Some of the abbreviations are for terms defined in Chapter 2. Others are terms used in various tables and text of the code.

AFUE	Annual fuel utilization efficiency
bhp	Brake horsepower (fans)
Btu	British thermal unit
Btu/h-ft ²	Btu per hour per square foot
C-factor	See Chapter 2—Definitions
CDD	Cooling degree days
cfm	Cubic feet per minute
cfm/ft ²	Cubic feet per minute per square foot
ci	Continuous insulation
COP	Coefficient of performance
DCV	Demand control ventilation
°C	Degrees Celsius
°F	Degrees Fahrenheit
DWHR	Drain water heat recovery
DX	Direct expansion
E _c	Combustion efficiency
E _v	Ventilation efficiency

E_t	Thermal efficiency
EER	Energy efficiency ratio
EF	Energy factor
ERI	Energy Rating index
<i>F</i> -factor	See Chapter 2—Definitions

FDD	Fault detection and diagnostics
FEG	Fan efficiency grade
FL	Full load
ft ²	Square foot
gpm	Gallons per minute
HDD	Heating degree days
hp	Horsepower
HSPF	Heating seasonal performance factor
HVAC	Heating, ventilating and air conditioning
IEER	Integrated energy efficiency ratio
IPLV	Integrated Part Load Value
Kg/m ²	Kilograms per square meter
kW	Kilowatt
LPD	Light power density (lighting power allowance)
L/s	Liters per second
Ls	Liner system
m ²	square meters
MERV	Minimum efficiency reporting value
NAECA	National Appliance Energy Conservation Act
NPLV	Nonstandard Part Load Value
Pa	Pascal
PF	Projection factor
pcf	Pounds per cubic foot
psf	Pounds per square foot
PTAC	Packaged terminal air conditioner
PTHP	Packaged terminal heat pump
R-value	See Chapter 2—Definitions
SCOP	Sensible coefficient of performance
SEER	Seasonal energy efficiency ratio
SHGC	Solar Heat Gain Coefficient
SPVAC	Single packaged vertical air conditioner
SPVHP	Single packaged vertical heat pump
SRI	Solar reflectance index
SWHF	Service water heat recovery factor
U-factor	See Chapter 2—Definitions
VAV	Variable air volume
VRF	Variable refrigerant flow
VT	Visible transmittance
W	Watts
w.c.	Water column
w.g.	Water gauge

DRAFT

LEGISLATION

Jurisdictions wishing to adopt the 2015 *International Energy Conservation Code* as an enforceable regulation governing energy-efficient building envelopes and installation of energy-efficient mechanical, lighting and power systems should ensure that certain factual information is included in the adopting legislation at the time adoption is being considered by the appropriate governmental body. The following sample adoption legislation addresses several key elements, including the information required for insertion into the code text.

SAMPLE LEGISLATION FOR ADOPTION OF THE INTERNATIONAL ENERGY CONSERVATION CODE ORDINANCE NO. _____

A ~~[N]~~ ~~[ORDINANCE/STATUTE/REGULATION]~~ of the ~~[JURISDICTION]~~ adopting the 2015 edition of the *International Energy Conservation Code*, regulating and governing energy-efficient building envelopes and installation of energy-efficient mechanical, lighting and power systems in the ~~[JURISDICTION]~~; providing for the issuance of permits and collection of fees therefor; repealing ~~[ORDINANCE/STATUTE/REGULATION]~~ No. _____ of _____ the ~~[JURISDICTION]~~ and all other ordinances or parts of laws in conflict therewith.

The ~~[GOVERNING BODY]~~ of the ~~[JURISDICTION]~~ does ordain as follows:

Section 1. That a certain document, three (3) copies of which are on file in the office of the ~~[TITLE OF JURISDICTION'S KEEPER OF RECORDS]~~ of ~~[NAME OF JURISDICTION]~~, being marked and designated as the *International Energy Conservation Code, 2015* edition, as published by the International Code Council, be and is hereby adopted as the Energy Conservation Code of the ~~[JURISDICTION]~~, in the State of ~~[STATE NAME]~~ for regulating and governing energy-efficient building envelopes and installation of energy-efficient mechanical, lighting and power systems as herein provided; providing for the issuance of permits and collection of fees therefor; and each and all of the regulations, provisions, penalties, conditions and terms of said Energy Conservation Code on file in the office of the ~~[JURISDICTION]~~ are hereby referred to, adopted, and made a part hereof, as if fully set out in this legislation, with the additions, insertions, deletions and changes, if any, prescribed in Section 2 of this ordinance.

Section 2. The following sections are hereby revised:

Sections C101.1 and R101.1. Insert: ~~[NAME OF JURISDICTION]~~.

Section 3. That ~~[ORDINANCE/STATUTE/REGULATION]~~ No. _____ of _____ ~~[JURISDICTION]~~ entitled ~~[FILL IN HERE THE COMPLETE TITLE OF THE LEGISLATION OR LAWS IN EFFECT AT THE PRESENT TIME SO THAT THEY WILL BE REPEALED BY DEFINITE MENTION]~~ and all other ordinances or parts of laws in conflict herewith are hereby repealed.

Section 4. That if any section, subsection, sentence, clause or phrase of this legislation is, for any reason, held to be unconstitutional, such decision shall not affect the validity of the remaining portions of this ordinance. The ~~[GOVERNING BODY]~~ hereby declares that it would have passed this law, and each section, subsection, clause or phrase thereof, irrespective of the fact that any one or more sections, subsections, sentences, clauses and phrases be declared unconstitutional.


Section 5. That nothing in this legislation or in the Energy Conservation Code hereby adopted shall be construed to affect any suit or proceeding impending in any court, or any rights acquired, or liability incurred, or any cause or causes of action acquired or existing, under any act or ordinance hereby repealed as cited in Section 3 of this law; nor shall any just or legal right or remedy of any character be lost, impaired or affected by this legislation.

Section 6. That the ~~[JURISDICTION'S KEEPER OF RECORDS]~~ is hereby ordered and directed to cause this legislation to be published. (An additional provision may be required to direct the number of times the legislation is to be published and to specify that it is to be in a newspaper in general circulation. Posting may also be required.)

Section 7. That this law and the rules, regulations, provisions, requirements, orders and matters established and adopted hereby shall take effect and be in full force and effect ~~[TIME PERIOD]~~ from and after the date of its final passage and adoption.

DRAFT

DRAFT



DRAFT

TABLE OF CONTENTS

~~IECC—COMMERCIAL PROVISIONS.....C-1~~

~~CHAPTER 1—SCOPE AND
ADMINISTRATION.....C-3~~

~~CHAPTER 2—DEFINITIONS.....C-7~~

~~CHAPTER 3—GENERAL REQUIREMENTS.....C-13~~

~~CHAPTER 4—COMMERCIAL ENERGY
EFFICIENCY.....C-31~~

~~CHAPTER 5—EXISTING BUILDINGS.....C-95~~

~~CHAPTER 6—REFERENCED STANDARDS.....C-99~~

~~INDEX.....C-107~~

IECC—RESIDENTIAL PROVISIONS..... R-1

CHAPTER 1 SCOPE AND
ADMINISTRATION..... R-3

CHAPTER 2 DEFINITIONS..... R-7

CHAPTER 3 GENERAL REQUIREMENTS R-11

CHAPTER 4 RESIDENTIAL ENERGY
EFFICIENCY..... R-29

CHAPTER 5 EXISTING BUILDINGS R-43

CHAPTER 6 REFERENCED STANDARDS..... R-45


APPENDIX RA RECOMMENDED PROCEDURE
FOR WORST-CASE TESTING
OF ATMOSPHERIC VENTING
SYSTEMS UNDER
R402.4 OR R405
CONDITIONS $\leq 5ACH_{50}$ R-49

APPENDIX RB SOLAR-READY PROVISIONS—
DETACHED ONE- AND TWO-
FAMILY DWELLINGS,
MULTIPLE SINGLE-FAMILY
DWELLINGS
(TOWNHOUSES)..... R-51

INDEX..... R-53

DRAFT

DRAFT



DRAFT

IECC—RESIDENTIAL PROVISIONS

TABLE OF CONTENTS

CHAPTER 1 SCOPE AND ADMINISTRATION R-3

PART 1—SCOPE AND APPLICATION..... R-3

Section

- R101 Scope and General Requirements..... R-3
- R102 Alternative Materials, Design and Methods of Construction and Equipment... R-3

PART 2—ADMINISTRATION AND ENFORCEMENT R-3

- R103 Construction Documents R-3
- R104 Inspections R-4
- R105 Validity..... R-5
- R106 Referenced Standards..... R-5
- R107 Fees..... R-5
- R108 Stop Work Order R-5
- R109 Board of Appeals R-5

CHAPTER 2 DEFINITIONS R-7

Section

- R201 General R-7
- R202 General Definitions R-7

CHAPTER 3 GENERAL REQUIREMENTS... R-11

Section

- R301 Climate Zones..... R-11
- R302 Design Conditions R-26
- R303 Materials, Systems and Equipment R-26

CHAPTER 4 RESIDENTIAL ENERGY EFFICIENCY..... R-29

Section

- R401 General..... R-29
- R402 Building Thermal Envelope..... R-29
- R403 Systems..... R-35

- R404 Electrical Power and Lighting Systems..... R-37
- R405 Simulated Performance Alternative (Performance)..... R-37
- R406 Energy Rating Index Compliance Alternative R-41

[R407 Stretch Code](#)

CHAPTER 5 EXISTING BUILDINGS..... R-43

Section

- R501 General..... R-43
- R502 Additions..... R-43
- R503 Alterations..... R-44
- R504 Repairs..... R-44
- R505 Change of Occupancy or Use..... R-44

CHAPTER 6 REFERENCED STANDARDS.... R-45

APPENDIX RA RECOMMENDED PROCEDURE FOR WORST-CASE TESTING OF ATMOSPHERIC VENTING SYSTEMS UNDER R402.4 OR R405 CONDITIONS □ 5ACH₅₀... R-49

Section

- RA101 Scope R-49
- RA201 General Definitions R-49
- RA301 Testing Procedure R-49

APPENDIX RB SOLAR-READY PROVISIONS—DETACHED ONE- AND TWO-FAMILY DWELLINGS, MULTIPLE SINGLE-FAMILY DWELLINGS (TOWNHOUSES).. R-51

Section


- RB101 Scope R-51
- RB102 General Definitions R-51
- RB103 Solar-ready Zone R-51

INDEX..... R-53

DRAFT

DRAFT

STANDARDS



CHAPTER 1 [RE] SCOPE AND ADMINISTRATION

PART 1—SCOPE AND APPLICATION

SECTION R101 SCOPE AND GENERAL REQUIREMENTS

R101.1 Title. This code shall be known as the 2015 International Energy Conservation Code Residential Building Energy Standards (RBES) of Vermont ~~NAME OF JURISDICTION~~, and shall be cited as such. It is referred to herein as “this code.”

R101.2 Scope. This code applies to *residential buildings* and the building sites and associated systems and equipment.

R101.3 Intent. This code shall regulate the design and construction of buildings for the effective use and conservation of energy over the useful life of each building. This code is intended to provide flexibility to permit the use of innovative approaches and techniques to achieve this objective. This code is not intended to abridge safety, health or environmental requirements contained in other applicable codes or ordinances.

R101.4 Applicability. Where, in any specific case, different sections of this code specify different materials, methods of construction or other requirements, the most restrictive shall govern. Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall govern.

R101.4.1 Mixed occupancy. Where a building includes both *residential* and *commercial* occupancies, each occupancy shall be separately considered and meet the applicable provisions of the IECC Commercial Provisions Vermont Commercial Building Energy Standards (CBES) or IECC Residential Provisions RBES.

R101.5 Compliance. *Residential buildings* shall meet the provisions of IECC Residential Provisions RBES. *Commercial buildings* shall meet the provisions of IECC Commercial Provisions CBES.

R101.5.1 Compliance materials. The ~~code official~~ code official or other authority having jurisdiction shall be permitted to approve specific computer software, work- sheets, compliance manuals and other similar materials that meet the intent of this code.

R 101.5.2 Exempt buildings. The following buildings, or portions thereof, shall be exempt from the provisions of this code:

1. Low Energy Use Buildings. Those with a peak design rate of energy usage less than 3.4 Btu/h-ft² (10.7 W/m²) or 1.0 watt/ft² (10.7 W/m²) of floor area for space conditioning purposes.
2. Unconditioned Buildings. Those that do not contain conditioned space.
3. Mobile homes. Homes subject to Title VI of the

National Manufactured Housing Construction and Safety Standards Act of 1974 (42 U.S.C. §§ 5401-5426).

4. Hunting camps. Residential buildings shall not include hunting camps.

5. Summer camps. Residential buildings constructed for non-winter occupation with only a biomass (wood) heating system.

6. Owner-built homes. Residential construction by an owner, if all of the following apply:

1. The owner of the residential construction is the builder, as defined in 21 V.S.A §§ 266 a1, and;

2. The residential construction is used as a dwelling by the owner, and;

3. The owner in fact directs the details of construction with regard to the installation of materials not in compliance with the RBES, and;

4. The owner discloses in writing to a prospective buyer, before entering into a binding purchase and sales agreement, with respect to the nature and extent of any noncompliance with the RBES. Any statement or certificate given to a prospective buyer shall itemize how the home does not comply with RBES, and shall itemize which measures do not meet the RBES in effect at the time construction commenced.

Any certificate given under this subsection shall be recorded in the land records where the property is located, and sent to the department of public service, within 30 days following sale of the property by the owner. The department of public service will develop and make available to the public a certificate that itemizes how the home does not comply with RBES.

SECTION R102 ALTERNATIVE MATERIALS, DESIGN AND METHODS OF CONSTRUCTION AND EQUIPMENT

R102.1 General. The provisions of this code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by this code, provided that any such alternative has been approved. The ~~code official~~ code official or other authority having jurisdiction shall be permitted to approve an alternative material, design or method of construction where the ~~code official~~ code official or other authority having

Comment [RF1]: Note: Yellow-highlighted text throughout is new for 2015 relative to 2011 RBES.

jurisdiction finds that the proposed design is satisfactory and complies with the intent of the provisions of this code, and that the material, method or work offered is, for the pur-

pose intended, at least the equivalent of that prescribed in this code.

R102.1.1 Above code programs. The code official or other authority having jurisdiction shall be permitted to deem a national, state or local energy-efficiency program to exceed the energy efficiency required by this code. Buildings *approved* in writing by such an energy-efficiency program shall be considered in compliance with this code. The requirements identified as “mandatory” in Chapter 4 shall be met.

PART 2—ADMINISTRATION AND ENFORCEMENT

SECTION R103

CONSTRUCTION DOCUMENTS

R103.1 General. Where required, ~~C~~construction documents, technical reports and other supporting data shall be submitted in one or more sets with each application for a permit. The construction ~~doc~~e-uments and technical reports shall be prepared by a registered design professional where required by the statutes of the jurisdiction in which the project is to be constructed. Where special conditions exist, the ~~code official~~code official or other authority having jurisdiction is authorized to require necessary construction documents to be prepared by a registered design professional.

Exception: The ~~code official~~code official or other authority having jurisdiction is authorized to waive the requirements for construction documents or other supporting data if the ~~code official~~code official or other authority having jurisdiction determines they are not necessary to confirm compliance with this code.

R103.2 Information on construction documents. Where required, ~~C~~onstruc—tion documents shall be drawn to scale upon suitable mate—rial. Electronic media documents are permitted to be submitted where *approved* by the ~~code official~~code official or other authority having jurisdiction. Construction documents shall be of sufficient clarity to indicate the loca—tion, nature and extent of the work proposed, and show in suf—ficient detail pertinent data and features of the *building*, systems and equipment as herein governed. Details shall include, but are not limited to, the following as applicable:

1. Insulation materials and their *R*-values.
2. Fenestration *U*-factors and solar heat gain coefficients (SHGC).
3. Area-weighted *U*-factor and solar heat gain coefficients (SHGC) calculations.
4. Mechanical system design criteria.
5. Mechanical and service water-heating system and equipment types, sizes and efficiencies.
6. Equipment and system controls.
7. Duct sealing, duct and pipe insulation and location.
8. Air sealing details.

DRAFT

SCOPE AND ADMINISTRATION

R103.2.1 Building thermal envelope depiction. The *building's thermal envelope* shall be represented on the construction documents.

R103.3 Examination of documents. The ~~code official~~*code official or other authority having jurisdiction* shall examine or cause to be examined the accompanying construction documents and shall ascertain whether the construction indicated and described is in accordance with the requirements of this code and other pertinent laws or ordinances. The ~~code official~~*code official or other authority having jurisdiction* is authorized to utilize a registered design professional, or other *approved* entity not affiliated with the building design or construction, in conducting the review of the plans and specifications for compliance with the code.

R103.3.1 Approval of construction documents. When the ~~code official~~*code official or other authority having jurisdiction* issues a permit where construction documents are required, the construction documents shall be endorsed in writing and stamped "Reviewed for Code Compliance." Such *approved* construction documents shall not be changed, modified or altered without authorization from the ~~code official~~*code official or other authority having jurisdiction*. Work shall be done in accordance with the *approved* construction documents.

One set of construction documents so reviewed shall be retained by the ~~code official~~*code official or other authority having jurisdiction*. The other set shall be returned to the applicant, kept at the site of work and shall be open to inspection by the ~~code official~~*code official or other authority having jurisdiction* or a duly authorized representative.

R103.3.2 Previous approvals. This code shall not require changes in the construction documents, construction or designated occupancy of a structure for which a lawful permit has been heretofore issued or otherwise lawfully authorized, and the construction of which has been pursued in good faith within 180 days after the effective date of this code and has not been abandoned.

R103.3.3 Phased approval. The ~~code official~~*code official or other authority having jurisdiction* shall have the authority to issue a permit for the construction of part of an energy conservation system before the construction documents for the entire system have been submitted or *approved*, provided adequate information and detailed statements have been filed complying with all pertinent requirements of this code. The holders of such permit shall proceed at their own risk without assurance that the permit for the entire energy conservation system will be granted.

R103.4 Amended construction documents. Work shall be installed in accordance with the approved construction documents, and any changes made during construction that are not in compliance with the *approved* construction documents shall be resubmitted for approval as an amended set of construction documents.

R103.5 Retention of construction documents. One set of *approved* construction documents shall be retained by the ~~code official~~*code official or other authority having jurisdiction* for a period of not less than 180 days from date of completion of the permitted work, or as required by state or local laws.

SECTION R104 INSPECTIONS

R104.1 General. ~~Where required, c~~Construction or work for which a permit is required shall be subject to inspection by the ~~code official~~*code official or other authority having jurisdiction* or his or her designated agent, and such construction or work shall remain accessible and exposed for inspection purposes until *approved*. It shall be the duty of the permit applicant to cause the work to remain accessible and exposed for inspection purposes. Neither the *code official* nor the jurisdiction shall be liable for expense entailed in the removal or replacement of any material, product, system or building component required to allow inspection to validate compliance with this code.

R104.2 Required inspections~~approvals.~~

~~Work shall not be done beyond the point indicated in each successive inspection without first obtaining the approval of the code official or other authority having jurisdiction. The code official or other authority having jurisdiction, upon notification, shall make the requested inspections and shall either indicate the portion of the construction that is satisfactory as completed, or notify the permit holder or his or her agent wherein the same fails to comply with this code. Any portions that do not comply shall be corrected and such portion shall not be covered or concealed until authorized by the code official or other authority having jurisdiction.~~

~~The code official or his or her designated agent, upon notification, shall make the inspections set forth in Sections R104.2.1 through R104.2.5.~~

R104.2.1 Footing and foundation inspection. ~~Inspections associated with footings and foundations shall verify compliance with the code as to R-value, location, thickness, depth of burial and protection of insulation as required by the code and approved plans and specifications.~~

R104.2.2 Framing and rough-in inspection. ~~Inspections at framing and rough-in shall be made before application of interior finish and shall verify compliance with the code as to types of insulation and corresponding R-values and their correct location and proper installation; fenestration properties (U-factor and SHGC) and proper installation; and air leakage controls as required by the code and approved plans and specifications.~~

R104.2.3 Plumbing rough-in inspection. ~~Inspections at plumbing rough-in shall verify compliance as required by the code and approved plans and specifications as to types of insulation and corresponding R-values and protection, and required control.~~

R104.2.4 Mechanical rough-in inspection. ~~Inspections at mechanical rough-in shall verify compliance as required by the code and approved plans and specifications as to installed HVAC equipment type and size, required controls, system insulation and corresponding R-value, system air leakage control, programmable thermostats, dampers, whole house ventilation, and minimum fan efficiency.~~

Exception: Systems serving multiple dwelling units shall be inspected in accordance with Section C104.2.4.

R104.2.5 Final inspection. The *building* shall have a final inspection and shall not be occupied until *approved*. The

final inspection shall include verification of the installation of all required *building* systems, equipment and controls and their proper operation and the required number of high-efficacy lamps and fixtures.

R104.3 Reinspection. A *building* shall be reinspected when determined necessary by the ~~code official~~[code official or other authority having jurisdiction](#).

SCOPE AND ADMINISTRATION

R104.4 Approved inspection agencies. The ~~code official~~code official or other authority having jurisdiction is authorized to accept reports of third-party inspection agencies not affiliated with the building design or construction, provided such agencies are *approved* as to qualifications and reliability relevant to the building components and systems they are inspecting.

R104.5 Inspection requests. It shall be the duty of the holder of the permit or their duly authorized agent to notify the ~~code official~~code official or other authority having jurisdiction when work is ready for inspection. It shall be the duty of the permit holder to provide access to and means for inspections of such work that are required by this code.

R104.6 Reinspection and testing. Where any work or installation does not pass an initial test or inspection, the necessary corrections shall be made to achieve compliance with this code. The work or installation shall then be resubmitted to the ~~code official~~code official or other authority having jurisdiction for inspection and testing.

R104.7 Approval. After the prescribed tests and inspections indicate that the work complies in all respects with this code, a notice of approval shall be issued by the ~~code official~~code official or other authority having jurisdiction.

R104.7.1 Revocation. The ~~code official~~code official or other authority having jurisdiction is authorized to, in writing, suspend or revoke a notice of approval issued under the provisions of this code wherever the certificate is issued in error, or on the basis of incorrect information supplied, or where it is determined that the *building* or structure, premise, or portion thereof is in violation of any ordinance or regulation or any of the provisions of this code.

SECTION R105 VALIDITY

R105.1 General. If a portion of this code is held to be illegal or void, such a decision shall not affect the validity of the remainder of this code.

SECTION R106 REFERENCED STANDARDS

R106.1 Referenced codes and standards. The codes and standards referenced in this code shall be those listed in Chapter 5, and such codes and standards shall be considered as part of the requirements of this code to the prescribed extent of each such reference and as further regulated in Sections R106.1.1 and R106.1.2.

R106.1.1 Conflicts. Where conflicts occur between provisions of this code and referenced codes and standards, the provisions of this code shall apply.

R106.1.2 Provisions in referenced codes and standards. Where the extent of the reference to a referenced code or standard includes subject matter that is within the scope of this code, the provisions of this code, as applicable, shall take precedence over the provisions in the referenced code or standard.

R106.2 Application of references. References to chapter or section numbers, or to provisions not specifically identified

by number, shall be construed to refer to such chapter, section or provision of this code.

R106.3 Other laws. The provisions of this code shall not be deemed to nullify any provisions of local, state or federal law.

SECTION R107- FEES

R107.1 Fees. A permit shall not be issued until the fees prescribed in Section R107.2 have been paid, nor shall an amendment to a permit be released until the additional fee, if any, has been paid.

R107.2 Schedule of permit fees. A fee for each permit shall be paid as required, in accordance with the schedule as established by the applicable governing authority.

R107.3 Work commencing before permit issuance. Any person who commences any work before obtaining the necessary permits shall be subject to an additional fee established by the *code official* that shall be in addition to the required permit fees.

R107.4 Related fees. The payment of the fee for the construction, alteration, removal or demolition of work done in connection to or concurrently with the work or activity authorized by a permit shall not relieve the applicant or holder of the permit from the payment of other fees that are prescribed by law.

R107.5 Refunds. The *code official* is authorized to establish a refund policy.

SECTION R108 STOP

WORK ORDER

R108.1 Authority. Where the *code official* finds any work regulated by this code being performed in a manner either ~~contrary to the provisions of this code or dangerous or unsafe~~, the *code official* is authorized to issue a stop work order.

R108.2 Issuance. The stop work order shall be in writing and shall be given to the owner of the property involved, to the owner's authorized agent, or to the person doing the work. Upon issuance of a stop work order, the cited work shall immediately cease. The stop work order shall state the reason for the order and the conditions under which the cited work will be permitted to resume.

R108.3 Emergencies. Where an emergency exists, the *code official* shall not be required to give a written notice prior to stopping the work.

R108.4 Failure to comply. Any person who shall continue any work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to a fine as set by the applicable governing authority.

SECTION R109- BOARD OF APPEALS

R109.1 General. In order to hear and decide appeals of orders, decisions or determinations made by the *code official* relative to the application and interpretation of this code, there shall be and is hereby created a board of appeals. The

SCOPE AND ADMINISTRATION

~~code official shall be an ex officio member of said board but shall not have a vote on any matter before the board. The board of appeals shall be appointed by the governing body and shall hold office at its pleasure. The board shall adopt rules of procedure for conducting its business, and shall render all decisions and findings in writing to the appellant with a duplicate copy to the code official.~~

R109.2 Limitations on authority. ~~An application for appeal shall be based on a claim that the true intent of this code or the rules legally adopted thereunder have been incorrectly interpreted, the provisions of this code do not fully apply or an equally good or better form of construction is proposed. The board shall not have authority to waive requirements of this code.~~

R109.3 Qualifications. ~~The board of appeals shall consist of members who are qualified by experience and training and are not employees of the jurisdiction.~~

CHAPTER 2 [RE] DEFINITIONS

SECTION R201 GENERAL

R201.1 Scope. Unless stated otherwise, the following words and terms in this code shall have the meanings indicated in this chapter.

R201.2 Interchangeability. Words used in the present tense include the future; words in the masculine gender include the feminine and neuter; the singular number includes the plural and the plural includes the singular.

R201.3 Terms defined in other codes. Terms that are not defined in this code but are defined in the *International Building Code*, *International Fire Code*, *International Fuel Gas Code*, *International Mechanical Code*, *International Plumbing Code* or the *International Residential Code* shall have the meanings ascribed to them in those codes.

R201.4 Terms not defined. Terms not defined by this chapter shall have ordinarily accepted meanings such as the context implies.

SECTION R202 GENERAL DEFINITIONS

ABOVE-GRADE WALL. A wall more than 50 percent above grade and enclosing *conditioned space*. This includes between-floor spandrels, peripheral edges of floors, roof and basement knee walls, dormer walls, gable end walls, walls enclosing a mansard roof and skylight shafts.

ACCESSIBLE. Admitting close approach as a result of not being guarded by locked doors, elevation or other effective means (see “*Readily accessible*”).

ADDITION. An extension or increase in the *conditioned space* floor area or height of a building or structure.

AIR BARRIER. Any durable solid (non-porous) material that completely blocks air flow between conditioned space and unconditioned space, including necessary accessories to provide adequate support to resist positive and negative pressures without displacement or damage. The air barrier should be continuous and be durably connected to all penetrations, windows and other (structural) interruptions. Material(s) assembled and joined together to provide a barrier to air leakage through the building envelope. An air barrier may be a single material or a combination of materials.

ALTERATION. Any construction, retrofit or renovation to an existing structure other than repair or addition ~~that requires a permit~~. Also, a change in a building, electrical, gas, mechanical or plumbing system that involves an extension, addition or change to the arrangement, type or purpose of the original installation ~~that requires a permit~~.

ANNUAL FUEL UTILIZATION EFFICIENCY (AFUE). The ratio of annual output energy to annual input energy which includes any non-heating season pilot input loss, and for gas or oil-fired furnaces or boilers, does not include electrical energy.

ANNUAL FUEL UTILIZATION EFFICIENCY (AFUE)

APPROVED. Approval by the ~~code official~~ *code official or other authority having jurisdiction* as a result of investigation and tests conducted by him or her, or by reason of accepted principles or tests by nationally recognized organizations.

APPROVED AGENCY. An established and recognized agency regularly engaged in conducting tests or furnishing inspection services, when such agency has been approved by the ~~code official~~ *code official or other authority having jurisdiction*.

AUTOMATIC. Self-acting, operating by its own mechanism when actuated by some impersonal influence, as, for example, a change in current strength, pressure, temperature or mechanical configuration (see "Manual").

BASE CODE. The standard RBES Energy Code, as distinct from the higher stringency Stretch Code.

BASEMENT WALL. A wall 50 percent or more below grade and enclosing *conditioned space*.

BATHROOM. A room containing a bathtub, shower, spa or similar bathing fixture.

BEDROOM. A room or space 70 square feet or greater, with egress window and closet, used or intended to be used for sleeping. A "den," "library," "home office" with a closet, egress window, and 70 square feet or greater or other similar rooms shall count as a bedroom, but living rooms and foyers shall not. (Source: RESNET)

BTU. Abbreviation for British thermal unit, which is the quantity of heat required to raise the temperature of 1 pound (0.454 kg) of water 1°F (0.56°C). (1 Btu = 1,055 J), or about the amount of energy in one wooden kitchen match burned end to end.

BUILDER. The general contractor or other person in charge of construction, who has the power to direct others with respect to the details to be observed in construction. (Source: VT 30 VSA 51).

BUILDING. Any structure used or intended for supporting or sheltering any use or occupancy, including any mechanical systems, service water heating systems and electric power and lighting systems located on the building site and supporting the building.

CATEGORY I COMBUSTION APPLIANCE. An appliance which operates with a non-positive vent static pressure and a with a vent gas temperature that avoids excessive condensate production in the vent. (Source: NFPA54)

CATEGORY II COMBUSTION APPLIANCE. An appliance which operates with a non-positive vent static pressure and a with a vent gas temperature that may cause excessive condensate production in the vent. (Source: NFPA54)

CATEGORY III COMBUSTION APPLIANCE. An appliance which operates with a positive vent static pressure and a with a vent gas temperature that avoids excessive condensate production in the vent. (Source: NFPA54)

CATEGORY IV COMBUSTION APPLIANCE. An appliance which operates with a positive vent static pressure and a with a vent gas temperature that may cause excessive condensate production in the vent. (Source: NFPA54)

CIRCULATING HOT WATER SYSTEM. A specifically designed water distribution system where one or more pumps are operated in the service hot water piping to circulate heated water from the water-heating equipment to fixtures and back to the water-heating equipment.

BUILDING SITE. A contiguous area of land that is under the ownership or control of one entity.

BUILDING THERMAL ENVELOPE. The basement walls, exterior walls, floor, roof, and any other building element that enclose *conditioned space*. This boundary also includes the boundary between *conditioned space* and any exempt or unconditioned space.

BUILDING THERMAL ENVELOPE. The basement walls, exterior walls, floor, roof and any other building elements that enclose *conditioned space* or provide a boundary between *conditioned space* and exempt or unconditioned space.

CATEGORY I COMBUSTION APPLIANCE

C-FACTOR (THERMAL CONDUCTANCE). The coefficient of heat transmission (surface to surface) through a building component or assembly, equal to the time rate of heat flow per unit area and the unit temperature difference between the warm side and cold side surfaces (Btu/h · ft² · °F) [W/(m² · K)].

CUBIC FEET PER MINUTE (CFM). The quantity of air moved in 1 minute. A measurement typically applied to ventilation equipment.

CLIMATE ZONE. A geographical region based on climatic criteria as specified in this code.

CODE OFFICIAL. The officer or other designated authority charged with the administration and enforcement of this code, or a duly authorized representative. Vermont CODE OFFICIAL. The officer or other designated authority charged with the administration and enforcement of this code, or a duly authorized representative. The Public Service Department is not the code official and shall not be required to conduct inspections of construction or construction documents.

COEFFICIENT OF PERFORMANCE (COP)—COOLING. The ratio of the rate of heat removal to the rate of energy input in consistent units, for a complete cooling system or factory-assembled equipment, as tested under a nationally recognized standard or designated operating conditions.

COEFFICIENT OF PERFORMANCE (COP)—HEAT PUMP—HEATING. The ratio of the rate of heat delivered to the rate of energy input, in consistent units, for a complete heat pump system under designated operating conditions. Supplemental heat shall not be considered when checking compliance with the heat pump equipment.

~~COMMERCIAL BUILDING. For this code, all~~
~~COMMERCIAL BUILDING. For this code, all~~
~~buildings that are not included in the definition of~~
~~"Residential building."~~

COMMERCIAL BUILDING. For this code, all buildings that are not included in the definition of "Residential buildings, excluding mobile homes."

COMMERCIAL BUILDING ENERGY STANDARDS (CBES). The Vermont non-residential Energy Code, based on the IECC 2015.

CONDENSER. A heat exchanger designed to liquefy refrigerant vapor by removal of heat.

CONDENSING UNIT. A specific refrigerating machine combination for a given refrigerant, consisting of one or more power-driven compressors, condensers, liquid receivers (when required), and the regularly furnished accessories.

CONDITIONED FLOOR AREA. The horizontal projection of the floors associated with the *conditioned space*.

CONDITIONED SPACE. An area, room or space that is enclosed within the building thermal envelope and that is directly or indirectly heated or cooled. Spaces are indirectly heated or cooled where they communicate through openings with conditioned spaces, where they are separated from conditioned spaces by uninsulated walls, floors or ceilings, or where they contain uninsulated ducts, piping or other sources of heating or cooling.

CONDITIONED SPACE. An area or room within a building that meets one or more of the following criteria: (a) is provided with positive heating and/or cooling supply; (b) contains uninsulated ducts, pipes, or other systems designed to distribute heating and/or cooling; (c) is separated from any area or room that meets either (a) or (b) by an uninsulated wall, ceiling, or floor, or an opening.

CONTINUOUS AIR BARRIER. A combination of materials and assemblies that restrict or prevent the passage of air through the building thermal envelope.

Comment [RF2]: 2015 definition

Comment [RF3]: 2011 definition

DEFINITIONS

CONTINUOUS INSULATION (ci). Insulating material that is continuous across all structural members without thermal bridges other than fasteners and service openings. It is installed on the interior or exterior, or is integral to any opaque surface, of the building envelope.

CRAWL SPACE WALL. The opaque portion of a wall that encloses a crawl space and is partially or totally below grade.

CURTAIN WALL. Fenestration products used to create an external nonload-bearing wall that is designed to separate the exterior and interior environments.

DAYLIGHT ZONE.

1. **Under skylights.** The area under skylights whose horizontal dimension, in each direction, is equal to the sky-light dimension in that direction plus either the floor-to-ceiling height or the dimension to a ceiling height opaque partition, or one-half the distance to adjacent skylights or vertical fenestration, whichever is least.
2. **Adjacent to vertical fenestration.** The area adjacent to vertical fenestration which receives daylight through the fenestration. For purposes of this definition and

unless more detailed analysis is provided, the daylight zone depth is assumed to extend into the space a distance of 15 feet (4572 mm) or to the nearest ceiling height opaque partition, whichever is less. The daylight zone width is assumed to be the width of the window plus 2 feet (610 mm) on each side, or the window width plus the distance to an opaque partition, or the window width plus one-half the distance to adjacent skylight or vertical fenestration, whichever is least.

DEMAND — RECIRCULATION — WATER SYSTEM. A

water distribution system where pump(s) prime the service hot water piping with heated water upon demand for hot water.

DEADBAND. The temperature range in which no heating or cooling is used.

DEGREE DAY, COOLING. A unit, based on temperature difference and time, used in estimating cooling energy consumption and specifying nominal cooling load of a building in summer. For any one day, when the mean temperature is more than 65°F, there are as many degree days as there are degrees Fahrenheit difference in temperature between the mean temperature for the day and 65°F. Annual cooling degree days (CDD) are the sum of the degree days over a calendar year.

DEGREE DAY, HEATING. A unit, based upon temperature difference and time, used in estimating heating energy consumption and specifying nominal heating load of a building in winter. For any one day, when the mean temperature is less than 65°F, there are as many degree days as there are degrees Fahrenheit difference in temperature between the mean temperature for the day and 65°F. Annual heating degree days are the sum of the degree days over a calendar year.

DEMAND CONTROL VENTILATION (DCV). A ventilation system capability that provides for the automatic reduction of outdoor air intake below design rates when the actual occupancy of spaces served by the system is less than design occupancy.

DIRECT-VENT APPLIANCES. Appliances that are constructed and installed so that all air for combustion is derived directly from the outside atmosphere and all flue gases are discharged directly to the outside atmosphere. See also Sealed Combustion Venting System.

DUCT. A tube or conduit utilized for conveying air. The air passages of self-contained systems are not to be construed as air ducts.

DUCT SYSTEM. A continuous passageway for the transmission of air that, in addition to ducts, includes duct fittings, dampers, plenums, fans and accessory air-handling equipment and appliances.

DWELLING UNIT. A single unit providing complete independent living facilities for one or more persons, including permanent provisions for living, sleeping, eating, cooking and sanitation.

ECONOMIZER, AIR. A duct and damper arrangement and automatic control system that allows a

cooling system to supply outside air to reduce or eliminate the need for mechanical cooling during mild or cold weather.

ECONOMIZER, WATER. A system where the supply air of a cooling system is cooled indirectly with water that is itself cooled by heat or mass transfer to the environment without the use of mechanical cooling.

ENERGY ANALYSIS. A method for estimating the annual energy use of the *proposed design* and *standard reference design* based on estimates of energy use.

ENERGY COST. The total estimated annual cost for purchased energy for the building functions regulated by this code, including applicable demand charges.

ENERGY EFFICIENCY RATIO (EER). The ratio of net equipment cooling capacity in Btu/h to total rate of electric input in watts under designated operating conditions. When consistent units are used, this ratio becomes equal to COP (see also "Coefficient of performance").

ENERGY RECOVERY VENTILATION SYSTEM. Systems that employ air-to-air heat exchangers to recover energy from exhaust air for the purpose of preheating, precooling, humidifying or dehumidifying outdoor ventilation air prior to supplying the air to a space, either directly or as part of an HVAC system.

ENERGY SIMULATION TOOL. An *approved* software program or calculation-based methodology that projects the annual energy use of a building.

ENTRANCE DOOR. Fenestration products used for ingress, egress and access in nonresidential buildings, including, but not limited to, exterior entrances that utilize latching hardware and automatic closers and contain over 50-percent glass specifically designed to withstand heavy use and possibly abuse.

ERI REFERENCE DESIGN. A version of the rated design that meets the minimum requirements of the 2006 *International Energy Conservation Code*.

EVAPORATOR. That part of the system in which liquid refrigerant is vaporized to produce refrigeration.

EXTERIOR ENVELOPE. See "Building Thermal Envelope."

EXTERIOR WALL. Walls including both above-grade walls and basement walls.

FAN BRAKE HORSEPOWER (BHP). The horsepower delivered to the fan's shaft. Brake horsepower does not include the mechanical drive losses (belts, gears, etc.).

FAN SYSTEM BHP. The sum of the fan brake horsepower of all fans that are required to operate at fan system design conditions to supply air from the heating or cooling source to the *conditioned space(s)* and return it to the source or exhaust it to the outdoors.

FAN SYSTEM DESIGN CONDITIONS. Operating conditions that can be expected to occur during normal system operation that result in the highest supply fan airflow rate to

conditioned spaces served by the system.

FAN SYSTEM MOTOR NAMEPLATE HP. The sum of the motor nameplate horsepower of all fans that are required to operate at design conditions to supply air from the heating or cooling source to the *conditioned space(s)* and return it to the source or exhaust it to the outdoors.

FENESTRATION. Products classified as either *vertical fenestration* or *skylights*.

FENESTRATION PRODUCT, SITE-BUILT. A fenestration designed to be made up of field-glazed or field-assembled units using specific factory cut or otherwise factory-formed framing and glazing units. Examples of site-built fenestration include storefront systems, curtain walls and atrium roof systems.

F-FACTOR. The perimeter heat loss factor for slab-on-grade floors (Btu/h · ft · °F) [W/(m · K)].

FINISHED AREA. An enclosed area in a house that is suitable for year-round use, embodying walls, floors, and ceilings that are similar to the rest of the house.

FINISHED CONDITIONED FLOOR AREA (FCFA). The floor area in square feet of a home that is within the *conditioned space* of the building, and also is finished area, as measured in accordance with ANSI Standard Z765-2003 (with the exception that floor areas with ceiling heights of less than 5 feet will be included in finished square footage).

FURNACE DUCT. A furnace normally installed in distribution ducts of air-conditioning systems to supply warm air for heating and which depends on a blower not furnished as part of the duct furnace for air circulation.

FURNACE, WARM AIR. A self-contained, indirect-fired or electrically heated furnace that supplies heated air through ducts to spaces that require it.

GROSS AREA OF EXTERIOR WALLS. The normal projection of all exterior walls, including the area of all windows and doors installed therein (see "Exterior wall").

HEAT. The form of energy that is transferred by virtue of a temperature difference or a change in state of a material.

HEAT CAPACITY (HC). The amount of heat necessary to raise the temperature of a given mass by 1°F (0.6°C). The heat capacity of a building element is the sum of the heat capacities of each of its components.

HEAT PUMP. A refrigeration system that extracts heat from one substance and transfers it to another portion of the same substance or to a second substance at a higher temperature for a beneficial purpose.

HEAT RECOVERY VENTILATION SYSTEM (HRV). A factory-assembled device or combination of devices, including fans or blowers, designed to provide outdoor air for ventilation in which heat or heat and moisture is transferred between two isolated intake and

DEFINITIONS

exhaust air streams.

HEAT TRAP. An arrangement of piping and fittings, such as elbows, or a commercially available heat trap that prevents thermosyphoning of hot water during standby periods.

HEATED SLAB. Slab-on-grade construction in which the heating elements, hydronic tubing, or hot air distribution system is in contact with, or placed within or under, the slab.

HIGH-EFFICACY LAMPS. Compact fluorescent lamps, T-8 or smaller diameter linear fluorescent lamps, or lamps with a minimum efficacy of:

1. 60 lumens per watt for lamps over 40 watts;
2. 50 lumens per watt for lamps over 15 watts to 40 watts; and
3. 40 lumens per watt for lamps 15 watts or less.

HISTORIC BUILDING. Any building or structure that is one or more of the following:

1. Listed, or certified as eligible for listing by the State Historic Preservation Officer or the Keeper of the National Register of Historic Places, in the National Register of Historic Places.
2. Designated as historic under an applicable state or local law.
3. Certified as a contributing resource within a National Register-listed, state-designated or locally designated historic district.

HISTORIC BUILDING. Buildings that are listed in or eligible for listing in the National Register of Historic Places, or designated as historic under an appropriate state or local law.

HOME ENERGY RATING SYSTEM (HERS). A home energy rating system accredited by the Vermont Public Service Department that provides a numerical rating in compliance with 21 V.S.A. § 267(a). The purpose of this procedure is to ensure that accurate and consistent home energy ratings are performed by accredited HERS providers in Vermont and to promote an objective, cost-effective, sustainable home energy rating process as a compliance method for residential building energy codes; as qualification for energy programs designed to reach specific energy-saving goals; and as a way to provide Vermont's housing market the ability to differentiate residences based on their energy efficiency.

HUMIDISTAT. A regulatory device, actuated by changes in humidity, used for automatic control of relative humidity.

HVAC. Heating, ventilating and air conditioning.

HVAC SYSTEM. The equipment, distribution network and terminals that provide either collectively or individually the processes of heating, ventilating or air conditioning to a building.

HVAC SYSTEM COMPONENTS. HVAC system components provide, in one or more factory-assembled packages, means for chilling or heating water, or both, with controlled temperature for delivery to terminal units serving the conditioned spaces of the building. Types of HVAC system components include, but are not limited to, water chiller packages, reciprocating condensing units and water source (hydronic) heat pumps (see "HVAC system equipment").

HVAC SYSTEM EQUIPMENT. HVAC system equipment provides, in one (single package) or more (split system) factory-assembled packages, means for air circulation, air cleaning, air cooling with controlled temperature and dehumidification and, optionally, either alone or in combination with a heating plant, the functions of heating and humidifying. The cooling function is either electrically or heat

operated and the refrigerant condenser is air, water or evaporatively cooled. Where the equipment is provided in more than one package, the separate packages shall be designed by the manufacturer to be used together. The equipment shall be permitted to provide the heating function as a heat pump or by the use of electric or fossil-fuel-fired elements. (The word "equipment" used without a modifying adjective, in accordance with common industry usage, applies either to HVAC system equipment or HVAC system components.)

HUNTING CAMP. A seasonal building used as a temporary residence only during hunting season.

INFILTRATION. The uncontrolled inward air leakage into a building caused by the pressure effects of wind or the effect of differences in the indoor and outdoor air density or both.

INSULATED SIDING. A type of continuous insulation with manufacturer-installed insulating material as an integral part of the cladding product having a minimum *R*-value of *R*-2.

INSULATING SHEATHING. An insulating board with a core material having a minimum *R*-value of *R*-2.

LABELED. Equipment, materials or products to which have been affixed a label, seal, symbol or other identifying mark of a nationally recognized testing laboratory, inspection agency or other organization concerned with product evaluation that maintains periodic inspection of the production of the above-labeled items and where labeling indicates either that the equipment, material or product meets identified standards or has been tested and found suitable for a specified purpose.

LEVEL 1 ELECTRIC VEHICLE CHARGING STATION. Level 1 charging uses a standard 120V outlet.

LEVEL 2 ELECTRIC VEHICLE CHARGING STATION. Level 2 uses a 240-volt AC charging.

LISTED. Equipment, materials, products or services included in a list published by an organization acceptable to the ~~code official~~ *code official or other authority having jurisdiction* and concerned with evaluation of products or services that maintains periodic inspection of production of *listed* equipment or materials or periodic evaluation of services and where the listing states either that the equipment, material, product or service meets identified standards or has been tested and found suitable for a specified purpose.

LOCAL VENTILATION. A mechanical ventilation system including fans, controls and ducts, dedicated to exhausting moisture-laden air to the outside of the building from the room or space in which the moisture is generated.

LOW-VOLTAGE LIGHTING. Lighting equipment powered through a transformer such as a cable conductor, a rail conductor and track lighting.

MANUAL. Capable of being operated by personal intervention (see "Automatic").

MECHANICAL VENTILATION. The mechanical process of supplying conditioned or unconditioned air to, or removing such air from, any space by powered fans. For purposes of this standard, mechanical ventilation does not include processes driven by wind, such as turbine ventilators.

MULTIFAMILY DWELLING. A building containing three or more dwelling units.

NAMEPLATE HORSEPOWER. The nominal motor horse power rating stamped on the motor nameplate.

OCCUPANCY. The purpose for which a building, or portion thereof, is utilized or occupied.

OCCUPANCY CLASSIFICATIONS. Residential Group R is the occupancy group used for buildings that include sleeping rooms and are not institutional and are not generally regulated by the International Residential Code. The IRC typically regulates single family homes and duplexes, any structure with more than two units is in the IBC. There are four different occupancy groups within R.

The first occupancy group is **R-1**. This group is for transient uses like hotels, motels and boarding houses.

The next group is **R-2**. *R-2* is the group we see most often and it is for residences where occupants are primarily permanent. This includes apartments, dormitories, fraternities and sororities. It also includes vacation timeshares (again with more than two units) and convents and monasteries. Congregate living facilities with 16 or fewer occupants go into group *R-3*.

R-3 is for permanent occupancies that aren't *R-1*, *R-2*, *R-4* or *I*. These include buildings that are in the IBC but have no more than two units. Adult facilities and child care facilities that provide accommodation for five or less people less than 24 hours a day are *R-3*. Where these facilities are in a single family home they must comply with the IRC.

R-4 is for residential care/assisted living facilities including more than five and not more than 16 occupants.

OPAQUE AREAS. All exposed areas of a building envelope which enclose conditioned space, except openings for windows, skylights, doors and building service systems.

OUTDOOR AIR. Air taken from the outdoors and, therefore, not previously circulated through the building.

OWNER BUILDER. If all of the following apply:

DEFINITIONS

(A) The owner of the residential construction is the builder, as defined under this section.

(B) The residential construction is used as a dwelling by the owner.

(C) The owner in fact directs the details of construction with regard to the installation of materials not in compliance with RBES.

(D) The owner discloses in writing to a prospective buyer, before entering into a binding purchase and sales agreement, with respect to the nature and extent of any noncompliance with RBES. Any statement or certificate given to a prospective buyer shall itemize how the home does not comply with RBES, and shall itemize which measures do not meet the RBES standards in effect at the time construction commenced. Any certificate given under this subsection shall be recorded in the land records where the property is located, and sent to the department of public service, within 30 days following sale of the property by the owner.

PACKAGED TERMINAL AIR CONDITIONER (PTAC). A factory-selected wall sleeve and separate unencased combination of heating and cooling components, assemblies or sections (intended for mounting through the wall to serve a single room or zone). It includes heating capability by hot water, steam or electricity. (For the complete technical definition, see ARI 310/380.)

PACKAGED TERMINAL HEAT PUMP. A PTAC capable of using the refrigeration system in a reverse cycle or heat pump mode to provide heat. (For the complete technical definition, see ARI 310/380.)

POSITIVE COOLING SUPPLY. Mechanical cooling deliberately supplied to a space, such as through a supply register.

Additionally, mechanical cooling indirectly supplied to a space through uninsulated surfaces of space-cooling components, such as evaporator coil cases and cooling distribution systems which continually maintain air temperatures within the space of 85°F (29°C) or lower during normal operation. To be considered exempt from inclusion in this definition, such surfaces shall comply with the insulation requirements of this code.

POSITIVE HEAT SUPPLY. Heat deliberately supplied to a space by design, such as a supply register, radiator or heating element. Additionally, heat indirectly supplied to a space through uninsulated surfaces of service water heaters and space-heating components, such as furnaces, boilers and heating and cooling distribution systems which continually maintain air temperature within the space of 50°F (10°C) or higher during normal operation. To be considered exempt from inclusion in this definition, such surfaces shall comply with the insulation requirements of this code.

POWER-VENTED APPLIANCE. Appliances that operate with a positive vent static pressure (Category III) and utilize a mechanical fan to exhaust combustion gases from the appliance to the outside atmosphere.

PROPOSED DESIGN. A description of the proposed building used to estimate annual energy use for determining compliance

based on total building performance.

RATED CAPACITY. In terms of ventilation, the volume of air (in cfm) that the fan can move against a given static pressure (in inches or water gage). Prescriptive compliance with the *Vermont Residential Building Energy Standards* requires that all fan capacities be rated at 0.1 inch (25 Pa) of water gage.

RATED DESIGN. A description of the proposed building used to determine the energy rating index.

RBES. *Vermont Residential Building Energy Standards.*

READILY ACCESSIBLE. Capable of being reached quickly for operation, renewal or inspection without requiring those to whom ready access is requisite to climb over or remove obstacles or to resort to portable ladders or access equipment (see "Accessible").

REFRIGERANT. A substance utilized to produce refrigeration by its expansion or vaporization or absorption.

RENEWABLE ENERGY SOURCES. Means energy produced using a technology that relies on a resource that is being consumed at a harvest rate at or below its natural regeneration rate. (From 30 V.S.A. § 8002. Definitions)

(A) Methane gas and other flammable gases produced by the decay of sewage treatment plant wastes or landfill wastes and anaerobic digestion of agricultural products, byproducts, or wastes shall be considered renewable energy resources, but no form of solid waste, other than agricultural or silvicultural waste, shall be considered renewable.

(B) No form of nuclear fuel shall be considered renewable.

(C) The only portion of electricity produced by a system of generating resources that shall be considered renewable is that portion generated by a technology that qualifies as renewable.

(D) After conducting administrative proceedings, the Board may add technologies or technology categories to the definition of "renewable energy," provided that technologies using the following fuels shall not be considered renewable energy supplies: coal, oil, propane, and natural gas.

(E) Renewable energy refers to either "existing renewable energy" or "new renewable energy" (renewable energy produced by a specific and identifiable plant coming into service after December 31, 2004).

Sources of energy (excluding minerals) derived from incoming solar radiation, including natural daylighting and photosynthetic processes; from phenomena resulting therefrom, including wind, waves and tides, lake or pond thermal differences; and from the internal heat of the earth, including nocturnal thermal exchanges.

REPAIR. The reconstruction or renewal of any part of an existing building for the purpose of its maintenance or to correct damage.

DRAFT

DEFINITIONS

REROOFING. The process of recovering or replacing an existing *roof covering*. See “Roof recover” and “Roof replacement.”

RESIDENTIAL BUILDING. For this code, includes detached one- and two-family dwellings and multiple single-family dwellings (townhouses) as well as Group R-2, R-3 and R-4 buildings three stories or less in height above grade plane. (See *Occupancy Classifications*)

ROOF ASSEMBLY. A system designed to provide weather protection and resistance to design loads. The system consists of a roof covering and roof deck or a single component serving as both the roof covering and the roof deck. A roof assembly includes the roof covering, underlayment, roof deck, insulation, vapor retarder and interior finish. The gross area of a roof assembly consists of the total interior surface of all roof/ceiling components, including opaque surfaces, dormer and bay window roofs, treyed ceilings, overhead portions of an interior stairway to an unconditioned attic, doors and hatches, glazing and skylights exposed to conditioned space, that are horizontal or sloped at an angle less than 60 degrees (1.1 rad) from the horizontal (see “Exterior wall”). A roof assembly, or portions thereof, having a slope of 60 degrees (1.1 rad) or greater from horizontal shall be considered in the

gross area of exterior walls and thereby excluded from consideration in the roof assembly. Skylight shaft walls 12 inches (305 mm) in depth or greater (as measured from the ceiling plane to the roof deck) shall be considered in the gross area of exterior walls and are thereby excluded from consideration in the roof assembly

ROOF RECOVER. The process of installing an additional *roof covering* over a prepared existing *roof covering* without removing the existing *roof covering*.

ROOF REPAIR. Reconstruction or renewal of any part of an existing roof for the purposes of its maintenance.

ROOF REPLACEMENT. The process of removing the existing *roof covering*, repairing any damaged substrate and installing a new *roof covering*.

ROOM AIR CONDITIONER. An encased assembly designed as a unit for mounting in a window or through a wall, or as a console. It is designed primarily to provide free delivery of conditioned air to an enclosed space, room or zone. It includes a prime source of refrigeration for cooling and dehumidification and means for circulating and cleaning air, and shall be permitted to also include means for ventilating and heating.

R-VALUE (THERMAL RESISTANCE). The inverse of the time rate of heat flow through a body from one of its bounding surfaces to the other surface for a unit temperature difference between the two surfaces, under steady state conditions, per unit area ($h \cdot \text{ft}^2 \cdot ^\circ\text{F}/\text{Btu}$) [$(\text{m}^2 \cdot \text{K})/\text{W}$].

SASH CRACK. The sum of all perimeters of all window sashes, based on overall dimensions of such parts, expressed in feet. If a portion of one sash perimeter overlaps a portion of another sash perimeter, only count the length of the overlapping portions once.

SCREW LAMP HOLDERS. A lamp base that requires a screw-in-type lamp, such as a compact-fluorescent, incandescent, or tungsten-halogen bulb.

SEALED COMBUSTION VENTING SYSTEM. A venting system designed so that all air for combustion is derived directly from the outside atmosphere and all flue gases are discharged directly to the outside atmosphere. (See also “Direct-vent Appliances.”)

SEASONAL ENERGY EFFICIENCY RATIO (SEER). The total cooling output of an air conditioner during its normal annual usage period for cooling, in Btu/h, divided by the total electric energy input during the same period, in watt-hours, as determined by DOE 10 CFR Part 430, Subpart B, Test Procedures.

SERVICE SYSTEMS. All energy-using systems in a building that are operated to provide services for the occupants or processes housed therein, including HVAC, service water heating, illumination, transportation, cooking or food preparation, laundering and similar functions.


SERVICE WATER HEATING. Supply of hot water for purposes other than comfort heating.

SKYLIGHT. Glass or other transparent or translucent glazing material installed at a slope of less than 60 degrees (1.05 rad) from horizontal.

SIMULATION TOOL. An approved software program or calculation-based methodology that projects the hour-by-hour loads and annual energy use of a building.

SLAB-ON-GRADE EDGE INSULATION. Insulation
around, or underneath, the perimeter of the floor slab when

DRAFT



the top edge of the floor perimeter slab is above the finished grade or 12 inches (305 mm) or less below the finished grade.

SLEEPING UNIT. A room or space in which people sleep, which can also include permanent provisions for living, eating, and either sanitation or kitchen facilities but not both. Such rooms and spaces that are also part of a dwelling unit are not *sleeping units*.

SOLAR ENERGY SOURCE. Source of natural daylighting and of thermal, chemical or electrical energy derived directly from conversion of incident solar radiation.

SOLAR HEAT GAIN COEFFICIENT (SHGC). The ratio of the solar heat gain entering the space through the fenestration assembly to the incident solar radiation. Solar heat gain includes directly transmitted solar heat and absorbed solar radiation that is then reradiated, conducted or convected into the space.

SONE. A subjective unit of loudness for an average listener equal to the loudness of a 1,000-hertz (cycles per second) sound that has an intensity 40 decibels above the listener's own threshold of hearing.

STANDARD REFERENCE DESIGN. A version of the *proposed design* that meets the minimum requirements of this code and is used to determine the maximum annual energy use requirement for compliance based on total building performance.

STANDARD TRUSS. Any construction that does not permit the roof/ceiling insulation to achieve the required *R-value* over the exterior walls.

STOREFRONT. A nonresidential system of doors and windows mullied as a composite fenestration structure that has been designed to resist heavy use. *Storefront* systems include, but are not limited to, exterior fenestration systems that span from the floor level or above to the ceiling of the same story on commercial buildings.

STRETCH CODE. A building energy code that achieves greater energy savings than the base RBES. The Stretch Code is required for Act 250 projects and may be adopted by municipalities.

SUNROOM. A one-story structure attached to a dwelling with a glazing area in excess of 40 percent of the gross area of the structure's exterior walls and roof.

SYSTEM. A combination of central or terminal equipment or components or controls, accessories, interconnecting means and terminal devices by which energy is transformed so as to perform a specific function, such as HVAC, service water heating or illumination.

THERMAL ISOLATION. Physical and space conditioning separation from *conditioned space(s)*. The *conditioned space(s)* shall be controlled as separate zones for heating and cooling or conditioned by separate equipment.

THERMAL RESISTANCE (R). The reciprocal of thermal conductance ($h \cdot \text{ft}^2 \cdot ^\circ\text{F}/\text{Btu}$) [$\text{m}^2 \cdot \text{K}/\text{W}$].

THERMAL RESISTANCE, OVERALL (Ro). The reciprocal of overall thermal conductance ($h \cdot \text{ft}^2 \cdot ^\circ\text{F}/\text{Btu}$) [$\text{m}^2 \cdot \text{K}/\text{W}$]. The overall thermal resistance of the gross area or individual component of the exterior building envelope (such as roof/ceiling, exterior wall, floor, crawl space wall, founda-

tion, window, skylight, door, opaque wall, etc.), which includes the area-weighted *R-values* of the specific component assemblies (such as air film, insulation, drywall, framing, glazing, etc.).

THERMAL TRANSMITTANCE (U). The coefficient of heat transmission (air to air). It is the time rate of heat flow per unit area and unit temperature difference between the warm-side and cold-side air films ($\text{Btu}/\text{hr} \cdot \text{ft}^2 \cdot ^\circ\text{F}$) [$\text{W}/(\text{m}^2 \cdot \text{K})$].

The *U-factor* applies to combinations of different materials used in series along the heat flow path, single materials that comprise a building section, cavity airspaces and surface air films on both sides of a building element.

THERMAL TRANSMITTANCE, OVERALL (Uo). The overall (average) heat transmission of a gross area of the exterior building envelope ($\text{Btu}/\text{h} \cdot \text{ft}^2 \cdot ^\circ\text{F}$) [$\text{W}/(\text{m}^2 \cdot \text{K})$].

The *Uo-factor* applies to the combined effect of the time rate of heat flow through the various parallel paths, such as windows, doors and opaque construction areas, comprising the gross area of one or more exterior building components, such as walls, floors or roof/ceilings.

THERMOSTAT. An automatic control device used to maintain temperature at a fixed or adjustable set point.

TOILET ROOM. A room containing a water closet and, frequently, a lavatory, but not a bathtub, shower, spa or similar bathing fixture.

U-FACTOR (THERMAL TRANSMITTANCE). The coefficient of heat transmission (air to air) through a building component or assembly, equal to the time rate of heat flow per unit

area and unit temperature difference between the warm side and cold side air films ($\text{Btu/h} \cdot \text{ft}^2 \cdot ^\circ\text{F}$) [$\text{W}/(\text{m}^2 \cdot \text{K})$].

UNITARY COOLING AND HEATING EQUIPMENT.

One or more factory-made assemblies which include an evaporator or cooling coil, a compressor and condenser combination, and which shall be permitted to include a heating function as well. When heating and cooling equipment is provided in more than one assembly, the separate assemblies shall be designed to be used together.

UNITARY HEAT PUMP. One or more factory-made assemblies which include an indoor conditioning coil, compressor(s) and outdoor coil or refrigerant-to-water heat exchanger, including means to provide both heating and cooling functions. When heat pump equipment is provided in more than one assembly, the separate assemblies shall be designed to be used together.

UNUSUALLY TIGHT CONSTRUCTION. Construction meeting the following requirements:

1. Storm windows or weatherstripping on openable windows and doors; and
2. Caulking or sealants applied to areas, such as joints around window and door frames, between sole plates and floors, between wall-ceiling joints, between wall panels, at penetrations for plumbing, electrical and gas lines, and at other openings.
3. Buildings constructed in compliance with the RBES shall be considered built of unusually tight construction.

VAPOR PERMEABLE MEMBRANE. A material or covering having a permeance rating of 5 perms ($2.9 \cdot 1040 \text{ kg}/\text{Pa} \cdot \text{s} \cdot \text{m}^2$) or greater, when tested in accordance with the desiccant method using Procedure A of ASTM E 96. A vapor permeable material permits the passage of moisture vapor.

VAPOR RETARDER CLASS. A measure of the ability of a material or assembly to limit the amount of moisture that passes through that material or assembly. Vapor retarder class shall be defined using the desiccant method with Procedure A of ASTM E 96 as follows:

- Class 1: 0.1 perm or less
- Class 2: $0.1 < \text{perm} < 1.0 \text{ perm}$
- Class 3: $1.0 < \text{perm} < 10 \text{ perm}$

VENTING SYSTEM. A continuous open passageway from the flue collar or draft hood of a solid fuel, gas-burning, kerosene or oil-burning appliance to the outside atmosphere for the purpose of removing flue or vent gases. A venting system is usually composed of a vent or a chimney and vent connector, if used, assembled to form the open passageway.

Mechanical draft venting system. A venting system designed to remove flue or vent gases by mechanical means, that consists of an induced draft portion under nonpositive static pressure or a forced draft portion under positive static pressure.

1. **Forced-draft or power venting system.** A portion of a venting system using a fan or other mechanical means to cause the removal of flue or vent gases under positive static vent pressure.

2. **Induced draft venting system.** A portion of a venting system using a fan or other mechanical means to cause the removal of flue or vent gases under nonpositive static vent pressure.

Natural draft venting system. A venting system designed to remove flue or vent gases under nonpositive static vent pressure entirely by natural draft.

Scaled combustion venting system. A venting system designed so that all air for combustion is derived directly from the outside atmosphere and all flue gases are discharged directly to the outside atmosphere.

VENTILATION. The natural or mechanical process of supplying conditioned or unconditioned air to, or removing such air from, any space.

VENTILATION AIR. That portion of supply air that comes from outside (outdoors) plus any recirculated air that has been treated to maintain the desired quality of air within a designated space.

VERTICAL FENESTRATION. Windows (fixed or movable), opaque doors, glazed doors, glazed block and combination opaque/glazed doors composed of glass or other transparent or translucent glazing materials and installed at a slope of a least 60 degrees (1.05 rad) from horizontal.

VISIBLE TRANSMITTANCE [VT]. The ratio of visible light entering the space through the fenestration product assembly to the incident visible light. Visible Transmittance, includes the effects of glazing material and frame and is expressed as a number between 0 and 1.

WHOLE HOUSE MECHANICAL VENTILATION SYSTEM. An exhaust system, supply system, or combination thereof that is designed to mechanically exchange indoor air with outdoor air when operating continuously or through a programmed intermittent schedule to satisfy the whole house ventilation rates.

WHOLE HOUSE VENTILATION SYSTEM, BALANCED. Balanced systems provide outdoor air for ventilation such that supply and exhaust air quantities are of equal capacity to achieve pressure equalization, such as heat recovery ventilator, an air-to-air heat exchanger or any other system that is designed to provide mechanical supply as well as mechanical exhaust.

WHOLE HOUSE VENTILATION SYSTEM, EXHAUST ONLY. Exhaust only systems exhaust stale indoor air via a single fan, multiple fans or the installation of dual-purpose fans (i.e., serving both localized and whole house ventilation functions). Fresh incoming air may be provided by installed inlet ports or from typical leaks in the building envelope. Exhaust only systems may depressurize the indoor environment.

WHOLE HOUSE VENTILATION SYSTEM, MULTI-PORT. A whole house ventilation system that has more than one exhaust or supply port inside the house.


WHOLE HOUSE VENTILATION SYSTEM, SINGLE-PORT. A whole house ventilation system that has only one connection to the conditioned space and one connection to outdoor air.

WINDOW PROJECTION FACTOR. A measure of the portion of glazing that is shaded by an eave or overhang.

ZONE. A space or group of spaces within a building with heating or cooling requirements that are sufficiently similar so that desired conditions can be maintained throughout using a single controlling device.

DRAFT

DRAFT



CHAPTER 3 [RE] GENERAL REQUIREMENTS

SECTION R301

RESERVED

CLIMATE ZONES

~~R301.1 General.~~

~~*Climate zones*
from Figure
R301.1 or Table
R301.1 shall be
used in
determining the
applicable
require-ments
from Chapter 4.
Locations not in
Table R301.1
(out-side the
United States)
shall be
assigned a
climate zone
based on
Section R301.3.~~

~~**R301.2 Warm humid counties.** Warm humid counties are identified in Table R301.1 by an asterisk.~~

~~**R301.3 International climate zones.** The *climate zone* for any location outside the United States shall be determined by applying Table R301.3(1) and then Table R301.3(2).~~

~~**R301.4 Tropical climate zone.** The *tropical climate zone* shall be defined as:~~

- ~~1. Hawaii, Puerto Rico, Guam, American Samoa, U.S. Virgin Islands, Commonwealth of Northern Mariana Islands; and~~
- ~~2. Islands in the area between the Tropic of Cancer and the Tropic of Capricorn.~~

CLIMATE ZONE MAP AND ALL CLIMATE ZONE STATE TABLES DELETED (pages R-12 to R-25).

TABLE R301.3(1)
INTERNATIONAL CLIMATE ZONE DEFINITIONS
MAJOR CLIMATE TYPE DEFINITIONS

Marine (C) Definition—Locations meeting all four criteria: 1. Mean temperature of coldest month between -3°C (27°F) and 18°C (65°F); 2. Warmest month mean $< 22^{\circ}\text{C}$ (72°F); 3. At least four months with mean temperatures over 10°C (50°F); 4. Dry season in summer. The month with the heaviest precipitation in the cold season has at least three times as much precipitation as the month with the least precipitation in the rest of the year. The cold season is October through March in the Northern Hemisphere and April through September in the Southern Hemisphere.
Dry (B) Definition—Locations meeting the following criteria: Not marine and $P_m < 0.44 \times (TF - 19.5)$ [$P_m < 2.0 \times (TC + 7)$ in SI units] where: P_m = Annual precipitation in inches (cm) T = Annual mean temperature in $^{\circ}\text{F}$ ($^{\circ}\text{C}$)
Moist (A) Definition—Locations that are not marine and not dry.
Warm humid Definition—Moist (A) locations where either of the following wet-bulb temperature conditions shall occur during the warmest six consecutive months of the year: 1. 67°F (19.4°C) or higher for 3,000 or more hours; or 2. 73°F (22.8°C) or higher for 1,500 or more hours.

For SI: $^{\circ}\text{C} = ({}^{\circ}\text{F} - 32) / 1.8$, 1 inch = 2.54 cm.

GENERAL REQUIREMENTS

TABLE R301.3(2)
INTERNATIONAL CLIMATE ZONE DEFINITIONS

ZONE NUMBER	THERMAL CRITERIA	
	IP Units	SI Units
1	$9000 < \text{CDD}50^{\circ}\text{F}$	$5000 < \text{CDD}10^{\circ}\text{C}$
2	$6300 < \text{CDD}50^{\circ}\text{F} \leq 9000$	$3500 < \text{CDD}10^{\circ}\text{C} \leq 5000$
3A and 3B	$4500 < \text{CDD}50^{\circ}\text{F} \leq 6300$ AND $\text{HDD}65^{\circ}\text{F} \leq 5400$	$2500 < \text{CDD}10^{\circ}\text{C} \leq 3500$ AND $\text{HDD}18^{\circ}\text{C} \leq 3000$
4A and 4B	$\text{CDD}50^{\circ}\text{F} \leq 4500$ AND $\text{HDD}65^{\circ}\text{F} \leq 5400$	$\text{CDD}10^{\circ}\text{C} \leq 2500$ AND $\text{HDD}18^{\circ}\text{C} \leq 3000$
3C	$\text{HDD}65^{\circ}\text{F} \leq 3600$	$\text{HDD}18^{\circ}\text{C} \leq 2000$
4C	$3600 < \text{HDD}65^{\circ}\text{F} \leq 5400$	$2000 < \text{HDD}18^{\circ}\text{C} \leq 3000$
5	$5400 < \text{HDD}65^{\circ}\text{F} \leq 7200$	$3000 < \text{HDD}18^{\circ}\text{C} \leq 4000$
6	$7200 < \text{HDD}65^{\circ}\text{F} \leq 9000$	$4000 < \text{HDD}18^{\circ}\text{C} \leq 5000$
7	$9000 < \text{HDD}65^{\circ}\text{F} \leq 12600$	$5000 < \text{HDD}18^{\circ}\text{C} \leq 7000$
8	$12600 < \text{HDD}65^{\circ}\text{F}$	$7000 < \text{HDD}18^{\circ}\text{C}$

For SI: $^{\circ}\text{C} = [(^{\circ}\text{F}) - 32] / 1.8$.

SECTION R302 DESIGN CONDITIONS

R302.1 Interior design conditions. The interior design temperatures used for heating and cooling load calculations shall be a maximum of 72°F (22°C) for heating and minimum of 75°F (24°C) for cooling.

302.2 Exterior design conditions. The following design parameters in Table 302.2 shall be used for calculations required under this code.

TABLE 302.2
THERMAL DESIGN PARAMETERS

CONDITION	VALUE
Winter ^a , Design Dry-Bulb	-1°F
Summer ^a , Design Dry-Bulb	84°F
Summer, Design Wet Bulb	69°F
Degree Days Heating ^b	7,771
Degree Days Cooling ^b	2,228

For SI: $^{\circ}\text{C} = [(^{\circ}\text{F}) - 32] / 1.8$.

a. The outdoor design temperature is selected from the columns of 97½-percent values for winter and 2½-percent values for summer from tables in the ASHRAE *Handbook of Fundamentals*. Adjustments shall be permitted to reflect local climates which differ from the tabulated temperatures, or local weather experience determined by the code official or other authority having jurisdiction.

b. The degree days heating (base 65°F) and cooling (base 65°F) shall be selected from NOAA "Annual Degree Days to Selected Bases Derived from the 1971-2000 Normals," the ASHRAE *Handbook of Fundamentals*, data available from adjacent military installations or other sources of local weather data acceptable to the code official or other authority having jurisdiction.

type, manufacturer and *R*-value of insulation installed in each element of the *building thermal envelope*. For blown or sprayed insulation (fiberglass and cellulose), the initial installed thickness, settled thickness, settled *R*-value, installed density, coverage area and number of bags installed shall be *listed* on the certification. For sprayed polyurethane foam (SPF) insulation, the installed thickness of the areas covered and *R*-value of installed thickness shall be *listed* on the certification. For insulated siding, the *R*-value shall be labeled on the product's package and shall be *listed* on the certification. The insulation installer shall sign, date and post the certification in a conspicuous location on the job site.

R303.1.1.1 Blown or sprayed roof/ceiling insulation. The thickness of blown-in or sprayed roof/ceiling insulation (fiberglass or cellulose) shall be written in inches (mm) on markers that are installed at least one for every 300 square feet (28 m²) throughout the attic space. The markers shall be affixed to the trusses or joists and marked with the minimum initial installed thickness with numbers not less than 1 inch (25 mm) in height. Each marker shall face the attic access opening. Spray

SECTION R303 MATERIALS, SYSTEMS AND EQUIPMENT

R303.1 Identification. Materials, systems and equipment shall be identified in a manner that will allow a determination of compliance with the applicable provisions of this code.

R303.1.1 Building thermal envelope insulation. An *R*-value identification mark shall be applied by the manufacturer to each piece of *building thermal envelope* insulation 12 inches (305 mm) or greater in width. Alternately, the insulation installers shall provide a certification listing the

GENERAL REQUIREMENTS

polyurethane foam thickness and installed *R*-value shall be *listed* on certification provided by the insulation installer.

R303.1.2 Insulation mark installation. Insulating materials shall be installed such that the manufacturer’s *R*-value mark is readily observable upon inspection.

R303.1.3 Fenestration product rating. *U*-factors of fenestration products (windows, doors and skylights) shall be determined in accordance with NFRC 100.

Exception: Where required, garage door *U*-factors shall be determined in accordance with either NFRC 100 or ANSI/DASMA 105.

U-factors shall be determined by an accredited, independent laboratory, and *labeled* and certified by the manufacturer.

Products lacking such a *labeled U*-factor shall be assigned a default *U*-factor from Table R303.1.3(1) or R303.1.3(2). The solar heat gain coefficient (SHGC) and *visible transmittance* (VT) of glazed fenestration products (windows, glazed doors and skylights) shall

TABLE R303.1.3(1)
DEFAULT GLAZED FENESTRATION U-FACTORS

FRAME TYPE	SINGLE PANE	DOUBLE PANE	SKYLIGHT	
			Single	Double
Metal	1.20	0.80	2.00	1.30
Metal with Thermal Break	1.10	0.65	1.90	1.10
Nonmetal or Metal Clad	0.95	0.55	1.75	1.05
Glazed Block	0.60			

TABLE R303.1.3(2)
DEFAULT DOOR U-FACTORS

DOOR TYPE	U-FACTOR
Uninsulated Metal	1.20
Insulated Metal	0.60
Wood	0.50
Insulated, nonmetal edge, max 45% glazing, any glazing double pane	0.35

GENERAL REQUIREMENTS

be determined in accordance with NFRC 200 by an accredited, independent laboratory, and *labeled* and certified by the manufacturer. Products lacking such a *labeled* SHGC or VT shall be assigned a default SHGC or VT from Table R303.1.3(3).

TABLE R303.1.3(3)
DEFAULT GLAZED FENESTRATION SHGC AND VT

	SINGLE GLAZED		DOUBLE GLAZED		GLAZED BLOCK
	Clear	Tinted	Clear	Tinted	
SHGC	0.8	0.7	0.7	0.6	0.6
VT	0.6	0.3	0.6	0.3	0.6

R303.1.4 Insulation product rating. The thermal resistance (*R*-value) of insulation shall be determined in accordance with the U.S. Federal Trade Commission *R*-value rule (CFR Title 16, Part 460) in units of $\text{h} \cdot \text{ft}^2 \cdot ^\circ\text{F}/\text{Btu}$ at a mean temperature of 75°F (24°C).

R303.1.4.1 Insulated siding. The thermal resistance (*R*-value) of insulated siding shall be determined in accordance with ASTM C 1363. Installation for testing shall be in accordance with the manufacturer's instructions.

R303.2 Installation. Materials, systems and equipment shall be installed in accordance with the manufacturer's instructions and the *International Building Code* or *International Residential Code*, as applicable.

R303.2.1 Protection of exposed foundation insulation. Insulation applied to the exterior of basement walls, crawl-space walls and the perimeter of slab-on-grade floors shall have a rigid, opaque and weather-resistant protective covering to prevent the degradation of the insulation's thermal performance. The protective covering shall cover the exposed exterior insulation and extend not less than 6 inches (153 mm) below grade.

R303.3 Maintenance information. Maintenance instructions shall be furnished for equipment and systems that require preventive maintenance. Required regular maintenance actions shall be clearly stated and incorporated on a readily accessible label. The label shall include the title or publication number for the operation and maintenance manual for that particular model and type of product.

DRAFT

SECTION 304 DESIGN CRITERIA FOR RESIDENTIAL VENTILATION SYSTEMS

304.1 Scope. This section shall govern ventilation of the dwelling unit(s) within Type A-1 residential buildings, Type A-2 residential buildings and multiple single-family attached dwellings (townhouses) not more than three stories in height.

304.1.1 Compliance. Compliance with Section 304 shall be achieved by meeting Section 304.2 and 304.3.

304.2 Local ventilation. Bathrooms containing a bathtub, shower, spa or similar bathing fixture and not included in the whole house ventilation system shall be sized to meet the net capacity rates as required in Table 304.2. Whole house ventilation fans serving both localized and whole house ventilation functions shall be sized to meet the net capacity rates as required by Section 304.6 and must meet all other requirements listed in Section 304.3, as applicable.

**TABLE 304.2
MINIMUM REQUIRED LOCAL EXHAUST**

OCCUPANCY CLASSIFICATION	MECHANICAL EXHAUST CAPACITY (CFM)
Bathrooms	50 cfm intermittent or 20 cfm continuous

304.3 Whole house ventilation (MANDATORY). Every home built to RBES shall be mechanically ventilated by a whole house ventilation system as defined in Chapter 2. The whole house ventilation system shall be one of two types: “exhaust only” or “balanced.”

304.4 Whole house air circulation. Provisions shall be made to allow air flow to all finished living spaces by installation of

distribution ducts, undercutting doors, installation of grilles, transoms or equivalent means. Door undercuts shall be at least $\frac{1}{2}$ inch (12.7 mm) above the surface of the finished floor covering.

304.5 Fan motor requirements. Fans installed for the purpose of providing whole house ventilation must meet the minimum requirements as specified in this section.

Exception: Fans installed exclusively for local ventilation purposes are exempted from meeting the fan motor requirements listed in section 304.5.

304.5.1 Fan durability. Whole house ventilation fan motors shall be rated for “continuous duty” and have manufacturer flow ratings as listed in HVI 911.

304.5.2 Fan power consumption. Single-port whole house ventilation equipment shall not exceed 50 watts as listed by the manufacturer on the fan motor or as listed in accordance with HVI 911. Power used for lights, sensors, heaters, timers or night lights shall not be included in the determination of power consumption.

304.5.3 Fan noise. Whole house ventilation equipment located less than 4 feet (1219 mm) from louvers, grilles or openings shall have a sound rating no greater than 1.5 sones as determined in accordance with HVI 911.

304.5.4 Performance verification. In-field measurements of exhaust fan flows shall be conducted using a manufactured flow-measuring device in accordance with the manufacturer’s instructions. Acceptable devices include a calibrated orifice combined with a digital manometer or a flow hood. All measuring devices shall be accurate to within 10 percent of measured flow.

304.6 Net capacity requirements. Whole house ventilation system fans shall be installed according to the manufacturer’s installation instructions and shall have the manufacturer’s fan flow ratings as listed in accordance with HVI 911. Unless the whole house system is tested according to procedures in Section 304.6.1, the minimum continuous flow rate that the ventilation system must be capable of supplying during its operation shall be based on the rate per bedroom as specified in Table 304.6.

304.6.1 Testing option. Testing may be done to verify that the whole house ventilation system satisfies the ventilation requirements of this section in accordance with Sections 304.6.1.1 and 304.6.1.2.

304.6.1.1 Minimum Outdoor Air. Automatic operation of the ventilation system shall not reduce the minimum continuous ventilation rate below 15 cfm of outdoor air per bedroom plus 15 cfm during occupancy.

304.6.1.2 Performance Verification. In-field measurements of exhaust fan flows shall be conducted using a manufactured flow-measuring device in accordance with the manufacturer’s instructions. Acceptable devices include a calibrated orifice combined with a digital manometer or a flow hood. All measuring devices shall be accurate to within 10 percent of measured flow.

Comment [RF4]: Lifted word-for-word from 2011 version.

GENERAL REQUIREMENTS

TABLE 304.6
PRESCRIPTIVE FAN CAPACITY REQUIREMENTS

NUMBER OF BEDROOMS	MINIMUM NOMINAL RATED TOTAL FAN CAPACITY ^a (at 0.1 inches w.g.)	MINIMUM NUMBER OF FANS TO MEET WHOLE HOUSE AIRFLOW RATES
1	50 cfm	1
2	75 cfm	1
3	100 cfm	1
4	125 cfm	Centrally ducted systems—1 All other systems—2 or more
5	150 cfm	Centrally ducted systems—1 All other systems—2 or more
Homes > 3,000 ft ²	cfm = 0.05 · ft ²	Centrally ducted systems—1 All other systems—2 or more

For SI: 1 cubic foot per minute = 0.0004719 m³/s, 1 cubic foot per minute per square foot = 0.00508 m³/(s · m²).

a. Represents the total installed rated capacity of all fans designed for whole house ventilation.

304.7 Ventilation required during periods of occupancy. Ventilation shall be provided continuously or intermittently during the period that the building is occupied.

304.8 Controls. Whole house ventilation systems shall be capable of being set remotely for continuous operation or shall be provided with an automatic control for intermittent operation. All whole house ventilation controls shall be readily accessible.

Exception: Fans installed expressly for local ventilation purposes.

304.8.1 Intermittent operation. Intermittently operated whole house ventilation systems shall be capable of being set remotely for continuous operation, or shall be provided with an automatic control capable of operating without the need for occupant intervention, such as a time switch or some other control device. Twist or crank-style timers are prohibited as control devices for whole house ventilation systems. Operation controlled solely by a humidity sensor (humidistat or dehumidistat) does not qualify.

304.8.2 Continuous operation. Continuously operated whole house ventilation systems shall not be provided with local controls unless that control only operates the whole house ventilation system both intermittently at high speed and continuously at low speed.

304.8.2.1 On/off switch for continuous operation. An on/off switch for continuously operated whole-house ventilation systems shall be remotely installed and appropriately labeled.

304.9 Installation requirements. Ventilation equipment shall be installed according to the manufacturer's instructions and in accordance with Sections 304.9.1 through 304.9.8.

304.9.1 Fan housings. Fan housings for single-port exhaust only systems must be sealed to the ceiling or wall.

304.9.2 Inlet grills. Inlet grills for multiport exhaust ventilation systems or balanced whole house ventilation systems must be sealed to the ceiling or wall.

304.9.3 Ducts. Smooth wall ducts (PVC or metal) must be used for all duct runs longer than 8 feet (2438 mm). Ducts shall be insulated when installed in an unheated location.

304.9.4 Fasteners. Mechanical fasteners must be used to connect all ducts to the fan(s) without impeding the operation of the fan or any internal backdraft damper.

304.9.5 Joints and connections. All joints, seams and connections shall be securely fastened and sealed with welds, gaskets, mastics (adhesives), mastic embedded fabric systems or approved tapes.

304.9.6 Noise abatement. Remote whole house ventilation fans shall be acoustically isolated from the structural elements of the building and from attached ducts using at least 1 foot (305 mm), but not more than 2 feet (610 mm) of insulated flexible duct.

304.9.7 Intake openings. Mechanical and gravity outside air intake openings for balanced whole house systems, integrated supply systems or heat recovery ventilating systems that are installed in accordance with Section 304 shall be located a minimum of 10 feet (3048 mm) from any hazardous or noxious contaminant, such as vents, chimneys, plumbing vents, fuel fills and vents, streets, alleys, parking lots and loading docks, except as otherwise specified in this code.

The bottom of the intake termination shall be located at least 12 inches (305 mm) above the normally expected snow accumulation level.

304.9.8 Outside opening protection. Air exhaust and intake openings located in exterior walls shall be protected with corrosion-resistant screens, louvers or grilles having a minimum opening size of 1/4 inch (6.4 mm) and a maximum opening size of 1/2 inch (12.7 mm), in any dimension. Openings shall be protected against local weather conditions.

304.10 Clothes dryer exhaust. Clothes dryers shall be exhausted in accordance with the manufacturer's instructions. Dryer exhaust systems shall be independent of all other systems and shall convey the moisture and any products of combustion to the outside of the building.

Exception: This section shall not apply to listed and labeled condensing (ductless) clothes dryers

SECTION 305

COMBUSTION SAFETY (MANDATORY)

305.1 General. The provisions of this section shall govern the requirements for combustion and dilution air for fuel-burning appliances in every new home built to RBES, whenever a new heating system is installed, or whenever alteration, renovation or repair work creates *unusually tight construction* as defined in NFPA 54 and NFPA 31.

305.2 Unusually tight construction. For the purpose of applying the provisions of Section 305 to fuel gas, kerosene and oil-burning equipment, buildings constructed in compliance with the RBES shall be considered so tight that normal infiltration does not meet combustion air requirements, and therefore, of unusually tight construction as defined in NFPA 54 and NFPA 31.

305.3 Fuel gas, kerosene and oil-burning equipment. Every new home built to the RBES that contains Category I or II natural draft venting fuel-burning appliances shall be provided with combustion and dilution air as required by NFPA 54 for fuel-gas utilization equipment or NFPA 31 for oil-burning equipment. Direct vent appliances that do not draw combustion air from inside of the building are not required to be considered in the determination of the combustion and dilution air requirements.

Exception: Where all combustion devices in the home have a sealed combustion venting system, a mechanical draft venting system or are direct-vent appliances, then the combustion and dilution air requirements of this section do not apply.

305.3.1 Crawl space and attic space. For the purposes of applying the provisions of Section 305, an opening to a naturally ventilated crawl space or attic space is not considered equivalent to an opening outdoors and is therefore prohibited for the purposes of supplying combustion and dilution air.

305.3.2 Unvented Room Heaters. Unvented fuel-fired heaters, including room heaters and unvented fireplaces are prohibited.

305.4 Solid fuel-burning appliances and fireplaces. All solid fuel-burning appliances and fireplaces shall meet the provisions of this section.

305.4.1 Gasketed Doors. All solid fuel-burning appliances and fireplaces shall have tight-fitting (defined as gasketed doors with compression closure or compression latch system) metal glass or ceramic doors.

Exception: Any home certified to have passed the Canadian General Standards Board 51.71 "Spillage Test" is not required to have tight-fitting doors. The CGSB Spillage Test creates a "worst-case" condition to determine whether the appliances can vent properly even with the house closed tight and all the exhaust equipment running.

305.4.2 Spillage Testing. All chimney-vented equipment shall establish complete draft without spillage under "worst-case" conditions within two minutes. If any chimney-vented equipment fails this requirement, mechanically

induced pressure relief shall be provided such that the requirement is met.

305.4.2 Exterior air supply requirements. Solid fuel-burning appliances and fireplaces shall be equipped with an exterior air supply according to the provisions of sections 305.4.2.1 through 305.4.2.7.

Exception: Factory-built fireplaces, masonry fireplaces and solid fuel-burning appliances that list exterior air supply ducts as optional or required for proper installation are permitted to be installed with those exterior air supply ducts according to the manufacturer's installation instructions.

305.4.2.1 Combustion air shall not be taken from within the garage, attic, or basement.

305.4.2.2 The exterior air inlet shall not terminate to the exterior higher than the firebox and shall not rise vertically within 18 inches of the firebox.

Exception: Where woodstove or fireplace is installed below grade (in a basement), air intake is permitted to terminate above the firebox if the combustion air supply point is below the firebox and the combustion air intake point is greater than 15 inches below the top of the wood stove or fireplace chimney.

305.4.2.3 The exterior air intake must deliver combustion air to the firebox.

Exception: For older woodstoves and cookstoves where direct connection of combustion air is not possible, combustion air may be delivered within 24 inches of the stove's air intake opening.

305.4.2.4 The air inlet shall be screened with 1/4 inch mesh.

305.4.2.5 The air inlet shall be closable and designed to prevent debris from dropping into the air intake.

305.4.2.6 The exterior air inlet shall be installed so as to remain free of obstruction from snow.

305.4.2.7 Passageway. The combustion air passageway for unlisted exterior air supply ducts shall be a minimum of 6 square inches (3870 mm²) and not more than 55 square inches (0.035 m²). The passageway shall be non-combustible, masonry or 30 gauge (or thicker) metal, have 1 inch clearance to combustibles for the length of the combustion air intake. Combustion air systems for listed fireplaces shall be constructed according to the fireplace manufacturer's instructions.

GENERAL REQUIREMENTS

2015 INTERNATIONAL ENERGY CONSERVATION CODE®

R-27

DRAFT

DRAFT

CHAPTER 4 [RE] RESIDENTIAL ENERGY EFFICIENCY

SECTION R401 GENERAL

R401.1 Scope. This chapter applies to residential buildings.

R401.2 Compliance. Projects shall comply with one of the following:

1. Sections R401 through R404.
2. Section R405 and the provisions of Sections R401 through R404 labeled "Mandatory."
3. An energy rating index (ERI) approach in Section R406.

R401.2.1 Tropical zone. Residential buildings in the tropical zone at elevations below 2,400 feet (731.5 m) above sea level shall be deemed to comply with this chapter where the following conditions are met:

1. Not more than one-half of the occupied space is air conditioned.
2. The occupied space is not heated.
3. Solar, wind or other renewable energy source supplies not less than 80 percent of the energy for service water heating.
4. Glazing in conditioned space has a solar heat gain coefficient of less than or equal to 0.40, or has an overhang with a projection factor equal to or greater than 0.30.
5. Permanently installed lighting is in accordance with Section R404.
6. The exterior roof surface complies with one of the options in Table C402.3 or the roof/ceiling has insulation with an *R* value of R-15 or greater. If present, attics above the insulation are vented and attics below the insulation are unvented.

sional and posted on a wall in the space where the furnace is located, a utility room or an approved location inside the building. Where located on an electrical panel, the certificate shall not cover or obstruct the visibility of the circuit directory label, service disconnect label or other required labels. The certificate shall list the predominant *R* values of insulation installed in or on ceiling/roof, walls, foundation (slab, basement wall, crawlspace wall and floor) and ducts outside conditioned spaces; *U* factors for fenestration and the solar heat gain coefficient (SHGC) of fenestration, and the results from any required duct system and building envelope air leakage testing done on the building. Where there is more than one value for each component, the certificate shall list the value covering the largest area. The certificate shall list the types and efficiencies of heating, cooling and service water heating equipment. Where a gas-fired unvented room heater, electric furnace or baseboard electric heater is installed in the residence, the certificate shall list "gas-fired unvented room heater," "electric furnace" or "baseboard electric heater," as appropriate. An efficiency shall not be listed for gas-fired unvented room heaters, electric furnaces or electric baseboard heaters.

401.3 Certificate of compliance. A certification may be issued and signed by a builder, a licensed professional engineer, a licensed architect or an accredited home energy rating organization. If certification is not issued by a licensed professional engineer, a licensed architect or an accredited home energy rating organization, it shall be issued by the builder. Any certification shall certify that residential construction meets the RBES. The department of public service will develop and make available to the public a certificate that lists key features of the RBES. Any person certifying shall use this certificate or one substantially like it to certify compliance with the RBES. Certification shall be issued by completing and signing a certificate and permanently affixing it to the electrical service panel, without covering or obstructing the visibility of the circuit directory label, service disconnect label or other required labels. The certificate shall certify that the residential building has been constructed in compliance with the requirements of the RBES. The person certifying under this subsection shall provide a copy of the certificate to the department of public service and shall assure that a certificate is recorded and indexed in the town land records. A builder may contract with a licensed professional engineer, a licensed architect or an accredited home energy rating organization to issue certification and to indemnify the builder from any liability to the owner of the residential construction caused by noncompliance with the RBES.

SECTION R402 BUILDING THERMAL ENVELOPE

R402.1 General (Prescriptive). The building thermal envelope shall meet the requirements of Sections R402.1.1 through R402.1.5.

2011 VERMONT RESIDENTIAL BUILDING ENERGY STANDARDS
buildings, or portions thereof, shall be exempt from the

provisions of this code:

1. Low Energy Use Buildings. Those with a peak design rate of energy usage less than 3.4 Btu/h·ft² (10.7 W/m²) or 1.0 watt/ft² (10.7 W/m²) of floor area for space conditioning purposes.

2. Unconditioned Buildings. Those that do not contain *conditioned space*.

3. Mobile homes. Homes subject to Title VI of the National Manufactured Housing Construction and

Safety Standards Act of 1974 (42 U.S.C. §§ 5401- 5426).

4. Hunting camps. Residential buildings shall not include hunting camps.

5. Summer camps. Residential buildings constructed for non-winter occupation with only a biomass (wood) heating system.

6. Owner-built homes. Residential construction by an owner, if all of the following apply:

1. The owner of the residential construction is the *builder*, as defined in 21 V.S.A. §§ 266 a1, and;

7. Roof surfaces have a minimum slope inch of 4 per foot of run. The finished roof does not have water accumulation areas.

8. Operable fenestration provides ventilation area equal to not less than 14 percent of the floor area in each room. Alternatively, equivalent ventilation is provided by a ventilation fan.

9. Bedrooms with exterior walls facing two different directions have operable fenestration or exterior walls facing two directions.

10. Interior doors to bedrooms are capable of being secured in the open position.

11. A ceiling fan or ceiling fan rough-in is provided for bedrooms and the largest space that is not used as a bedroom.

R401.3 Certificate (Mandatory). A permanent certificate shall be completed by the builder or registered design profes-

2. The residential construction is used as a dwelling by the owner, and;

3. The owner in fact directs the details of construction with regard to the installation of materials not in compliance with the RBES, and;

4. The owner discloses in writing to a prospective buyer, before entering into a binding purchase and sales agreement, with respect to the nature and extent of any noncompliance with the RBES. Any statement or certificate given to a prospective buyer shall itemize how the home does not comply with RBES, and shall itemize which measures do not meet the RBES in effect at the time construction commenced.

Exception: The following low-energy buildings, or portions thereof, separated from the remainder of the building by *building thermal envelope* assemblies complying with this section shall be exempt from the *building thermal envelope* provisions of Section R402.

1. Those with a peak design rate of energy usage less

than 3.4 Btu/h·ft² (10.7 W/m²) or 1.0 watt/ft² of floor area for space conditioning purposes.

2. Those that do not contain *conditioned space*.

R402.1.1 Vapor retarder. Wall assemblies in the *building thermal envelope* shall comply with the vapor retarder requirements of Section R702.7 of the *International Residential Code* or Section 1405.3 of the *International Building Code*, as applicable.

R402.1.2 Insulation and fenestration criteria. The *building thermal envelope* shall meet the requirements of Table R402.1.2, R402.1.4 or 402.1.5, based on the climate zone 6 A as specified in Chapter 3.

R402.1.3 R-value computation. Insulation material used in layers, such as framing cavity insulation, or continuous insulation shall be summed to compute the corresponding component *R*-value. The manufacturer's settled *R*-value shall be used for blown insulation. Computed *R*-values

shall not include an R -value for other building materials or air films. Where insulated siding is used for the purpose of complying with the continuous insulation requirements of Table R402.1.2, the manufacturer's labeled R -value for insulated siding shall be reduced by R -0.6.

R402.1.4 U -factor alternative. An assembly with a U -factor equal to or less than that specified in Table R402.1.4 shall be permitted as an alternative to the R -value in Table R402.1.2.

R402.1.5 Total UA alternative. If the total *building thermal envelope* UA (sum of U -factor times assembly area) is less than or equal to the total UA resulting from using the U -factors in Table R402.1.4 (multiplied by the same

assembly area as in the proposed building), the building shall be considered in compliance with Table R402.1.2. The UA calculation shall be done using a method consistent with the ASHRAE *Handbook of Fundamentals* and shall include the thermal bridging effects of framing materials. The SHGC requirements shall be met in addition to UA compliance.

R402.2 Specific insulation requirements (Prescriptive). In addition to the requirements of Section R402.1, insulation shall meet the specific requirements of Sections R402.2.1 through R402.2.13.

R402.2.1 Ceilings with attic spaces. Where Section R402.1.2 would require R -38 insulation in the ceiling,

RESIDENTIAL ENERGY EFFICIENCY

TABLE R402.1.2
INSULATION AND FENESTRATION REQUIREMENTS BY COMPONENT^a

CLIMATE ZONE	FENESTRATION U-FACTOR ^b	SKYLIGHT ^b U-FACTOR	GLAZED FENESTRATION SHGC ^{b, c}	CEILING R-VALUE	WOOD FRAME WALL R-VALUE	MASS WALL R-VALUE ^d	FLOOR R-VALUE	WALL R-VALUE ^e	R-VALUE & DEPTH ^f	CRAWL SPACE ^g WALL R-VALUE
1	NR	0.75	0.25	30	13	3/4	13	0	0	0
2	0.40	0.65	0.25	38	13	4/6	13	0	0	0
3	0.35	0.55	0.25	38	20 or 13+5 ^h	8/13	19	5/13 ⁱ	0	5/13
4 except Marine	0.35	0.55	0.40	49	^h	8/13	19	10/13	10, 2 ft	10/13
5 and Marine 4	0.32	0.55	NR	49	^h	13/17	^g	15/19	10, 2 ft	15/19
6	0.32	0.55	NR	49	20+5 or 13+10 ^h	15/20	30 ^g	15/19	10, 4 ft	15/19
7 and 8	0.32	0.55	NR	49	20+5 or 13+10 ^h	19/21	38 ^g	15/19	10, 4 ft	15/19

For SI: 1 foot = 304.8 mm.

- a. R-values are minimums. U-factors and SHGC are maximums. When insulation is installed in a cavity which is less than the label or design thickness of the insulation, the installed R-value of the insulation shall not be less than the R-value specified in the table.
- b. The fenestration U-factor column excludes skylights. The SHGC column applies to all glazed fenestration. Exception: Skylights may be excluded from glazed fenestration SHGC requirements in climate zones 1 through 3 where the SHGC for such skylights does not exceed 0.30.
- c. "15/19" means R-15 continuous insulation on the interior or exterior of the home or R-19 cavity insulation at the interior of the basement wall. "15/19" shall be permitted to be met with R-13 cavity insulation on the interior of the basement wall plus R-5 continuous insulation on the interior or exterior of the home. "10/13" means R-10 continuous insulation on the interior or exterior of the home or R-13 cavity insulation at the interior of the basement wall.
- d. R-5 shall be added to the required slab edge R-values for heated slabs. Insulation depth shall be the depth of the footing or 2 feet, whichever is less in Climate Zones 1 through 3 for heated slabs.
- e. There are no SHGC requirements in the Marine Zone.
- f. Basement wall insulation is not required in warm humid locations as defined by Figure R301.1 and Table R301.1.
- g-c. Or insulation sufficient to fill the framing cavity, R-19 minimum.
- h-f. The first value is cavity insulation, the second value is continuous insulation, so "13+5" means R-13 cavity insulation plus R-5 continuous insulation.
- i-g. The second R-value applies when more than half the insulation is on the interior of the mass wall.

TABLE R402.1.4
EQUIVALENT U-FACTORS^a

CLIMATE ZONE	FENESTRATION U-FACTOR	SKYLIGHT U-FACTOR	CEILING U-FACTOR	FRAME WALL U-FACTOR	MASS WALL U-FACTOR ^b	FLOOR U-FACTOR	BASEMENT WALL U-FACTOR	CRAWL SPACE WALL U-FACTOR
1	0.50	0.75	0.035	0.084	0.197	0.064	0.360	0.477
2	0.40	0.65	0.030	0.084	0.165	0.064	0.360	0.477
3	0.35	0.55	0.030	0.060	0.098	0.047	0.091 ^c	0.136
4 except Marine	0.35	0.55	0.026	0.060	0.098	0.047	0.059	0.065
5 and Marine 4	0.32	0.55	0.026	0.060	0.082	0.033	0.050	0.055
6	0.32	0.55	0.026	0.045	0.060	0.033	0.050	0.055
7 and 8	0.32	0.55	0.026	0.045	0.057	0.028	0.050	0.055

- a. Nonfenestration U-factors shall be obtained from measurement, calculation or an approved source.
- b. When more than half the insulation is on the interior, the mass wall U-factors shall be a maximum of 0.17 in Climate Zone 1, 0.14 in Climate Zone 2, 0.12 in Climate Zone 3, 0.087 in Climate Zone 4 except Marine, 0.065 in Climate Zone 5 and Marine 4, and 0.057 in Climate Zones 6 through 8.
- c. Basement wall U-factor of 0.360 in warm humid locations as defined by Figure R301.1 and Table R301.1.

TABLE 402.1.5
LOG HOME INSULATION, FENESTRATION AND HEATING REQUIREMENTS BY COMPONENT^a

FENESTRATION U-FACTOR ^b	SKYLIGHT U-FACTOR	MAXIMUM GLAZING AREA ^c	CEILING R-VALUE	LOG WALL ^d	FLOOR R-VALUE ^e	BASEMENT/ CRAWL SPACE WALL R-VALUE ^f	SLAB R-VALUE & DEPTH	HEATED SLAB R-VALUE ^g	HEATING SYSTEM AFUE ^h
0.30	0.55	20%	R-49	≥5" Log	R-38	R-15	R-15, 4 ft.	R-15 edge and under	90% gas/LP, 85% oil

For SI: 1 foot = 304.8 mm.

- a. U-factors are maximums, R-values are minimums.
- b. The fenestration U-factor column excludes skylights.
- c. Glazing area includes window and skylight opening area, plus actual glazed area of glass in doors, as a percentage of wall area. Sunrooms are exempt from this requirement.
- d. Log walls must comply with ICC400 with an average minimum average wall thickness of 5" or greater. Non-log exterior walls shall be insulated to R-20+5.
- e. Or insulation sufficient to fill the framing cavity, with R-38 as the absolute maximum.
- f. Basement walls shall be R-15 continuous insulation or R-20 cavity full basement height.

RESIDENTIAL ENERGY EFFICIENCY

- g. Heated slabs shall be completely insulated around the perimeter and under the entire slab.
h. Boilers must have an outdoor temperature reset or thermal purge control.

installing R-30 over 100 percent of the ceiling area requiring insulation shall be deemed to satisfy the requirement for R-38 wherever the full height of uncompressed R-30 insulation extends over the wall top plate at the eaves. Similarly, where Section R402.1.2 would require R-49 insulation in the ceiling, installing R-38 over 100 percent of the ceiling area requiring insulation shall be deemed to satisfy the requirement for R-49 insulation wherever the full height of uncompressed R-38 insulation extends over the wall top plate at the eaves. This reduction shall not apply to the *U*-factor alternative approach in Section R402.1.4 and the total UA alternative in Section R402.1.5.

R402.2.2 Ceilings without attic spaces. Where Section R402.1.2 would require insulation levels above R-30 and the design of the roof/ceiling assembly does not allow sufficient space for the required insulation, the minimum required insulation for such roof/ceiling assemblies shall be R-30. This reduction of insulation from the requirements of Section R402.1.2 shall be limited to 500 square feet (46 m²) or 20 percent of the total insulated ceiling area, whichever is less. This reduction shall not apply to the *U*-factor alternative approach in Section R402.1.4 and the total UA alternative in Section R402.1.5.

R402.2.3 Eave baffle. For air-permeable insulations in vented attics, a baffle shall be installed adjacent to soffit and eave vents. Baffles shall maintain an opening equal or greater than the size of the vent. The baffle shall extend over the top of the attic insulation. The baffle shall be permitted to be any solid material.

R402.2.4 Access hatches and doors. Access doors from conditioned spaces to unconditioned spaces such as attics and crawl spaces shall be weatherstripped and insulated to a level equivalent to the insulation on the surrounding surfaces. Access shall be provided to all equipment that prevents damaging or compressing the insulation. A wood-framed or equivalent baffle or retainer is required to be provided when loose-fill insulation is installed, the purpose of which is to prevent the loose-fill insulation from spilling into the living space when the attic access is opened, and to provide a permanent means of maintaining the installed *R*-value of the loose-fill insulation.

Exception: Vertical doors that provide access from conditioned to unconditioned spaces shall be permitted to meet the fenestration requirements of Table R402.1.2 based on the applicable climate zone 6A as specified in Chapter 3.

R402.2.5 Mass walls. Mass walls for the purposes of this chapter shall be considered above-grade walls of concrete block, concrete, insulated concrete form (ICF), masonry cavity, brick (other than brick veneer), earth (adobe, compressed earth block, rammed earth) and solid timber/logs, or any other walls having a heat capacity greater than or equal to 6 Btu/ft² × °F (123 kJ/m² × K).

R402.2.6 Steel-frame ceilings, walls and floors. Steel-frame ceilings, walls, and floors shall meet the insulation requirements of Table R402.2.6 or shall meet the *U*-factor requirements of Table R402.1.4. The calculation of

the *U*-factor for a steel-frame envelope assembly shall use a series-parallel path calculation method.

R402.2.7 Walls with partial structural sheathing. Where Section R402.1.2 would require continuous insulation on exterior walls and structural sheathing covers 40 percent or less of the gross area of all exterior walls, the continuous insulation *R*-value shall be permitted to be reduced by an amount necessary to result in a consistent total sheathing thickness, but not more than R-3, on areas of the walls covered by structural sheathing. This reduction shall not apply to the *U*-factor alternative approach in Section R402.1.4 and the total UA alternative in Section R402.1.5.

TABLE R402.2.6
STEEL-FRAME CEILING, WALL AND FLOOR INSULATION (R-VALUE)

WOOD FRAME R-VALUE REQUIREMENT	COLD-FORMED STEEL EQUIVALENT R-VALUE ^a
Steel Truss Ceilings^b	
R-30	R-38 or R-30 + 3 or R-26 + 5
R-38	R-49 or R-38 + 3
R-49	R-38 + 5
Steel Joist Ceilings^b	
R-30	R-38 in 2 × 4 or 2 × 6 or 2 × 8 R-49 in any framing
R-38	R-49 in 2 × 4 or 2 × 6 or 2 × 8 or 2 × 10
Steel-Framed Wall, 16" on center	
R-13	R-13 + 4.2 or R-19 + 2.1 or R-21 + 2.8 or R-0 + 9.3 or R-15 + 3.8 or R-21 + 3.1
R-13 + 3	R-0 + 11.2 or R-13 + 6.1 or R-15 + 5.7 or R-19 + 5.0 or R-21 + 4.7
R-20	R-0 + 14.0 or R-13 + 8.9 or R-15 + 8.5 or R-19 + 7.8 or R-19 + 6.2 or R-21 + 7.5
R-20 + 5	R-13 + 12.7 or R-15 + 12.3 or R-19 + 11.6 or R-21 + 11.3 or R-25 + 10.9
R-21	R-0 + 14.6 or R-13 + 9.5 or R-15 + 9.1 or R-19 + 8.4 or R-21 + 8.1 or R-25 + 7.7
Steel Framed Wall, 24" on center	
R-13	R-0 + 9.3 or R-13 + 3.0 or R-15 + 2.4
R-13 + 3	R-0 + 11.2 or R-13 + 4.9 or R-15 + 4.3 or R-19 + 3.5 or R-21 + 3.1
R-20	R-0 + 14.0 or R-13 + 7.7 or R-15 + 7.1 or R-19 + 6.3 or R-21 + 5.9
R-20 + 5	R-13 + 11.5 or R-15 + 10.9 or R-19 + 10.1 or R-21 + 9.7 or R-25 + 9.1
R-21	R-0 + 14.6 or R-13 + 8.3 or R-15 + 7.7 or R-19 + 6.9 or R-21 + 6.5 or R-25 + 5.9
Steel Joist Floor	
R-13	R-19 in 2 × 6, or R-19 + 6 in 2 × 8 or 2 × 10
R-19	R-19 + 6 in 2 × 6, or R-19 + 12 in 2 × 8 or 2 × 10

^a Cavity insulation *R*-value is listed first, followed by continuous insulation *R*-value.

^b Insulation exceeding the height of the framing shall cover the framing.

DRAFT

R402.2.8 Floors. Floor framing-cavity insulation shall be installed to maintain permanent contact with the underside of the subfloor decking.

Exception: The floor framing-cavity insulation shall be permitted to be in contact with the topside of sheathing or continuous insulation installed on the bottom side of floor framing where combined with insulation that meets or exceeds the minimum wood frame wall *R*-value in Table 402.1.2 and that extends from the bottom to the top of all perimeter floor framing members.

R402.2.9 Basement walls. Walls associated with conditioned basements shall be insulated from the top of the basement wall down to 10 feet (3048 mm) below grade or to the basement floor, whichever is less. Walls associated with unconditioned basements shall meet this requirement unless the floor overhead is insulated in accordance with Sections R402.1.2 and R402.2.8.

R402.2.10 Slab-on-grade floors. Slab-on-grade floors with a floor surface less than 12 inches (305 mm) below grade shall be insulated in accordance with Table R402.1.2. The insulation shall extend downward from the top of the slab on the outside or inside of the foundation wall. Insulation located below grade shall be extended the distance provided in Table R402.1.2 by any combination of vertical insulation, insulation extending under the slab or insulation extending out from the building. Insulation extending away from the building shall be protected by pavement or by not less than 10 inches (254 mm) of soil. The top edge of the insulation installed between the exterior wall and the edge of the interior slab shall be permitted to be cut at a 45-degree (0.79 rad) angle away from the exterior wall. Slab-edge insulation is not required in jurisdictions designated by the ~~code~~ official code official or other authority having jurisdiction as having a very heavy termite infestation.

R402.2.11 Crawl space walls. As an alternative to insulating floors over crawl spaces, crawl space walls shall be permitted to be insulated when the crawl space is not vented to the outside. Crawl space wall insulation shall be permanently fastened to the wall and extend downward from the floor to the finished grade level and then vertically and/or horizontally for at least an additional 24 inches (610 mm). Exposed earth in unvented crawl space foundations shall be covered with a continuous Class I vapor retarder in accordance with the *International Building Code* or *International Residential Code*, as applicable. All joints of the vapor retarder shall overlap by 6 inches (153 mm) and be sealed or taped. The edges of the vapor retarder shall extend not less than 6 inches (153 mm) up the stem wall and shall be attached to the stem wall.

R402.2.12 Masonry veneer. Insulation shall not be required on the horizontal portion of the foundation that supports a masonry veneer.

R402.2.13 Sunroom insulation. Sunrooms enclosing conditioned space shall meet the insulation requirements of this code.

Exception: For sunrooms with thermal isolation, and enclosing conditioned space, the following exceptions to the insulation requirements of this code shall apply:

1. The minimum ceiling insulation *R*-values shall be ~~R-19 in Climate Zones 1 through 4 and R-24 in Climate Zones 5 through 8.~~
2. The minimum wall *R*-value shall be R-13 ~~in all climate zones.~~ Walls separating a sunroom with a thermal isolation from conditioned space shall meet the building thermal envelope requirements of this code.

R402.2.14 Common, party, and fire walls. Whenever continuity of the building thermal envelope is broken at walls separating dwelling units in Group R-2 building, including common, party, and fire walls, such walls shall be insulated to a minimum of R-10 on each side of the break in insulation continuity, and the walls shall be air sealed in accordance with Section 402.4.

R402.3 Fenestration (Prescriptive). In addition to the requirements of Section R402, fenestration shall comply with Sections R402.3.1 through R402.3.6.

R402.3.1 U-factor. An area-weighted average of fenestration products shall be permitted to satisfy the *U*-factor requirements.

R402.3.2 Glazed fenestration SHGC. An area-weighted average of fenestration products more than 50-percent glazed shall be permitted to satisfy the SHGC requirements.

Dynamic glazing shall be permitted to satisfy the SHGC requirements of Table R402.1.2 provided the ratio of the higher to lower labeled SHGC is greater than or equal to 2.4, and the *dynamic glazing* is automatically controlled to modulate the amount of solar gain into the space in multiple steps. *Dynamic glazing* shall be considered separately from other fenestration, and area-weighted averaging with other fenestration that is not dynamic glazing shall not be permitted.

Exception: *Dynamic glazing* is not required to comply with this section when both the lower and higher labeled SHGC already comply with the requirements of Table R402.1.1.

R402.3.3 Glazed fenestration exemption. Up to 15 square feet (1.4 m²) of glazed fenestration per dwelling unit shall be permitted to be exempt from *U*-factor and SHGC requirements in Section R402.1.2. This exemption shall not apply to the *U*-factor alternative approach in Section R402.1.4 and the Total UA alternative in Section R402.1.5.

R402.3.4 Opaque door exemption. One side-hinged opaque door assembly up to 24 square feet (2.22 m²) in area is exempted from the *U*-factor requirement in Section R402.1.4. This exemption shall not apply to the *U*-factor alternative approach in Section R402.1.4 and the total UA alternative in Section R402.1.5.

R402.3.5 Sunroom fenestration. Sunrooms enclosing conditioned space shall meet the fenestration requirements of this code.

Exception: For sunrooms with thermal isolation and enclosing conditioned space, the following exceptions to the fenestration requirements of this code shall apply:

VERMONT RESIDENTIAL BUILDING ENERGY STANDARDS
through 8, the maximum fenestration *U*-factor shall

RESIDENTIAL ENERGY EFFICIENCY

be 0.45 and the maximum skylight *U*-factor shall be 0.7055.

New fenestration separating the *sunroom* with *thermal isolation* from *conditioned space* shall meet the *building thermal envelope* requirements of this code.

2015 INTERNATIONAL ENERGY CONSERVATION CODE*VERMONT RESIDENTIAL BUILDING ENERGY STANDARDS

R-32

R402.4 Air leakage (Mandatory). The ~~building thermal envelope~~ shall be constructed to limit air leakage in accordance with the requirements of Sections R402.4.1 through R402.4.4.

R402.4.1 Building thermal envelope. The ~~building thermal envelope~~ shall comply with Sections R402.4.1.1 and R402.4.1.2. The sealing methods between dissimilar materials shall allow for differential expansion and contraction.

R402.4.1.1 Installation. The components of the ~~building thermal envelope~~ as listed in Table R402.4.1.1 shall be installed in accordance with the manufacturer's instructions and the criteria listed in Table R402.4.1.1, as applicable to the method of construction. Where required by the ~~code official~~*code official or other authority having jurisdiction*, an approved third party shall inspect all components and verify compliance.

R402.4.1.2 Testing. ~~For the Stretch Code, the building or dwelling unit shall be tested and verified as having an air leakage rate not exceeding five air changes per hour in Climate Zones 1 and 2, and three air changes per hour in Climate Zones 3 through 8. Testing shall be conducted in accordance with ASTM E 779 or ASTM E 1827 and reported at a pressure of 0.2 inch w.g. (50 Pascals). Where required by the code official, testing shall be conducted by an approved third party. Testing and verification shall be conducted by an applicable Building Performance Institutes (BPI) Professional, a Home Energy Rating System (HERS) Energy Rater, HERS Field Inspector, or a Vermont Public Service Department approved air leakage tester. A written report of the results of the test shall be signed by the party conducting the test and provided to the code official or other authority having jurisdiction. Testing shall be performed at any time after creation of all penetrations of the building thermal envelope.~~

During testing:

1. Exterior windows and doors, fireplace and stove doors shall be closed, but not sealed, beyond the intended weatherstripping or other infiltration control measures.
2. Dampers including exhaust, intake, makeup air, backdraft and flue dampers shall be closed, but not sealed beyond intended infiltration control measures.
3. Interior doors, if installed at the time of the test, shall be open.
4. Exterior doors for continuous ventilation systems and heat recovery ventilators shall be closed and sealed.
5. Heating and cooling systems, if installed at the time of the test, shall be turned off.
6. Supply and return registers, if installed at the time of the test, shall be fully open.

R402.4.2 Fireplaces. New wood-burning fireplaces shall have tight-fitting flue dampers or doors, and outdoor combustion air. Where using tight-fitting doors on factory-built fireplaces listed and labeled in accordance with UL 127, the doors shall be tested and listed for the fireplace.

Where using tight-fitting doors on masonry fireplaces, the doors shall be listed and labeled in accordance with UL 907.

R402.4.3 Fenestration air leakage. Windows, skylights and sliding glass doors shall have an air infiltration rate of no more than 0.3 cfm per square foot (1.5 L/s/m²), and swinging doors no more than 0.5 cfm per square foot (2.6 L/s/m²), when tested according to NFRC 400 or AAMA/WDMA/CSA 101/1.S.2/A440 by an accredited, independent laboratory and ~~listed and labeled~~ by the manufacturer.

Exception: Site-built windows, skylights and doors.

R402.4.4 Rooms containing fuel-burning appliances. ~~In Climate Zones 3 through 8, Where open combustion air ducts provide combustion air to open combustion fuel burning appliances, the appliances and combustion air opening shall be located outside the building thermal envelope or enclosed in a room, isolated from inside the thermal envelope. Such rooms shall be sealed and insulated in accordance with the envelope requirements of Table R402.1.2, where the walls, floors and ceilings shall meet not less than the basement wall R-value requirement. The door into the room shall be fully gasketed and any water lines and ducts in the room insulated in accordance with Section R403. The combustion air duct shall be insulated where it passes through conditioned space to a minimum of R-8.~~

Exceptions:

1. Direct vent appliances with both intake and exhaust pipes installed continuous to the outside.
2. Fireplaces and stoves complying with Section R402.4.2 and Section R1006 of the *International Residential Code*.

R402.4.5 Recessed lighting. Recessed luminaires installed in the ~~building thermal envelope~~ shall be sealed to limit air leakage between conditioned and unconditioned spaces. All recessed luminaires shall be IC-rated and ~~labeled~~ as having an air leakage rate not more than 2.0 cfm (0.944 L/s) when tested in accordance with ASTM E 283 at a 1.57 psf (75 Pa) pressure differential. All recessed luminaires shall be sealed with a gasket or caulk between the housing and the interior wall or ceiling covering.

R402.5 Maximum fenestration U-factor and SHGC (Mandatory). The area-weighted average maximum fenestration U-factor permitted using tradeoffs from Section R402.1.5 or R405 shall be ~~0.48 in Climate Zones 4 and 5 and 0.40-32 in Climate Zones 6 through 8 for vertical fenestration, and 0.575 in Climate Zones 4 through 8 for skylights. The area-weighted average maximum fenestration SHGC permitted using tradeoffs from Section R405 in Climate Zones 1 through 3 shall be 0.50.~~

Comment [RF5]: Is this still an issue?
Stakeholder input requested.

DRAFT

**TABLE R402.4.1.1
AIR BARRIER AND INSULATION INSTALLATION**

COMPONENT	AIR BARRIER CRITERIA	INSULATION INSTALLATION CRITERIA
General requirements	<p>A continuous, <u>durable</u> air barrier shall be installed in the building envelope.</p> <p>The exterior thermal envelope contains a continuous, <u>durable</u> air barrier.</p> <p>Breaks or joints in the air barrier shall be sealed.</p> <p><u>An air barrier is defined as any durable solid (non-porous) material that completely blocks air flow between conditioned space and unconditioned space, including necessary accessories to provide adequate support to resist positive and negative pressures without displacement or damage. The air barrier should be continuous and be durably connected to all penetrations, windows and other (structural) interruptions.</u></p> <p><u>Open-cell or closed-cell foam shall have a finished thickness > 5.5 in. or 1.5 in., respectively, to qualify as an air barrier unless the manufacturer indicates otherwise.</u></p> <p><u>If flexible air barriers are used, they shall be fully sealed at all seams and edges and supported per manufacturer's installation instructions. Flexible air barriers shall not be made of kraft paper, or other materials that are easily torn. If polyethylene is used, its thickness shall be ≥ 6mil.</u></p>	<p>Air-permeable insulation shall not be used as a sealing material <u>and shall be installed in all vertical walls, sloped ceilings, and floors within the thermal envelope shall be enclosed on all six sides and in contact with a durable, air barrier.</u></p>
Ceiling/attic	<p>The air barrier in any dropped ceiling/soffit shall be aligned with the insulation and any gaps in the air barrier shall be sealed.</p> <p>Access openings, drop down stairs or knee wall doors to unconditioned attic spaces shall be sealed, <u>insulated and gasketed.</u></p>	<p>The insulation in any dropped ceiling/soffit shall be aligned with the air barrier <u>and shall be enclosed on five sides and in contact with a durable, interior air barrier. A top-side air barrier is not required in a flat attic.</u></p>
Walls	<p>The junction of the foundation and sill plate shall be sealed.</p> <p>The junction of the top plate and the top of exterior walls shall be sealed.</p> <p>Knee walls shall be sealed. <u>When part of the thermal envelope, knee wall insulation shall be enclosed on all six sides and in contact with a durable, interior air barrier.</u></p>	<p>Cavities within corners and headers of frame walls shall be insulated by completely filling the cavity with a material having a thermal resistance of R-3 per inch minimum.</p> <p>Exterior thermal envelope insulation for framed walls shall be installed in substantial contact and continuous alignment with the air barrier.</p> <p><u>Exterior thermal envelope insulation for framed walls shall be enclosed on all six sides and in contact with a durable, air barrier.</u></p>
Windows, skylights and doors	<p>The space between window/door jambs and framing, and skylights and framing shall be sealed <u>with minimally-expanding foam.</u></p>	
Rim joists	<p>Rim joists shall include the air barrier. <u>Junctions of the foundation and sill plate, sill plate and rim-band, and rim band and subfloor shall be sealed. When air permeable insulation is installed a durable, interior air barrier shall be installed at the rim joist.</u></p>	<p>Rim joists shall be insulated.</p>
Floors (including above garage and cantilevered floors)	<p>The air barrier shall be installed at any exposed edge of insulation.</p>	<p>Floor framing cavity insulation shall be installed to maintain permanent contact with the underside of subfloor decking, or floor framing cavity insulation shall be permitted to be in contact with the top side of sheathing, or continuous insulation installed on the underside of floor framing and extends from the bottom to the top of all perimeter floor framing members.</p>
Crawl space walls	<p>Exposed earth in unvented crawl spaces shall be covered with a Class I vapor retarder with overlapping joints taped.</p>	<p>Where provided instead of floor insulation, insulation shall be permanently attached to the crawlspace walls.</p>
Shafts, penetrations	<p>Duct shafts, utility penetrations, and flue shafts opening to exterior or unconditioned space shall be sealed. <u>Doors or hatches in knee walls opening to exterior or unconditioned space shall be insulated and gasketed.</u></p>	

RESIDENTIAL ENERGY EFFICIENCY

Narrow cavities		Batts in narrow cavities shall be cut to fit, or narrow cavities shall be filled by insulation that on installation readily conforms to the available cavity space.
Garage separation	Air sealing shall be provided between the garage and conditioned spaces.	
Recessed lighting <u>and appliances</u>	<u>Recessed light fixtures and other appliances (speakers, exhaust fans, light shafts, etc.) installed in the building thermal envelope shall be IC rated, airtight labeled (or "Washington State Approved") and sealed with a gasket or caulk between the housing and the interior wall or ceiling cover. Fixtures and appliances shall maintain required clearances of not less than 1/2" from combustible material and not less than 3" from insulation material, or as required by manufacturer's installation requirements. Recessed light fixtures installed in the building thermal envelope shall be sealed to the drywall.</u>	Recessed light fixtures installed in the building thermal envelope shall be air tight and IC rated.
Plumbing and wiring	<u>All plumbing and wiring penetrations shall be sealed to the air barrier.</u>	<u>Insulation shall be placed between the exterior of the wall assembly and pipes. Batt insulation shall be cut neatly to fit around wiring and plumbing in exterior walls, or insulation that on installation readily conforms to available space shall extend behind piping and wiring and shall be in full contact with all air barriers.</u>
Shower/tub on exterior wall	<u>Exterior walls adjacent to showers and tubs shall have insulation filling any gaps or voids between tub or shower walls and unconditioned space. The air barrier installed at exterior walls adjacent to showers and tubs shall separate them from the showers and tubs.</u>	Exterior walls adjacent to showers and tubs shall have a durable air barrier separating the exterior wall from the shower and tubs and be insulated.
Electrical/phone box on exterior walls	The air barrier shall be installed behind electrical or communication boxes or air-sealed boxes shall be installed.	<u>Insulation completely fills voids between the box and exterior sheathing.</u>
HVAC register boots	HVAC register boots that penetrate building thermal envelope shall be sealed to the subfloor or drywall.	
Concealed sprinklers	When required to be sealed, concealed fire sprinklers shall only be sealed in a manner that is recommended by the manufacturer. Caulking or other adhesive sealants shall not be used to fill voids between fire sprinkler cover plates and walls or ceilings.	
<u>Fireplace</u>	<u>A durable air barrier shall be installed in contact with insulation. Fireplace shall have compression closure doors and combustion air supplied from the outdoors.</u>	

a. In addition, inspection of log walls shall be in accordance with the provisions of ICC-400.

SECTION R403 SYSTEMS

R403.1 Controls (Mandatory). At least one thermostat shall be provided for each separate heating and cooling system.

R403.1.1 Programmable thermostat. The thermostat controlling the primary heating or cooling system of the dwelling unit shall be capable of controlling the heating and cooling system on a daily schedule to maintain different temperature set points at different times of the day. This thermostat shall include the capability to set back or temporarily operate the system to maintain zone temperatures down to 55°F (13°C) or up to 85°F (29°C). The thermostat shall initially be programmed by the manufacturer with a heating temperature set point no higher than 70°F (21°C) and a cooling temperature set point no lower than 78°F (26°C).

R403.1.2 Heat pump supplementary heat (Mandatory). Heat pumps ~~shall not have having~~ supplementary electric-resistance heat ~~shall have controls that, except during defrost, prevent supplemental heat operation when the heat pump compressor can meet the heating load.~~

R403.2 Hot water boiler outdoor temperature setback. Hot water boilers that supply heat to the building through one- or two-pipe heating systems shall have an outdoor setback control that lowers the boiler water temperature based on the outdoor temperature.

R403.3 Ducts. Ducts and air handlers shall be in accordance with Sections R403.3.1 through R403.3.5.

R403.3.1 Insulation (Prescriptive). ~~All supply and return ducts shall be insulated to meet the same R-value requirement that applies to immediately proximal surfaces. Supply and return ducts in attics shall be insulated to a minimum of R-8 where 3 inches (76 mm) in diameter and greater and R-6 where less than 3 inches (76 mm) in diameter. Supply and return ducts in other portions of the building shall be insulated to a minimum of R-6 where 3 inches (76 mm) in diameter or greater and R-4.2 where less than 3 inches (76 mm) in diameter.~~

Exception: Ducts or portions thereof located completely inside the building thermal envelope.

R403.3.2 Sealing (Mandatory). Ducts, air handlers and filter boxes shall be sealed. Joints and seams shall comply with either the *International Mechanical Code* or *International Residential Code*, as applicable.

Exceptions:

1. Air-impermeable spray foam products shall be permitted to be applied without additional joint seals.
2. For ducts having a static pressure classification of less than 2 inches of water column (500 Pa), additional closure systems shall not be required for continuously welded joints and seams, and locking-type joints and seams of other than the snap-lock and button-lock types.

R403.3.2.1 Sealed air handler. Air handlers shall have a manufacturer's designation for an air leakage of no more than 2 percent of the design air flow rate when tested in accordance with ASHRAE 193.

R403.3.3 Duct testing (Mandatory). Ducts shall be pressure tested to determine air leakage by one of the following methods:

1. Rough-in test: Total leakage shall be measured with a pressure differential of 0.1 inch w.g. (25 Pa) across the system, including the manufacturer's air handler enclosure if installed at the time of the test. All registers shall be taped or otherwise sealed during the test.
2. Postconstruction test: Total leakage shall be measured with a pressure differential of 0.1 inch w.g. (25 Pa) across the entire system, including the manufacturer's air handler enclosure. Registers shall be taped or otherwise sealed during the test.

Exception: A duct air leakage test shall not be required where the ducts and air handlers are located entirely within the building thermal envelope.

A written report of the results of the test shall be signed by ~~the party conducting the test~~ an individual certified as either a Building Performance Institute (BPI) Heating Professional or Air Conditioning/Heat Pump Professional, a Home Energy Rating System (HERS) Energy Rater or HERS Field Inspector, and provided to the ~~code official~~ code official or other authority having jurisdiction.

R403.3.4 Duct leakage (Prescriptive). The total leakage of the ducts, where measured in accordance with Section R403.3.3, shall be as follows:

1. Rough-in test: The total leakage shall be less than or equal to ~~43~~ cubic feet per minute (~~113.385.0~~ L/min) per 100 square feet (9.29 m²) of conditioned floor area where the air handler is installed at the time of the test. Where the air handler is not installed at the time of the test, the total leakage shall be less than or equal to 3 cubic feet per minute (85 L/min) per 100 square feet (9.29 m²) of conditioned floor area.
2. Postconstruction test: Total leakage shall be less than or equal to 4 cubic feet per minute (113.3 L/min) per 100 square feet (9.29 m²) of conditioned floor area.

R403.3.5 Building cavities (Mandatory). Building framing cavities shall not be used as ducts or plenums.

R403.4 Mechanical system piping insulation (Mandatory). Mechanical system piping capable of carrying fluids above 105°F (41°C) or below 55°F (13°C) shall be insulated to a minimum of R-3.

R403.4.1 Protection of piping insulation. Piping insulation exposed to weather shall be protected from damage, including that caused by sunlight, moisture, equipment maintenance and wind, and shall provide shielding from solar radiation that can cause degradation of the material. Adhesive tape shall not be permitted.

R403.5 Service-hot water systems. Energy conservation measures for service hot water systems shall be in accordance with Sections R403.5.1 and R403.5.4.

R403.5.1 Heated water circulation and temperature
2011 VERMONT RESIDENTIAL BUILDING ENERGY STANDARDS

RESIDENTIAL ENERGY EFFICIENCY

lation systems shall be in accordance with Section
R403.5.1.1. Heat trace temperature maintenance

systems shall be in accordance with Section R403.5.1.2.
Automatic

2015 ~~INTERNATIONAL ENERGY CONSERVATION CODE~~ VERMONT RESIDENTIAL BUILDING ENERGY STANDARDS

R-35

DRAFT

controls, temperature sensors and pumps shall be accessible. Manual controls shall be readily accessible.

R403.5.1.1 Circulation systems. Heated water circulation systems shall be provided with a circulation pump. The system return pipe shall be a dedicated return pipe or a cold water supply pipe. Gravity and thermosiphon circulation systems shall be prohibited. Controls for circulating hot water system pumps shall start the pump based on the identification of a demand for hot water within the occupancy. The controls shall automatically turn off the pump when the water in the circulation loop is at the desired temperature and when there is no demand for hot water.

R403.5.1.2 Heat trace systems. Electric heat trace systems shall comply with IEEE 515.1 or UL 515. Controls for such systems shall automatically adjust the energy input to the heat tracing to maintain the desired water temperature in the piping in accordance with the times when heated water is used in the occupancy.

R403.5.2 Demand recirculation systems. A water distribution system having one or more recirculation pumps that pump water from a heated water supply pipe back to the heated water source through a cold water supply pipe shall be a *demand recirculation water system*. Pumps shall have controls that comply with both of the following:

1. The control shall start the pump upon receiving a signal from the action of a user of a fixture or appliance, sensing the presence of a user of a fixture or sensing the flow of hot or tempered water to a fixture fitting or appliance.
2. The control shall limit the temperature of the water entering the cold water piping to 104°F (40°C).

R403.5.3 Hot water pipe insulation (Prescriptive). Insulation for hot water pipe with a minimum thermal resistance (*R*-value) of *R*-3 shall be applied to the following:

1. Piping $\frac{3}{4}$ inch (19.1 mm) and larger in nominal diameter.
2. Piping serving more than one dwelling unit.
3. Piping located outside the conditioned space.
4. Piping from the water heater to a distribution manifold.
5. Piping located under a floor slab.
6. Buried in piping.

7. Supply and return piping in recirculation systems other than demand recirculation systems.

R403.5.4 Drain water heat recovery units. Drain water heat recovery units shall comply with CSA B55.2. Drain water heat recovery units shall be tested in accordance with CSA B55.1. Potable water-side pressure loss of drain water heat recovery units shall be less than 3 psi (20.7 kPa) for individual units connected to one or two showers. Potable water-side pressure loss of drain water heat recovery units shall be less than 2 psi (13.8 kPa) for individual units connected to three or more showers.

R403.6 Mechanical ventilation (Mandatory). The building shall be provided with ventilation that meets the requirements of the *International Residential Code* or *International Mechanical Code*, as applicable, or with other approved means of ventilation. Outdoor air intakes and exhausts shall have automatic or gravity dampers that close when the ventilation system is not operating.

R403.6.1 Whole-house mechanical ventilation system fan efficacy. Mechanical ventilation system fans shall meet the efficacy requirements of Table R403.6.1.

Exception: Where mechanical ventilation fans are integral to tested and listed HVAC equipment, they shall be powered by an electronically commutated motor.

R403.7 Equipment sizing and efficiency rating (Mandatory). Heating and cooling equipment shall be sized in accordance with ACCA Manual S based on building loads calculated in accordance with ACCA Manual J or other approved heating and cooling calculation methodologies. New or replacement heating and cooling equipment shall have an efficiency rating equal to or greater than the minimum required by federal law for the geographic location where the equipment is installed [for Climate Zone 6A](#).

R403.8 Systems serving multiple dwelling units (Mandatory). Systems serving multiple dwelling units shall comply with Sections C403 and C404 of the [2015 Vermont Commercial Building Energy Standards \(CBES\)](#) ~~IECC Commercial Provisions~~ in lieu of Section R403.

R403.9 Snow melt and ice system controls (Mandatory). Snow- and ice-melting systems, supplied through energy service to the building, shall include automatic controls capable of shutting off the system when the pavement temperature is above 50°F (10°C), and no precipitation is falling and an automatic or manual control that will allow shutoff when the outdoor temperature is above 40°F (4.8°C). [All energy for snow- and ice-melting systems shall be provided by on-site renewable energy systems.](#)

TABLE R403.6.1
MECHANICAL VENTILATION SYSTEM FAN EFFICACY

FAN LOCATION	AIR FLOW RATE MINIMUM (CFM)	MINIMUM EFFICACY (CFM/WATT)	AIR FLOW RATE MAXIMUM (CFM)
Range hoods	Any	2.8 cfm/watt	Any
In-line fan	Any	2.8 cfm/watt	Any
Bathroom, utility room	10	1.4 cfm/watt	< 90
Bathroom, utility room	90	2.8 cfm/watt	Any

For SI: 1 cfm = 28.3 L/min.

2015 [INTERNATIONAL ENERGY CONSERVATION CODE](#) VERMONT RESIDENTIAL BUILDING ENERGY STANDARDS

DRAFT

R403.10 Pools and permanent spa energy consumption (Mandatory). The energy consumption of pools and permanent spas shall be in accordance with Sections R403.10.1 through R403.10.4.

R403.10.1 Residential pools and permanent residential spas. Swimming pools and permanent spas that are accessory to detached one- and two-family dwellings and townhouses three stories or less in height above grade plane and that are available only to the household and its guests shall be in accordance with APSP-145.

R403.10.2 Heaters. The ~~electric power to~~ heaters shall be controlled by a readily *accessible* on-off switch that is an integral part of the heater mounted on the exterior of the heater, or external to and within 3 feet (914 mm) of the heater. Operation of such switch shall not change the setting of the heater thermostat. Such switches shall be in addition to a circuit breaker for the power to the heater. Gas-fired heaters shall not be equipped with continuously burning ignition pilots.

R403.10.3 Time switches. Time switches or other control methods that can automatically turn off and on according to a preset schedule shall be installed for heaters and pump motors. Heaters and pump motors that have built-in time switches shall be in compliance with this section.

Exceptions:

1. Where public health standards require 24-hour pump operation.
2. Pumps that operate solar- and waste-heat-recovery pool heating systems.

R403.10.4 Covers. Outdoor heated pools and outdoor permanent spas shall be provided with an *insulated* vapor-retardant cover *of at least R-12* or other *approved* vapor-retardant means.

Exception: Where more than 70 percent of the energy for heating, computed over an operation season, is from site-recovered energy, such as from a heat pump or solar energy source, covers or other vapor-retardant means shall not be required.

R403.11 Portable spas (Mandatory). The energy consumption of electric-powered portable spas shall be controlled by the requirements of APSP-14.

R403.12 Residential pools and permanent residential spas. Residential swimming pools and permanent residential spas that are accessory to detached one- and two-family dwellings and townhouses three stories or less in height above grade plane and that are available only to the household and its guests shall be in accordance with APSP-15.

SECTION R404 ELECTRICAL POWER AND LIGHTING SYSTEMS

R404.1 Lighting equipment (Mandatory). Not less than **75** percent of the lamps in permanently installed lighting fixtures shall be high-efficacy lamps or not less than **75** percent of the permanently installed lighting fixtures shall contain only high-efficacy lamps.

Exception: Low-voltage lighting.

R404.1.1 Lighting equipment (Mandatory). Fuel gas lighting systems shall not have continuously burning pilot lights.

404.2 Electric Resistance Heating Equipment. In the City of Burlington, the use of electric resistance heating equipment is prohibited, except where such equipment can be shown to exhibit the lowest life-cycle cost.

SECTION R405 SIMULATED PERFORMANCE ALTERNATIVE (PERFORMANCE)

R405.1 Scope. This section establishes criteria for compliance using simulated energy performance analysis. Such analysis shall include heating, cooling and service water heating energy only.

R405.2 Mandatory requirements. Compliance with this section requires that the mandatory provisions identified in Section R401.2 be met. All supply and return ducts not completely inside the *building thermal envelope* shall be insulated to a minimum of R-6.

R405.3 Performance-based compliance. Compliance based on simulated energy performance requires that a proposed residence (*proposed design*) be shown to have an annual energy cost that is less than or equal to the annual energy cost of the *standard reference design*. Energy prices shall be taken from a source approved by the ~~code official~~ *code official or other authority having jurisdiction*, such as the Department of Energy, Energy Information Administration's *State Energy Price and Expenditure Report*. *Code officials* shall be permitted to require time-of-use pricing in energy cost calculations.

Exception: The energy use based on source energy expressed in Btu or Btu per square foot of *conditioned floor area* shall be permitted to be substituted for the energy cost. The source energy multiplier for electricity shall be 3.16. The source energy multiplier for fuels other than electricity shall be 1.1.

R405.4 Documentation. Documentation of the software used for the performance design and the parameters for the building shall be in accordance with Sections R405.4.1 through R405.4.3.

R405.4.1 Compliance software tools. Documentation verifying that the methods and accuracy of the compliance software tools conform to the provisions of this section shall be provided to the ~~code official~~ *code official or other authority having jurisdiction*.

R405.4.2 Compliance report. Compliance software tools shall generate a report that documents that the *proposed design* complies with Section R405.3. A compliance report on the *proposed design* shall be submitted with the application for the building permit. Upon completion of the building, a compliance report based on the as-built condition of the building shall be submitted to the ~~code official~~ *code official or other authority having jurisdiction* before a certificate of occupancy is issued. Batch sampling of buildings to determine energy code compliance for all buildings in the batch shall be prohibited.

Comment [RF6]: Waiting for response from Jeff Farlow at Pentair who presumably has pool code language, per Mike Russom, EVT.

RESIDENTIAL ENERGY EFFICIENCY

dance with Sections R405.4.2.1 and R405.4.2.2. Where the *proposed design* of a building could be built on different sites where the cardinal orientation of the building on each site is different, compliance of the

proposed design for the purposes of the application for the building permit shall be based on the worst-case orientation, worst-case

DRAFT

configuration, worst-case building air leakage and worst-case duct leakage. Such worst-case parameters shall be used as inputs to the compliance software for energy analysis.

R405.4.2.1 Compliance report for permit application. A compliance report submitted with the application for building permit shall include the following:

1. Building street address, or other building site identification.
2. A statement indicating that the *proposed design* complies with Section R405.3.
3. An inspection checklist documenting the building component characteristics of the *proposed design* as indicated in Table R405.5.2(1). The inspection checklist shall show results for both the *standard reference design* and the *proposed design* with user inputs to the compliance software to generate the results.
4. A site-specific energy analysis report that is in compliance with Section R405.3.
5. The name of the individual performing the analysis and generating the report.
6. The name and version of the compliance software tool.

R405.4.2.2 Compliance report for certificate of occupancy. A compliance report submitted for obtaining the certificate of occupancy shall include the following:

1. Building street address, or other building site identification.
2. A statement indicating that the as-built building complies with Section R405.3.
3. A certificate indicating that the building passes the performance matrix for code compliance and listing the energy saving features of the buildings.
4. A site-specific energy analysis report that is in compliance with Section R405.3.
5. The name of the individual performing the analysis and generating the report.
6. The name and version of the compliance software tool.

R405.4.3 Additional documentation. The ~~code official~~[code official or other authority having jurisdiction](#) shall be permitted to require the following documents:

1. Documentation of the building component characteristics of the *standard reference design*.
2. A certification signed by the builder providing the building component characteristics of the *proposed design* as given in Table R405.5.2(1).
3. Documentation of the actual values used in the software calculations for the *proposed design*.

R405.5 Calculation procedure. Calculations of the performance design shall be in accordance with Sections R405.5.1 and R405.5.2.

R405.5.1 General. Except as specified by this section, the *standard reference design* and *proposed design* shall be configured and analyzed using identical methods and techniques.

R405.5.2 Residence specifications. The *standard reference design* and *proposed design* shall be configured and analyzed as specified by Table R405.5.2(1). Table R405.5.2(1) shall include, by reference, all notes contained in Table R402.1.2.

R405.6 Calculation software tools. Calculation software, where used, shall be in accordance with Sections R405.6.1 through R405.6.3.

R405.6.1 Minimum capabilities. Calculation procedures used to comply with this section shall be software tools capable of calculating the annual energy consumption of all building elements that differ between the *standard reference design* and the *proposed design* and shall include the following capabilities:

1. Computer generation of the *standard reference design* using only the input for the *proposed design*. The calculation procedure shall not allow the user to directly modify the building component characteristics of the *standard reference design*.
2. Calculation of whole-building (as a single *zone*) sizing for the heating and cooling equipment in the *standard reference design* residence in accordance with Section R403.6.
3. Calculations that account for the effects of indoor and outdoor temperatures and part-load ratios on the performance of heating, ventilating and air-conditioning equipment based on climate and equipment sizing.
4. Printed ~~code official~~[code official or other authority having jurisdiction](#) inspection checklist listing each of the *proposed design* component characteristics from Table R405.5.2(1) determined by the analysis to provide compliance, along with their respective performance ratings (*R*-value, *U*-factor, SHGC, HSPF, AFUE, SEER, EF are some examples).

R405.6.2 Specific approval. Performance analysis tools meeting the applicable provisions of Section R405 shall be permitted to be *approved*. Tools are permitted to be *approved* based on meeting a specified threshold for a jurisdiction. The ~~code official~~[code official or other authority having jurisdiction](#) shall be permitted to approve tools for a specified application or limited scope.

R405.6.3 Input values. When calculations require input values not specified by Sections R402, R403, R404 and R405, those input values shall be taken from an *approved* source.

DRAFT

RESIDENTIAL ENERGY EFFICIENCY

TABLE R405.5.2(1)
SPECIFICATIONS FOR THE STANDARD REFERENCE AND PROPOSED DESIGNS

BUILDING COMPONENT	STANDARD REFERENCE DESIGN	PROPOSED DESIGN
Above-grade walls	Type: mass wall if proposed wall is mass; otherwise wood frame.	As proposed
	Gross area: same as proposed	As proposed
	U-factor: as specified in Table R402.1.4	As proposed
	Solar absorptance = 0.75	As proposed
	Remittance-Emittance = 0.90	As proposed
Basement and crawl space walls	Type: same as proposed	As proposed
	Gross area: same as proposed	As proposed
	U-factor: from Table R402.1.4, with insulation layer on interior side of walls	As proposed
Above-grade floors	Type: wood frame	As proposed
	Gross area: same as proposed	As proposed
	U-factor: as specified in Table R402.1.4	As proposed
Ceilings	Type: wood frame	As proposed
	Gross area: same as proposed	As proposed
	U-factor: as specified in Table R402.1.4	As proposed
Roofs	Type: composition shingle on wood sheathing	As proposed
	Gross area: same as proposed	As proposed
	Solar absorptance = 0.75	As proposed
	Emittance = 0.90	As proposed
Attics	Type: vented with aperture = 1 ft ² per 300 ft ² ceiling area	As proposed
Foundations	Type: same as proposed	As proposed
	Foundation wall area above and below grade and soil characteristics: same as proposed	As proposed
Opaque doors	Area: 40 ft ²	As proposed
	Orientation: North	As proposed
	U-factor: same as fenestration from Table R402.1.4	As proposed
Vertical fenestration other than opaque doors	Total area ^b = (a) The proposed glazing area, where the proposed glazing area is less than 15 percent of the conditioned floor area (b) 15 percent of the conditioned floor area, where the proposed glazing area is 15 percent or more of the conditioned floor area	As proposed
	Orientation: equally distributed to four cardinal compass orientations (N, E, S & W).	As proposed
	U-factor: as specified in Table R402.1.4	As proposed
	SHGC: as specified in Table R402.1.2 except that for climates with no requirement (NR) SHGC = 0.40 shall be used.	As proposed
	Interior shade fraction: 0.92-(0.21 × SHGC for the standard reference design)	0.92-(0.21 × SHGC as proposed)
	External shading: none	As proposed
Skylights	None	As proposed
Thermally isolated sunrooms	None	As proposed
Air exchange rate	Air leakage rate of 5 air changes per hour in climate zones 1 and 2, and 3 air changes per hour in climate zones 3 through 8 at a pressure of 0.2 inches w.g (50 Pa). The mechanical ventilation rate shall be in addition to the air leakage rate and the same as in the proposed design, but no greater than $0.01 \times CFA + 7.5 \times (N_{br} + 1)$ where: CFA = conditioned floor area N _{br} = number of bedrooms Energy recovery shall not be assumed for mechanical ventilation.	For residences that are not tested, the same air leakage rate as the standard reference design. For tested residences, the measured air exchange rate ^a . The mechanical ventilation rate ^b shall be in addition to the air leakage rate and shall be as proposed.

TABLE R405.5.2(1)—continued
SPECIFICATIONS FOR THE STANDARD REFERENCE DESIGN AND PROPOSED DESIGNS

BUILDING COMPONENT	STANDARD REFERENCE DESIGN	PROPOSED DESIGN
Mechanical ventilation	None, except where mechanical ventilation is specified by the proposed design, in which case: Annual vent fan energy use: $\text{kWh/yr} = 0.03942 \times CFA + 29,565 \times (N_{br} + 1)$ where: CFA = conditioned floor area N_{br} = number of bedrooms	As proposed
Internal gains	$IGain = 17,900 + 23.8 \times CFA + 4104 \times N_{br}$ (Btu/day per dwelling unit)	Same as standard reference design.
Internal mass	An internal mass for furniture and contents of 8 pounds per square foot of floor area.	Same as standard reference design, plus any additional mass specifically designed as a thermal storage element ^c but not integral to the building envelope or structure.
Structural mass	For masonry floor slabs, 80 percent of floor area covered by R-2 carpet and pad, and 20 percent of floor directly exposed to room air.	As proposed
	For masonry basement walls, as proposed, but with insulation required by Table R402.1.4 located on the interior side of the walls	As proposed
	For other walls, for ceilings, floors, and interior walls, wood frame construction	As proposed
Heating systems ^{d, e}	As proposed for other than electric heating without a heat pump, where the proposed design utilizes electric heating without a heat pump the standard reference design shall be an air source heat pump meeting the requirements of Section C403 of the IECC-Commercial Provisions. Capacity: sized in accordance with Section R403.7	As proposed
Cooling systems ^{d, f}	As proposed Capacity: sized in accordance with Section R403.7.	As proposed
Service water heating ^{d, e, f, g}	As proposed Use: same as proposed design	As proposed $\text{gal/day} = 30 + (10 \times N_{br})$
Thermal distribution systems	Duct insulation: From Section R403.2.1 A thermal distribution system efficiency (DSE) of 0.88 shall be applied to both the heating and cooling system efficiencies for all systems other than tested duct systems. For tested duct systems, the leakage rate shall be 4 cfm (113.3 L/min) per 100 ft ² (9.29 m ²) of conditioned floor area at a pressure of differential of 0.1 inches w.g. (25 Pa).	As tested or as specified in Table R405.5.2(2) if not tested. Duct insulation shall be as proposed.
Thermostat	Type: Manual, cooling temperature setpoint = 75°F; Heating temperature setpoint = 72°F	Same as standard reference

For SI: 1 square foot = 0.93 m², 1 British thermal unit = 1055 J, 1 pound per square foot = 4.88 kg/m², 1 gallon (US) = 3.785 L, °C = (°F-32)/1.8, 1 degree = 0.79 rad.

- a. Where required by the [code official](#) or other authority having jurisdiction, testing shall be conducted by an approved party. Hourly calculations as specified in the ASHRAE *Handbook of Fundamentals*, or the equivalent shall be used to determine the energy loads resulting from infiltration.
- b. The combined air exchange rate for infiltration and mechanical ventilation shall be determined in accordance with Equation 43 of 2001 ASHRAE *Handbook of Fundamentals*, page 26.24 and the "Whole-house Ventilation" provisions of 2001 ASHRAE *Handbook of Fundamentals*, page 26.19 for intermittent mechanical ventilation.
- c. Thermal storage element shall mean a component not part of the floors, walls or ceilings that is part of a passive solar system, and that provides thermal storage such as enclosed water columns, rock beds, or phase-change containers. A thermal storage element must be in the same room as fenestration that faces within 15 degrees (0.26 rad) of true south, or must be connected to such a room with pipes or ducts that allow the element to be actively charged.
- d. For a proposed design with multiple heating, cooling or water heating systems using different fuel types, the applicable standard reference design system capacities and fuel types shall be weighted in accordance with their respective loads as calculated by accepted engineering practice for each equipment and fuel type present.
- e. For a proposed design without a proposed heating system, a heating system with the prevailing federal minimum efficiency shall be assumed for both the standard reference design and proposed design.
- f. For a proposed design home without a proposed cooling system, an electric air conditioner with the prevailing federal minimum efficiency shall be assumed for both the standard reference design and the proposed design.
- g. For a proposed design with a nonstorage-type water heater, a 40-gallon storage-type water heater with the prevailing federal minimum energy factor for the same fuel as the predominant heating fuel type shall be assumed. For the case of a proposed design without a proposed water heater, a 40-gallon storage-type water heater with the prevailing federal minimum efficiency for the same fuel as the predominant heating fuel type shall be assumed for both the proposed design and standard reference design.

DRAFT

RESIDENTIAL ENERGY EFFICIENCY

TABLE R405.5.2(2)
DEFAULT DISTRIBUTION SYSTEM EFFICIENCIES FOR PROPOSED DESIGNS*

DISTRIBUTION SYSTEM CONFIGURATION AND CONDITION	FORCED AIR SYSTEMS	HYDRONIC SYSTEMS ^b
Distribution system components located in unconditioned space	—	0.95
Untested distribution systems entirely located in conditioned space ^c	0.88	1
"Ductless" systems ^d	1	—

For SI: 1 cubic foot per minute = 0.47 L/s, 1 square foot = 0.093 m², 1 pound per square inch = 6895 Pa, 1 inch water gauge = 1250 Pa.

a. Default values given by this table are for untested distribution systems, which must still meet minimum requirements for duct system insulation.

b. Hydronic systems shall mean those systems that distribute heating and cooling energy directly to individual spaces using liquids pumped through closed-loop piping and that do not depend on ducted, forced airflow to maintain space temperatures.

c. Entire system in conditioned space shall mean that no component of the distribution system, including the air-handler unit, is located outside of the conditioned space.

d. Ductless systems shall be allowed to have forced airflow across a coil but shall not have any ducted airflow external to the manufacturer's air-handler enclosure.

SECTION R406 ENERGY RATING INDEX COMPLIANCE ALTERNATIVE

used to determine the ERI and the parameters for the residential building shall be in accordance with Sections R406.6.1 through R406.6.3.

R406.1 Scope. This section establishes criteria for compliance using an Energy Rating Index (ERI) analysis. This approach uses a Home Energy Rating System (HERS) Energy Rating provided by a Vermont Public Service Department-approved accredited HERS provider. The "ERI" referenced herein is the same as the RESNET HERS Index.

R406.2 Mandatory requirements. Compliance with this section requires that the mandatory provisions identified in Sections R401.2 and R403.5.3 be met. The building thermal envelope shall be greater than or equal to levels of efficiency and Solar Heat Gain Coefficient in Table 402.1.2 or 402.1.4 of the 2009 *International Energy Conservation Code*.

Exception: Supply and return ducts not completely inside the building thermal envelope shall be insulated to a minimum of R-6.

R406.3 Energy Rating Index. The Energy Rating Index (ERI) shall be a numerical integer value that is based on a linear scale constructed such that the *ERI reference design* has an Index value of 100 and a *residential building* that uses no net purchased energy has an Index value of 0. Each integer value on the scale shall represent a 1-percent change in the total energy use of the rated design relative to the total energy use of the *ERI reference design*. The ERI shall consider all energy used in the *residential building*.

R406.3.1 ERI reference design. The *ERI reference design* shall be configured such that it meets the minimum requirements of the 2006 *International Energy Conservation Code* prescriptive requirements.

The proposed *residential building* shall be shown to have an annual total normalized modified load less than or equal to the annual total loads of the *ERI reference design*.

R406.4 ERI-based compliance. Compliance based on an ERI analysis requires that the *rated design* be shown to have an ERI less than or equal to the appropriate value listed in Table R406.4 when compared to the *ERI reference design*.

R406.5 Verification by approved agency. Verification of compliance with Section R406 shall be completed by an approved third-party-certified HERS Rater working under the authority of a Vermont PSD-approved accredited HERS Provider.

R406.6 Documentation. Documentation of the software

R406.6.1 Compliance software tools. Documentation verifying that the methods and accuracy of the compliance software tools conform to the provisions of this section shall be provided to the ~~code official~~*code official or other authority having jurisdiction*.

R406.6.2 Compliance report. Compliance software tools shall generate a report that documents that the ERI of the *rated design* complies with Sections R406.3 and R406.4. The compliance documentation shall include the following information:

- 1. Address or other identification of the residential building.
- 2. An inspection checklist documenting the building component characteristics of the *rated design*. The inspection checklist shall show results for both the *ERI reference design* and the *rated design*, and shall

document all inputs entered by the user necessary to reproduce the results.

- 3. Name of individual completing the compliance report.
- 4. Name and version of the compliance software tool.

Exception: Multiple orientations. Where an otherwise identical building model is offered in multiple orientations, compliance for any orientation shall be permitted by documenting that the building meets the performance requirements in each of the four (north, east, south and west) cardinal orientations.

2015 ~~INTERNATIONAL ENERGY CONSERVATION CODE~~*VERMONT RESIDENTIAL BUILDING ENERGY STANDARDS*

TABLE R406.4
MAXIMUM ENERGY RATING INDEX

CLIMATE ZONE	ENERGY RATING INDEX
1	52
2	51
3	51
4	54
5	55
6	54
7	53

R-41

TABLE R406.4 MAXIMUM BASE CODE ENERGY RATING INDEX

Base Code Target	60	Maximum HERS Index to demonstrate code compliance
Sub-Target	65	Maximum HERS Index without any renewables incorporated
Renewables Adder	5	Maximum HERS Index points that can be counted towards Code Target

Note: Includes all residential structures, including log homes.

R406.6.3 Additional documentation. The ~~code official~~ *code official or other authority having jurisdiction* shall be permitted to require the following documents:

1. Documentation of the building component characteristics of the *ERI reference design*.
2. A certification signed by the builder providing the building component characteristics of the *rated design*.
3. Documentation of the actual values used in the software calculations for the *rated design*.

R406.7 Calculation software tools. Calculation software, where used, shall be in accordance with Sections R406.7.1 through R406.7.3.

R406.7.1 Minimum capabilities. Calculation procedures used to comply with this section shall be software tools capable of calculating the ERI as described in Section R406.3, and shall include the following capabilities:

1. Computer generation of the *ERI reference design* using only the input for the *rated design*.

The calculation procedure shall not allow the user to directly modify the building component characteristics of the *ERI reference design*.

2. Calculation of whole building, as a single *zone*, sizing for the heating and cooling equipment in the *ERI reference design* residence in accordance with Section R403.7.
3. Calculations that account for the effects of indoor and outdoor temperatures and part-load ratios on the performance of heating, ventilating and air-conditioning equipment based on climate and equipment sizing.
4. Printed ~~code official~~ *code official or other authority having jurisdiction* inspection checklist listing each of the *rated design* component characteristics determined by the analysis to provide compliance, along with their respective performance ratings.

R406.7.2 Specific approval. Performance analysis tools meeting the applicable sections of Section R406 shall be *approved*. Tools are permitted to be *approved* based on meeting a specified threshold for a jurisdiction. The ~~code official~~ *code official or other authority having jurisdiction* shall approve tools for a specified application or limited scope.

R406.7.3 Input values. When calculations require input values not specified by Sections R402, R403, R404 and R405, those input values shall be taken from an approved source.

RESIDENTIAL ENERGY EFFICIENCY

SECTION R407

VERMONT STRETCH CODE

R407.1 Scope. This section establishes criteria for compliance with Vermont's "Stretch Code", as defined in Act 89 of 2013. Act 250 residential projects and residential buildings in municipalities that adopt the Stretch Code shall demonstrate compliance with the maximum ERI values in Table R407.1. All other requirements in the RBES shall apply.

TABLE R407.1 MAXIMUM STRETCH CODE ENERGY RATING INDEX

Stretch Code Target	54	Maximum HERS Index to demonstrate code compliance
Sub-Target	65	Maximum HERS Index without any renewables incorporated
Renewables Adder	11	Maximum HERS Index points that can be counted towards Code Target

R407.2 Electric Vehicle Charging Facilities. 4% of parking spots (rounded up to the nearest whole number) should have at least a level 1 charging socket within 5 feet of the centerline of the parking space.

1. One 120V AC 20 amp and one 208/240V 40 amp, grounded AC outlet for each parking space, or
2. Electrical panel capacity for one 120V AC 20 amp and one 208/240V 40 amp, grounded AC outlet and install conduit for future outlet for each parking space.

R-42

2015 INTERNATIONAL ENERGY CONSERVATION CODE*VERMONT RESIDENTIAL BUILDING ENERGY STANDARDS

CHAPTER 5 (RE) EXISTING BUILDINGS

**

SECTION R501 GENERAL

shall provide a copy to the State Historic Preservation Office.

R501.1 Scope. The provisions of this chapter shall control the *alteration*, repair, addition and change of occupancy of existing buildings and structures.

R501.1.1 Additions, alterations, or repairs: General.

Additions, alterations, or repairs to an existing building, building system or portion thereof shall comply with Section R502, R503 or R504. Unaltered portions of the existing building or building supply system shall not be required to comply with this code.

R501.2 Existing buildings. Except as specified in this chapter, this code shall not be used to require the removal, *alteration* or abandonment of, nor prevent the continued use and maintenance of, an existing building or building system lawfully in existence at the time of adoption of this code.

R501.3 Maintenance. Buildings and structures, and parts thereof, shall be maintained in a safe and sanitary condition. Devices and systems that are required by this code shall be maintained in conformance to the code edition under which installed. The owner or the owner's authorized agent shall be responsible for the maintenance of buildings and structures. The requirements of this chapter shall not provide the basis for removal or abrogation of energy conservation, fire protection and safety systems and devices in existing structures.

R501.4 Compliance. *Alterations, repairs, additions* and changes of occupancy to, or relocation of, existing buildings and structures shall comply with the provisions for *alterations, repairs, additions* and changes of occupancy or relocation, respectively, in the *International Residential Code, International Building Code, International Fire Code, International Fuel Gas Code, International Mechanical Code, International Plumbing Code, International Property Maintenance Code, International Private Sewage Disposal Code* and NFPA 70.

R501.5 New and replacement materials. Except as otherwise required or permitted by this code, materials permitted by the applicable code for new construction shall be used. Like materials shall be permitted for repairs, provided hazards to life, health or property are not created. Hazardous materials shall not be used where the code for new construction would not permit their use in buildings of similar occupancy, purpose and location.

**** R501.6 Historic buildings.** No provision of this code relating to the construction, *repair, alteration*, restoration and movement of structures, and *change of occupancy* shall be mandatory for *historic buildings* provided a report has been submitted to the ~~code official~~ code official or other authority having jurisdiction and signed by the owner, a registered *design professional*, or a representative of the State Historic Preservation Office or the historic preservation authority having jurisdiction, demonstrating that compliance with that provision would threaten, degrade or destroy the historic form, fabric or function of the building. If a report was signed by anyone other than a representative of the State Historic Preservation Officer, the signatory of the report

SECTION R502 ADDITIONS

R502.1 General. Additions to an existing building, building system or portion thereof shall conform to the provisions of this code as those provisions relate to new construction without requiring the unaltered portion of the existing building or building system to comply with this code. Additions shall not create an unsafe or hazardous condition or overload existing building systems. An addition shall be deemed to comply with this code where the addition alone complies, where the existing building and addition comply with this code as a single building, or where the building with the addition uses no more energy than the existing building. Additions shall be in accordance with Section R502.1.1 or R502.1.2.

R502.1.1 Prescriptive compliance. Additions shall comply with Sections R502.1.1.1 through R502.1.1.4.

R502.1.1.1 Building envelope. New building envelope assemblies that are part of the addition shall comply with Sections R402.1, R402.2, R402.3.1 through R402.3.5, and R402.4.

Exception: Where *nonconditioned* space is changed to conditioned space, the building envelope of the addition shall comply where the UA, as determined in Section 402.1.4, of the existing building and the addition, and any alterations that are part of the proj-

ect, is less than or equal to UA generated for the existing building.

R502.1.1.2 Heating and cooling systems. New heating, cooling and duct systems that are part of the addition shall comply with Sections R403.1, R403.2, R403.3, R403.5 and R403.6.

Exception: Where ducts from an existing heating and cooling system are extended to an addition, duct systems with less than 40 linear feet (12.19 m) in unconditioned spaces shall not be required to be tested in accordance with Section R403.3.3.

R502.1.1.3 Service hot water systems. New service hot water systems that are part of the addition shall comply with Section R403.4.

R502.1.1.4 Lighting. New lighting systems that are part of the addition shall comply with Section R404.1.

R502.1.2 Existing plus addition compliance (Simulated Performance Alternative). Where *nonconditioned* space is changed to conditioned space, the addition shall comply where the annual energy cost or energy use of the addition and the existing building, and any alterations that are part of the project, is less than or equal to the annual energy cost of the existing building when modeled in accordance with Section R405. The addition and any alterations that are part of the project shall comply with Section R405 in its entirety.

Comment [RF7]: How would you test otherwise?

**

SECTION R503 ALTERATIONS

R503.1 General. *Alterations* to any building or structure shall comply with the requirements of the code for new construction. *Alterations* shall be such that the existing building or structure is no less conforming to the provisions of this code than the existing building or structure was prior to the *alteration*.

Alterations to an existing building, building system or portion thereof shall conform to the provisions of this code as they relate to new construction without requiring the unaltered portions of the existing building or building system to comply with this code. Alterations shall not create an unsafe or hazardous condition or overload existing building systems. *Alterations* shall be such that the existing building or structure uses no more energy than the existing building or structure prior to the *alteration*. Alterations to existing buildings shall comply with Sections R503.1.1 through R503.2.

R503.1.1 Building envelope. Building envelope assemblies that are part of the alteration shall comply with Section R402.1.2 or R402.1.4, Sections R402.2.1 through R402.2.12, R402.3.1, R402.3.2, R402.4.3 and R402.4.4.

Exception: The following alterations need not comply with the requirements for new construction provided the energy use of the building is not increased:

1. Storm windows installed over existing fenestration.
2. Existing ceiling, wall or floor cavities exposed during construction provided that these cavities are filled with insulation.
3. Construction where the existing roof, wall or floor cavity is not exposed.
4. Roof recover.
5. Roofs without insulation in the cavity and where the sheathing or insulation is exposed during reroofing shall be insulated either above or below the sheathing.
6. Surface-applied window film installed on existing single pane fenestration assemblies to reduce solar heat gain provided the code does not require the glazing or fenestration assembly to be replaced.

R503.1.1.1 Replacement fenestration. Where some or all of an existing fenestration unit is replaced with a new fenestration product, including sash and glazing, the replacement fenestration unit shall meet the applicable requirements for *U*-factor and SHGC as provided in Table R402.1.4.

R503.1.2 Heating and cooling systems. New heating, cooling and duct systems that are part of the alteration shall comply with Sections R403.1, R403.2, R403.3 and R403.6.

Exception: Where ducts from an existing heating and cooling system are extended, duct systems with less than 40 linear feet (12.19 m) in unconditioned spaces shall

not be required to be tested in accordance with Section R403.3.3.

R503.1.3 Service hot water systems. New service hot water systems that are part of the alteration shall comply with Section R403.4.

R503.1.4 Lighting. New lighting systems that are part of the alteration shall comply with Section 404.1.

Exception: Alterations that replace less than 50 percent of the luminaires in a space, provided that such alterations do not increase the installed interior lighting power.

R503.2 Change in space conditioning. Any nonconditioned or low-energy space that is altered to become *conditioned space* shall be required to be brought into full compliance with this code.

Exception: Where the simulated performance option in Section R405 is used to comply with this section, the annual energy cost of the proposed design is permitted to be 110 percent of the annual energy cost otherwise allowed by Section R405.3.

SECTION R504 REPAIRS

**

R504.1 General. Buildings, structures and parts thereof shall be repaired in compliance with Section R501.3 and this section. Work on nondamaged components necessary for the required *repair* of damaged components shall be considered part of the *repair* and shall not be subject to the requirements for *alterations* in this chapter. Routine maintenance required by Section R501.3, ordinary repairs exempt from *permit*, and abatement of wear due to normal service conditions shall not be subject to the requirements for *repairs* in this section.

R504.2 Application. For the purposes of this code, the following shall be considered repairs:

1. Glass-only replacements in an existing sash and frame.
2. Roof repairs.
3. Repairs where only the bulb and/or ballast within the existing luminaires in a space are replaced provided that the replacement does not increase the installed interior lighting power.

SECTION R505 CHANGE OF OCCUPANCY OR USE

R505.1 General. Spaces undergoing a change in occupancy that would result in an increase in demand for either fossil fuel or electrical energy shall comply with this code.

R505.1 General. Spaces undergoing a change in occupancy that would result in an increase in demand for either fossil fuel or electrical energy shall comply with this code.

R505.2 General. Any space that is converted to a dwelling unit or portion thereof from another use or occupancy shall comply with this code.

Exception: Where the simulated performance option in Section R405 is used to comply with this section, the annual energy cost of the proposed design is permitted to be 110 percent of the annual energy cost otherwise allowed by Section R405.3.

Comment [RF8]: How would you test otherwise?

EXISTING BUILDINGS

R-44
[CODE® VERMONT RESIDENTIAL BUILDING ENERGY STANDARDS](#)

2015 [INTERNATIONAL ENERGY CONSERVATION](#)

DRAFT

CHAPTER 6

REFERENCED STANDARDS

This chapter lists the standards that are referenced in various sections of this document. The standards are listed herein by the promulgating agency of the standard, the standard identification, the effective date and title, and the section or sections of this document that reference the standard. The application of the referenced standards shall be as specified in Section 106.

AAMA

American Architectural Manufacturers Association
1827 Walden Office Square
Suite 550
Schaumburg, IL 60173-4268

Standard reference number	Title	Referenced in code section number
AAMA/WDMA/CSA 101/1.S.2/A C440—11	North American Fenestration Standard/ Specifications for Windows, Doors and Unit Skylights	R402.4.3

ACCA

Air Conditioning Contractors of America
2800 Shirlington Road, Suite 300
Arlington, VA 22206

Standard reference number	Title	Referenced in code section number
Manual J—2011	Residential Load Calculation Eighth Edition.	R403.7
Manual S—13	Residential Equipment Selection	R403.7

APSP

The Association of Pool and Spa Professionals
2111 Eisenhower Avenue
Alexandria, VA 22314

Standard reference number	Title	Referenced in code section number
APSP 14—11	American National Standard for Portable Electric Spa Energy Efficiency	R403.10.1, 403.11
APSP 15a—2013	American National Standard for Residential Swimming Pool and Spa Energy Efficiency.	R403.12

ASHRAE

American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
1791 Tullie Circle, NE
Atlanta, GA 30329-2305

Standard reference number	Title	Referenced in code section number
ASHRAE—2013	ASHRAE Handbook of Fundamentals	R402.1.5, Table R405.5.2(1)
ASHRAE 193—2010	Method of Test for Determining the Airtightness of HVAC Equipment.	R403.3.2.1

REFERENCED STANDARDS

ASTM ASTM International
100 Barr Harbor Drive
West Conshohocken, PA 19428-2859

Standard reference number	Title	Referenced in code section number
C 1363—11	Standard Test Method for Thermal Performance of Building Materials and Envelope Assemblies by Means of a Hot Box Apparatus	R303.1.4.1
E 283—04	Test Method for Determining the Rate of Air Leakage Through Exterior Windows, Curtain Walls and Doors Under Specified Pressure Differences Across the Specimen	R402.4.4
E 779—10	Standard Test Method for Determining Air Leakage Rate by Fan Pressurization	R402.4.1.2
E 1827—11	Standard Test Methods for Determining Airtightness of Building Using an Orifice Blower Door.	R402.4.1.2

CSA CSA Group
8501 East Pleasant Valley
Cleveland, OH 44131-5575

Standard reference number	Title	Referenced in code section number
AAMA/WDMA/CSA 101/1.S.2/A440—11	North American Fenestration Standard/Specification for Windows, Doors and Unit Skylights.	R402.4.3
CSA 55.1—2012	Test Method for measuring efficiency and pressure loss of drain water heat recovery units.	R403.5.4
CSA 55.2—2012	Drain water heat recover units	R403.5.4

DASMA Door and Access Systems Manufacturers Association
1300 Sumner Avenue
Cleveland, OH 44115-2851

Standard reference number	Title	Referenced in code section number
105—92(R2004)—13	Test Method for Thermal Transmittance and Air Infiltration of Garage Doors	R303.1.3

ICC International Code Council, Inc.
500 New Jersey Avenue, NW
6th Floor
Washington, DC 20001

Standard reference number	Title	Referenced in code section number
IBC—15	International Building Code®	R201.3, R303.2, R402.1.1, R501.4
ICC 400—12	Standard on the Design and Construction of Log Structures	Table R402.5.1.1
IECC—15	International Energy Conservation Code®	R101.4.1, 403.8
IECC—09	2009 International Energy Conservation Code®	R406.2
ECC—06	2006 International Energy Conservation Code®	R202, R406.3.1
IFC—15	International Fire Code®	R201.3, R501.4
IFGC—15	International Fuel Gas Code®	R201.3, R501.4
IMC—15	International Mechanical Code®	R201.3, R403.3.2, R403.6, R501.4
IPC—15	International Plumbing Code®	R201.3, R501.4
IPSDC—15	International Private Sewage Disposal Code®	501.4
IPMC—15	International Property Maintenance Code®	501.4
IRC—15	International Residential Code®	R201.3, R303.2, R402.1.1, R402.2.11, R403.3.2, R403.6, R501.4

REFERENCED STANDARDS

IEEE

The Institute of Electrical and Electronic Engineers, Inc.
3 Park Avenue
New York, NY 1016-5997

Standard reference number	Title	Referenced in code section number
515.1—2012	IEEE Standard for the Testing, Design, Installation, and Maintenance of Electrical Resistance Trace Heating for Commercial Applications	R403.5.1.2

NFPA

National Fire Protection Association.
1 Batterymarch Park
Quincy, MA 02169-7471

Standard reference number	Title	Referenced in code section number
70—14	National Electrical Code	R501.4

NFRC

National Fenestration Rating Council, Inc.
6305 Ivy Lane, Suite 140
Greenbelt, MD 20770

Standard reference number	Title	Referenced in code section number
100—2009	Procedure for Determining Fenestration Products <i>U</i> -factors—Second Edition	R303.1.3
200—2009	Procedure for Determining Fenestration Product Solar Heat Gain Coefficients and Visible Transmittance at Normal Incidence—Second Edition	R303.1.3
400—2009	Procedure for Determining Fenestration Product Air Leakage—Second Edition	R402.4.3

UL

UL LLC
333 Pfingsten Road
Northbrook, IL 60062

Standard reference number	Title	Referenced in code section number
127—11	Standard for Factory Built Fireplaces	R402.4.2
515—11	Electrical Resistance Heat Tracing for Commercial and Industrial Applications including revisions through November 30, 2011	R403.5.1.2

US-FTC

United States-Federal Trade Commission
600 Pennsylvania Avenue NW
Washington, DC 20580

Standard reference number	Title	Referenced in code section number
CFR Title 16 (May 31, 2005)	R-value Rule.	R303.1.4

REFERENCED STANDARDS

WDMA Window and Door Manufacturers Association
2025 M Street, NW Suite 800
Washington, DC 20036-3309

Standard reference number	Title	Referenced in code section number
AAMA/WDMA/CSA 101/1.S.2/A440—11	North American Fenestration Standard/Specification for Windows, Doors and Unit Skylights.	R402.4.3

DRAFT

STANDARDS

DRAFT

APPENDIX RA

RECOMMENDED PROCEDURE FOR WORST-CASE TESTING OF ATMOSPHERIC VENTING SYSTEMS UNDER R402.4 OR R405 CONDITIONS □ 5ACH₅₀

Comment [RF9]: Make sure that this aligns with BPI testing procedures that contractors are used to.

(This appendix is informative and is not part of the code.)

SECTION RA101 SCOPE

RA101.1 General. This appendix is intended to provide guidelines for worst-case testing of atmospheric venting systems. Worst-case testing is recommended to identify problems that weaken draft and restrict combustion air.

SECTION RA201 GENERAL DEFINITIONS

COMBUSTION APPLIANCE ZONE (CAZ). A contiguous air volume within a building that contains a Category I or II atmospherically vented appliance or a Category III or IV direct-vent or integral vent appliance drawing combustion air from inside the building or dwelling unit. The CAZ includes, but is not limited to, a mechanical closet, a mechanical room, or the main body of a house or dwelling unit.

DRAFT. The pressure difference existing between the *appliance* or any component part and the atmosphere that causes a continuous flow of air and products of *combustion* through the gas passages of the *appliance* to the atmosphere.

Mechanical or induced draft. The pressure difference created by the action of a fan, blower or ejector that is located between the *appliance* and the *chimney* or vent termination.

Natural draft. The pressure difference created by a vent or *chimney* because of its height and the temperature difference between the *flue* gases and the atmosphere.

SPILLAGE. Combustion gases emerging from an appliance or venting system into the combustion appliance zone during burner operation.

SECTION RA301 TESTING PROCEDURE

RA301.1 Worst-case testing of atmospheric venting systems. Buildings or dwelling units containing a Category I or II atmospherically vented appliance; or a Category III or IV direct-vent or integral vent appliance drawing combustion air from inside of the building or dwelling unit, shall have the Combustion Appliance Zone (CAZ) tested for spillage, acceptable draft and carbon monoxide (CO) in accordance with this section. Where required by the ~~code~~ official code, testing shall be conducted by an *approved* third party. A written report of the results of the test shall be signed by the party conducting the test and provided to the ~~code~~ official code *official or other authority having jurisdiction*. Testing shall be per-

formed at any time after creation of all penetrations of the *building thermal* envelope and prior to final inspection.

Exception: Buildings or dwelling units containing only Category III or IV direct-vent or integral vent appliances that do not draw combustion air from inside of the building or dwelling unit.

The enumerated test procedure as follows shall be complied with during testing:

1. Set combustion appliances to the pilot setting or turn off the service disconnects for combustion appliances. Close exterior doors and windows and the fireplace damper. With the building or dwelling unit in this configuration, measure and record the baseline ambient pressure inside the building or dwelling unit CAZ. Compare the baseline ambient pressure of the CAZ to that of the outside ambient pressure and record the difference (Pa).
2. Establish worst case by turning on the *clothes dryer* and all exhaust fans. Close all interior doors that make the CAZ pressure more negative. Turn on the air handler, where present, and leave on if, as a result, the pressure in the CAZ becomes more negative. Check interior door positions again, closing only the interior doors that make the CAZ pressure more negative. Measure net change in pressure from the CAZ to outdoor ambient pressure, correcting for the base ambient pressure inside the home. Record "worst case depressurization" pressure and compare to Table RA301.1(1).

Where CAZ depressurization limits are exceeded under worst-case conditions in accordance with Table A301.1(1), additional combustion air shall be provided or other modifications to building air-leakage performance or exhaust appliances such that depressurization is brought within the limits prescribed in Table RA301.1(1).

3. Measure worst-case spillage, acceptable draft and carbon monoxide (CO) by firing the fuel-fired appliance with the smallest Btu capacity first.
 - a. Test for spillage at the draft diverter with a mirror or smoke puffer. An appliance that continues to spill flue gases for more than 60 seconds fails the spillage test.
 - b. Test for CO measuring undiluted flue gases in the throat or flue of the appliance using a digital gauge in parts per million (ppm) at the 10-minute mark. Record CO ppm readings to be compared with Table

DRAFT

APPENDIX RA

RA301.1(3) upon completion of Step 4. Where the spillage test fails under worst case, go to Step 4.

- c. Where spillage ends within 60 seconds, test for acceptable draft in the connector not less than 1 foot (305 mm), but not more than 2 feet (610 mm) downstream of the draft diverter. Record draft pressure and compare to Table RA301.1(2).
- d. Fire all other connected appliances simultaneously and test again at the draft diverter of each appliance for spillage, CO and acceptable draft using procedures 3a through 3c.
4. Measure spillage, acceptable draft, and carbon monoxide (CO) under natural conditions—without *clothes dryer* and exhaust fans on—in accordance with the pro-

cedure outlined in Step 3, measuring the net change in pressure from worst case condition in Step 3 to natural in the CAZ to confirm the worst case depressurization taken in Step 2. Repeat the process for each appliance, allowing each vent system to cool between tests.

5. Monitor indoor ambient CO in the breathing zone continuously during testing, and abort the test where indoor ambient CO exceeds 35 ppm by turning off the appliance, ventilating the space, and evacuating the building. The CO problem shall be corrected prior to completing combustion safety diagnostics.
6. Make recommendations based on test results and the retrofit action prescribed in Table RA301.1(3).

**TABLE RA301.1(1)
CAZ DEPRESSURIZATION LIMITS**

VENTING CONDITION	LIMIT (Pa)
Category I, atmospherically vented water heater	-2.0
Category I or II atmospherically vented boiler or furnace common-vented with a Category I atmospherically vented water heater	-3.0
Category I or II atmospherically vented boiler or furnace, equipped with a flue damper, and common vented with a Category I atmospherically vented water heater	-5.0
Category I or II atmospherically vented boiler or furnace alone	
Category I or II atmospherically vented, fan-assisted boiler or furnace common vented with a Category I atmospherically vented water heater	
Decorative vented, gas appliance	
Power-vented or induced-draft boiler or furnace alone, or fan-assisted water heater alone	-15.0
Category IV direct-vented appliances and sealed combustion appliances	-50.0

For SI: 6894.76 Pa = 1.0 psi.

**TABLE RA301.1(2)
ACCEPTABLE DRAFT TEST CORRECTION**

OUTSIDE TEMPERATURE (°F)	MINIMUM DRAFT PRESSURE REQUIRED (Pa)
< 10	-2.5
10 – 90	(Outside Temperature ÷ 40) – 2.75
> 90	-0.5

For SI: 6894.76 Pa = 1.0 psi.

**TABLE RA301.1(3)
ACCEPTABLE DRAFT TEST CORRECTION**

CARBON DIOXIDE LEVEL (ppm)	AND OR	SPILLAGE AND ACCEPTABLE DRAFT TEST RESULTS	RETROFIT ACTION
0 – 25	and	Passes	Proceed with work
25 < □ □ 100	and	Passes	Recommend that CO problem be resolved
25 < □ □ 100	and	Fails in worst case only	Recommend an appliance service call and repairs to resolve the problem
100 < □ □ 400	or	Fails under natural conditions	Stop! Work shall not proceed until appliance is serviced and problem resolved
> 400	and	Passes	Stop! Work shall not proceed until appliance is serviced and problem resolved
> 400	and	Fails under any condition	Emergency! Shut off fuel to appliance and call for service immediately

STANDARDS

DRAFT

APPENDIX RB

SOLAR-READY PROVISIONS—DETACHED ONE- AND TWO-FAMILY DWELLINGS, MULTIPLE SINGLE-FAMILY DWELLINGS (TOWNHOUSES)

(The provisions contained in this appendix are not mandatory unless specifically referenced in the adopting ordinance.)

SECTION RB101— SCOPE

RB101.1 General. These provisions shall be applicable for new construction where solar-ready provisions are required.

SECTION RB102— GENERAL DEFINITION

SOLAR-READY ZONE. A section or sections of the roof or building overhang designated and reserved for the future installation of a solar photovoltaic or solar thermal system.

SECTION RB103— SOLAR-READY ZONE

RB103.1 General. New detached one- and two-family dwellings, and multiple single-family dwellings (townhouses) with not less than 600 square feet (55.74 m²) of roof area oriented between 110 degrees and 270 degrees of true north shall comply with Sections RB103.2 through RB103.8.

Exceptions:

1. New residential buildings with a permanently installed on-site renewable energy system.
2. A building with a solar-ready zone that is shaded for more than 70 percent of daylight hours annually.

RB103.2 Construction document requirements for solar-ready zone. Construction documents shall indicate the solar-ready zone.

RB103.3 Solar-ready zone area. The total solar-ready zone area shall be not less than 200 square feet (27.87 m²) exclusive of mandatory access or set-back areas as required by the *International Fire Code*. New multiple single-family dwellings (townhouses) three stories or less in height above grade plane and with a total floor area less than or equal to 2,000 square feet (185.8 m²) per dwelling shall have a solar-ready zone area of not less than 150 square feet (13.94 m²). The solar-ready zone shall be composed of areas not less than 5 feet (1524 mm) in width and not less than 80 square feet (7.44 m²) exclusive of access or set-back areas as required by the *International Fire Code*.

RB103.4 Obstructions. Solar-ready zones shall be free from obstructions, including but not limited to vents, chimneys, and roof-mounted equipment.

RB103.5 Roof load documentation. The structural design loads for roof dead load and roof live load shall be clearly indicated on the construction documents.

RB103.6 Interconnection pathway. Construction documents shall indicate pathways for routing of conduit or plumbing from the solar-ready zone to the electrical service panel or service hot water system.

RB103.7 Electrical service reserved space. The main electrical service panel shall have a reserved space to allow installation of a dual pole circuit breaker for future solar electric installation and shall be labeled "For Future Solar Electric." The reserved space shall be positioned at the opposite (load) end from the input feeder location or main circuit location.

RB103.8 Construction documentation certificate. A permanent certificate, indicating the solar-ready zone and other requirements of this section, shall be posted near the electrical distribution panel, water heater or other conspicuous location by the builder or registered design professional.

DRAFT

INDEX

A

ACCESS HATCHES	R402.2.4
ADDITIONS	
Defined	R202
Requirements	R501.1.1, R502
ALTERATIONS	
Defined	R202
Requirements	503
ADMINISTRATION	Chapter 1
AIR BARRIER	
Installation	R402.4.1.1, Table R402.4.1.1
Testing	???
AIR ECONOMIZERS	
Defined	R202
AIR INFILTRATION	
Defined	R202
Requirements	R402.8
AIR LEAKAGE	R402.4, R403.3.3, R403.3.4
ALTERNATE MATERIALS	R102
APPROVED	
Defined	R202
AUTOMATIC	
Defined	R202
ATMOSPHERIC VENTING	Appendix RA
Worst case testing	RA103

B

BASEMENT WALLS	
Defined	R202
Requirements	R303.2.1, Table R402.1.2, Table R402.1.3, R402.2.8, Table R405.5.2(1)
BELOW-GRADE WALLS (see BASEMENT WALLS)	
BOARD OF APPEALS	R109
Qualifications of members	R109.3
BUILDING	
Defined	R202
BUILDING THERMAL ENVELOPE	
Air tightness	R402.4.1
Compliance documentation	R103.2, R401.2
Defined	R202
Insulation	R303.1.1
Insulation and fenestration criteria	R402.1.2
Performance method	Table R405.5.2(1)
Requirements	R102.1.1, R402

C

CEILINGS	R402.2.1, R402.2.2
Specification for standard reference design	Table R405.5.2(1)
CERTIFICATE	R401.3, B103.8
CHANGE OF OCCUPANCY	R505
CIRCULATION SYSTEMS	R403.5.1
CLIMATE TYPES	
Defined	Table R301.3(1)
CLIMATE ZONES	R301, Figure R301.1, Table R301.1
By state or territory	Figure R301.1, Table R301.1
International climate zones	R301.3, Table R301.3(1), Table R301.3(2)
Tropical	R301.4
Warm humid	R301.2, Table R301.2, R301.3.1
CODE OFFICIAL	
Defined	R202
COMMERCIAL BUILDINGS	
Compliance	R101.5
Defined	R202
COMPLIANCE AND ENFORCEMENT	R101.5
Compliance Report	R405.4.2.2
CONDITIONED FLOOR AREA	
Defined	R202
CONDITIONED SPACE	
Defined	R202
CONSTRUCTION DOCUMENTS	R103
Amended	R103.4
Approval	R103.3.1
Examination	R103.3
Information required	R103.2
Phased	R103.3.3
Previous	R103.3.2
Retention	R103.5
Thermal envelope depiction	R405.4.2.2
CONTINUOUS AIR BARRIER	
Defined	R202
CONTROLS	
Heat pump	R403.1.1
Heating and cooling	R403.1
Service water heating	R403.5
CRAWL SPACE WALLS	
Defined	R202
Requirements	R303.2.1, Table R402.1.2, Table R402.1.3, R402.1.4, R402.2.10, Table R405.5.2(1)

D

DEFAULT DISTRIBUTION	
SYSTEM EFFICIENCIES	Table R405.5.2(2)
DEFINITIONS	Chapter 2
DEGREE DAY COOLING	Table R301.3(2)
DEGREE DAY HEATING	Table R301.3(2)
DEMAND RECIRCULATION WATER SYSTEM	
Defined	R202
Requirements	R403.5.2
DESIGN CONDITIONS	Chapter 3, R302
DOORS	
Attics and crawl spaces	R402.2.4
Default <i>U</i> -factors	Table R303.1.3(2)
Opaque	R402.3.4
Performance requirements	Table R405.5.2(1)
SHGC values	Table R402.1.2
<i>U</i> -values	Table R402.1.4
DUCTS	
Defined	R202
Insulation	R103.2, R401.3, R403.3, R403.3.1
Sealing	R103.2, R403.3.2
Tightness verification	
Postconstruction test	R403.3.2
Rough-in test	R403.3.2
DUCT SYSTEM	
Defined	R202
DWELLING UNIT	
Defined	R202
Multiple units	R403.8
DYNAMIC GLAZING	R402.3.2
Defined	R202

E

EAVE BAFFLE	
Installation	R402.2.3
ELECTRICAL POWER AND LIGHTING	R404
ENERGY ANALYSIS, ANNUAL	
Defined	R202
Documentation	R405.4
Requirements	R405.3
ENERGY COST	
Defined	R202
Energy rating index compliance alternative	R406
Energy rating index	R406.3
ERI-based compliance	R406.4
ENERGY RECOVERY VENTILATION SYSTEMS	
Defined	R202
Requirements	Table R405.5.2(1)

ENERGY SIMULATION TOOL

Defined	R202
ENTRANCE DOOR	
Defined	R202
ENVELOPE, BUILDING THERMAL	
Defined	R202
ENVELOPE DESIGN PROCEDURES	R402
EQUIPMENT EFFICIENCIES	R103.2, R401.3
EQUIPMENT ROOM	
Defined	R202
EXISTING BUILDINGS	Chapter 5
EXTERIOR WALLS	
Defined	R202
Thermal performance	R402, R402.1.2, Table R405.5.2(1)

F

FEES	R107
Refunds	R107.5
Related fees	R107.4
Schedule of permit fees	R107.2
FENESTRATION	R303.1.3, R402.3, R402.3.2, R402.4.3
Default <i>U</i> -factors	Table R303.1.3(1)
Defined	R202
Rating and labeling	R303.1.3, R402.1.1
Replacement	R402.3.6
Requirements	Table R402.1.2
FENESTRATION PRODUCT, FIELD-FABRICATED	
Defined	R202
FENESTRATION PRODUCT, SITE-BUILT	
Defined	R202
FIREPLACES	R402.4.2
FLOORS	
Above-grade	Table R405.5.2(1)
Insulation	R402.2.7
Slab-on-grade insulation requirements	R402.2.9
FOUNDATIONS	
Requirements	Table R402.5.1.1, Table R405.5.2(1)
FURNACE EFFICIENCY	Table R405.5.2(1)

G

GLAZED FENESTRATION	R402.3.2, R402.3.3
----------------------------	--------------------

INDEX

H

HEAT PUMP	R403.1.2
HEAT TRAPS	
Defined	R202
HEATED SLAB	
Defined	R202
HEATING AND COOLING LOADS ..	R302.1, R403.1.2
HIGH-EFFICACY LAMPS	
Defined	R202
HISTORIC BUILDINGS	R101.4.2
HOT WATER	
Piping insulation	R403.4.2, Table R403.4.2
HOT WATER BOILER	
Outdoor temperature setback	R403.2
HVAC SYSTEMS	
Tests	
Postconstruction	R403.3.4
Rough-in-test	R403.3.4

I

IDENTIFICATION (MATERIALS, EQUIPMENT AND SYSTEM)	R303.1
INDIRECTLY CONDITIONED SPACE (see CONDITIONED SPACE)	
INFILTRATION, AIR LEAKAGE	R402.4, Table R405.5.2(1)
Defined	R202
INSPECTIONS	R104
INSULATION	
Basement walls	R402.2.9
Ceilings with attic spaces	R402.2.1
Ceilings without attic spaces	R402.2.2
Crawl space walls	R402.2.10
Duct	R403.2.1
Eave baffle	R402.2.3
Floors	R402.2.8
Hot water piping	R403.4.2
Identification	R303.1, R303.1.2
Installation	R303.1.1, R303.1.1.1, R303.1.2, R303.2, Table R402.4.1.2
Masonry veneer	R402.2.11
Mass walls	R402.2.5
Mechanical system piping	R403.3
Product rating	R303.1.4
Protection of exposed foundation	R303.2.1
Protection of piping insulation	R403.3.1
Requirements	Table R402.1.1, R402.2
Slab-on-grade floors	R402.2.9
Steel-frame ceilings, walls and floors	R402.2.6, Table R402.2.6

Sunroom	R402.2.12
INSULATING SHEATHING	
Defined	R202
Requirements	Table R402.1.2, R402.1.2

L

LABELED	
Defined	R202
Requirements	R303.1.3, R303.3, R402.4.3
LIGHTING POWER	
Manufacturer's information	R102.2, R102.3
LIGHTING SYSTEMS	R404
Recessed	R402.4.4, R404
LISTED	
Defined	R202
LOW ENERGY BUILDINGS	R101.5.2
LOW-VOLTAGE LIGHTING	
Defined	R202
LUMINAIRE	
Sealed	R402.4.3

M

MAINTENANCE INFORMATION	R102.3
MANUALS	R101.5.1, R102.3
Defined	R202
MASONRY VENEER	
Insulation	R402.2.12
MASS	
Wall	402.1.2, R402.1.3, R402.2.5, Table R402.2.6
MATERIALS AND EQUIPMENT	R303
MECHANICAL SYSTEMS AND EQUIPMENT	R403, R405.1
MECHANICAL VENTILATION	R403.6, Table R403.5.1, Table R405.5.2(1)
MULTIPLE DWELLING UNITS	R403.8

O

OCCUPANCY	
Requirements	R101.4.4, R101.4.6, R101.5
OPAQUE DOORS	R402.3.4

P

PERFORMANCE ANALYSIS	R405
PERMIT (see FEES)	
Work commencing before permit	R107.3
PIPE INSULATION	R403.4, R403.5

PLANS AND SPECIFICATIONS	R103
POOLS	R403.10
Covers	R403.10.4
Heaters	R403.10.2
Time switches	R403.10.3
PROPOSED DESIGN	
Defined	R202
Requirements	R405, Table R405.5.2(1)
PUMPS	
Time switches	R403.10.3

R

R-VALUE	
Defined	R202
Computation	R402.1.3
Wood frame to cold formed steel frame ceiling, wall and floor insulation <i>R</i> -values	Table R402.2.6
READILY ACCESSIBLE	
Defined	R202
REFERENCED STANDARDS	R106, Chapter 6
REPAIR	
Defined	R202
Requirements	R504
RESIDENTIAL BUILDINGS	
Compliance	R101.2, R101.5
Defined	R202
Simulated performance alternative	R405
ROOF ASSEMBLY	
Defined	R202
Requirements	R101.4.3, R303.1.1.1, R402.2.2, Table R405.5.2(1)

S

SCOPE	R101.2
SERVICE HOT WATER	
Requirements	R403.5
SHEATHING, INSULATING (see INSULATING SHEATHING)	
SHGC (see SOLAR HEAT GAIN COEFFICIENT)	
SHUTOFF DAMPERS	R403.6
SIMULATED PERFORMANCE	
ALTERNATIVE	R405
Documentation	R405.4
Mandatory requirements	R405.2
Performance-based compliance	R405.3
Report	R405.4.2
Software tools	R405.4.1

SIZING

Equipment and system	R405.6.1
SKYLIGHTS	R303.1.3, R402.1.2, R402.3, Table R405.5.2(1)
Defined	R202
SNOW MELT SYSTEM CONTROLS	R403.9
SOLAR HEAT GAIN COEFFICIENT (SHGC)	
R102.1.3, R104.2, Table R303.1.3(3), R401.3, Table R402.1.2, R402.1.4, R402.3.2, R402.3.3, R402.3.6, R402.5	
Defined	R202
STANDARD REFERENCE DESIGN	
Defined	R202
Requirements	R405, Table R405.5.2(1)
STANDARDS, REFERENCED	R106, Chapter 5
STEEL FRAMING	R402.2.6
STOP WORK ORDER	R108
Authority	R108.1
Emergencies	R108.3
Failure to comply	R108.4
Issuance	R108.2
SUNROOM	R402.2.13, R402.3.5, Table R405.5.2(1)
Defined	R202
Insulation	R402.2.13
SWIMMING POOLS	R403.9

T

THERMAL CONDUCTANCE (see C-Factor)	
THERMAL ISOLATION	R402.2.12, R402.3.5, Table R405.5.2(1)
Defined	R202
THERMAL MASS (see MASS)	
THERMAL RESISTANCE (see R-VALUE)	
THERMAL TRANSMITTANCE (see U-FACTOR)	
THERMOSTAT	
Defined	R202
Controls	R403.1
Programmable	R403.1.1
TIME SWITCHES	R403.9.2
TOTAL BUILDING PERFORMANCE	
Residential	R405
TOWNHOUSE (see RESIDENTIAL BUILDINGS)	
TROPICAL CLIMATE ZONES	R301.4, R401.2.1

U

U-FACTOR

Alternative	R402.1.3, Table R402.1.3, R402.1.4
Default door	Table R303.1.3(2)

INDEX

Default glazed fenestration Table R303.1.3(1)
Defined R202, R402.3.1, R402.5
Skylights . Table R402.1.1, Table R402.1.3, R402.3.5
Sunroom R402.3.5

V

VALIDITY R105
VAPOR RETARDER R402.1.1
VENTILATION R401.2.1, R403.6,
Table R403.6.1, Table R405.5.2(1)
Defined R202
VISIBLE TRANSMITTANCE (VT)
Default glazed fenestration Table R303.1.3(3)
Defined R202

W

WALL

Above-grade, defined R202
Standard reference design Table R405.5.2(1)
Basement, defined R202
Installation R402.2.9
Standard reference design Table R405.5.2(1)
Crawlspace, defined R202
Installation R402.2.11
Standard reference design Table R405.5.2(1)
Exterior, defined R202
Mass R402.2.5
Steel-frame R402.2.6, Table R402.2.6
With partial structural sheathing R402.2.7

WALLS (see EXTERIOR WALLS AND BUILDING THERMAL ENVELOPE)

WALLS ADJACENT TO UNCONDITIONED SPACE (see BUILDING THERMAL ENVELOPE)

WATER HEATING R401.3, R403.4, R405.1,
Table R405.5.2(1)

WHOLE HOUSE MECHANICAL VENTILATION SYSTEM


Defined R202
System fan efficacy R403.6.1

WINDOW AREA

(see FENESTRATION and GLAZING AREA)

DRAFT

DRAFT



DRAFT