

NOTE: ICC will publish the final document and complete all final formatting

2015 RBES

Vermont Residential Building Energy Standards
Based on the:

2015 IECC
INTERNATIONAL
Energy Conservation Code®



2015 Vermont Residential Building Energy Standards

First Draft: XXXX, 2014

ISBN:

COPYRIGHT © 2014
by
INTERNATIONAL CODE COUNCIL, INC.

Date of First Publication: XX, 2014

ALL RIGHTS RESERVED. This [VT Code], contains substantial copyrighted material from the [International Code], which is a copyrighted work owned by the International Code Council, Inc. and which has been reproduced by [VT] with the written permission of the International Code Council. Vermont specific additions and changes are designated through markings in the margin. The ICC copyright does not pertain to the Vermont specific additions. Without advance written permission from the copyright owner, the ICC portion of this book may not be reproduced, distributed or transmitted in any form or by any means, including, without limitation, electronic, optical or mechanical means (by way of example and not limitation, photocopying, or recording by or in an information storage retrieval system). For information on permission to copy material exceeding fair use, please contact: Publications, 4051 West Flossmoor Road, Country Club Hills, IL 60478. Phone 1-888-ICC-SAFE (422-7233).

Trademarks: “International Code Council,” the “International Code Council” logo and the “International Energy Conservation Code” are trademarks of the International Code Council, Inc.

To receive free copies of the [VT Code] please contact the Vermont Department of Public Service at 1-802-828-2811.

PRINTED IN THE U.S.A.

PREFACE

Introduction

Internationally, code officials recognize the need for a modern, up-to-date energy conservation code addressing the design of energy-efficient building envelopes and installation of energy efficient mechanical, lighting and power systems through requirements emphasizing performance. The 2015 *Vermont Residential Building Energy Standards* (RBES) is based on the *International Energy Conservation Code*® 2015 edition, and is designed to meet these needs through model code regulations that will result in the optimal utilization of fossil fuel and non-depletable resources in all communities, large and small.

This comprehensive energy conservation code establishes minimum regulations for energy efficient buildings using prescriptive and performance-related provisions. It is founded on broad-based principles that make possible the use of new materials and new energy efficient designs.

The International Energy Conservation Code provisions provide many benefits, among which is the model code development process that offers an international forum for energy professionals to discuss performance and prescriptive code requirements. This forum provides an excellent arena to debate proposed revisions. The model code also encourages international consistency in the application of provisions.

Development

This 2015 RBES is founded on principles intended to establish provisions consistent with the scope of an energy conservation code that adequately conserves energy; provisions that do not unnecessarily increase construction costs; provisions that do not restrict the use of new materials, products or methods of construction; and provisions that do not give preferential treatment to particular types or classes of materials, products or methods of construction.

Background

During the 1995 legislative session, there was a consensus that a Task Force should be created to examine the issues related to developing an energy efficiency standard and address the concerns of interested parties. To this end, the Governor's Task Force on Energy Efficiency Standards for New Residential Construction was created in September, 1995 and was charged with developing a legislative proposal prior to the 1996 session.

The Governor's Task Force included stakeholders from many different perspectives on this issue. The Task Force reached a consensus that the legislature should adopt an energy code and that this code should include the following provisions:

- The code should be kept current by establishing a three-year cycle for revision and modification of the code through rule making;
- Compliance with the residential code should be given the presumption of compliance with 10 V.S.A. Chapter 151 (Act 250) Sub- Criterion 9(f), Energy Conservation;
- To demonstrate compliance, builders should be required to complete a form self-certifying that the energy efficiency requirements of the code have been met for each new home that is built;
- Owner/builders should be allowed to build a home that does not comply with the code as long as they disclose how that home is deficient to subsequent prospective buyers; and
- In order to address indoor air quality, a requirement for automatic, mechanical ventilation systems should be included in the first update of the code three years from adoption.

The *Vermont Residential Building Energy Standards* (RBES), was adopted by statute in 1997 and incorporated virtually all of the Task Force's recommendations. Since that time, an Energy Code Assistance Center has been established to provide builders and consumers with information on the code and answers to their questions. Workshops have also been held throughout the state to train builders, architects and trade allies about the code requirements and how to comply.

Act 89 passed in 2013, established a Stretch Code defined as a building energy code for residential buildings that achieves greater energy savings than the RBES. The stretch code shall be available for adoption by municipalities under 24 V.S.A. §117, and shall apply in proceedings under 10 V.S.A. §151 (Act 250).

Update Process

The Residential Building Energy Standards Statute (30 V.S.A. § 51) requires that revisions to the RBES are made promptly

after the issuance of updated standards for residential construction under the IECC. The PSD is required to convene stakeholders that include mortgage lenders, builders, building designers, utility representatives, and other persons with experience and expertise prior to the adoption of a revised RBES to provide recommendations.

The Vermont DPS held a series of stakeholder meetings in 2014 to gather feedback on proposed changes to RBES. The revisions to the 2015 edition of the International Energy Conservation Code presented in this document were drafted based on input received from these meetings.

Effective Use of the 2015 Residential Building Energy Standards

The 2015 *Vermont Residential Building Energy Standards* (RBES) is a code that regulates minimum energy conservation requirements for new buildings. The 2015 RBES addresses energy conservation requirements for all aspects of energy uses in residential construction, including heating and ventilating, lighting, water heating, and power usage for appliances and building systems.

The 2015 RBES is a design document. For example, before one constructs a building, the designer must determine the minimum insulation *R*-values and fenestration *U*-factors for the building exterior envelope. The RBES sets forth minimum requirements for exterior envelope insulation, and window and door *U*-factors, duct insulation, lighting and power efficiency, mechanical ventilation, and water distribution insulation.

Arrangement and Format of the 2015 RBES

Before applying the requirements of the 2015 RBES it is beneficial to understand its arrangement and format. The 2015 RBES, like other codes published by ICC, is arranged and organized to follow sequential steps that generally occur during a plan review or inspection. The 2015 RBES is divided into six different parts:

Chapters	Subjects
1-2	Administration and definitions
3	General Requirements
4	Residential Energy Efficiency
5	Existing buildings
6	Referenced standards

Italicized Terms

Selected terms set forth in Chapter 2, Definitions, are italicized where they appear in code text. Such terms are not italicized where the definition set forth in Chapter 2 does not impart the intended meaning in the use of the term. The terms selected have definitions that the user should read carefully to facilitate better understanding of the code.

Following is a chapter-by-chapter synopsis of the scope and intent of the provisions of the 2015 Vermont Residential Building Energy Standards:

Chapter 1 Administration. This chapter contains provisions for the application, enforcement and administration of subsequent requirements of the code. In addition to establishing the scope of the code, Chapter 1 identifies which buildings and structures come under its purview. Chapter 1 is largely concerned with maintaining “due process of law” in enforcing the energy conservation criteria contained in the body of this code. Only through careful observation of the administrative provisions can the code official or other authority having jurisdiction, where one exists, reasonably expect to demonstrate that “equal protection under the law” has been provided.

Chapter 2 Definitions. Chapter 2 is the repository of the definitions of terms used in the body of the code. Codes are technical documents and every word, term and punctuation mark can impact the meaning of the code text and the intended results. The code often uses terms that have a unique meaning in the code and the code meaning can differ substantially from the ordinarily understood meaning of the term as used outside of the code.

The terms defined in Chapter 2 are deemed to be of prime importance in establishing the meaning and intent of the code text. The user of the code should be familiar with and consult this chapter because the definitions are essential to the correct interpretation of the code and the user may not be aware that a term is defined.

Additional definitions regarding climate zones are found in Tables 301.3(1) and (2). These are not listed in Chapter 2.

Where understanding of a term's definition is especially key to or necessary for understanding of a particular code provision, the term is shown in *italics* wherever it appears in the code. This is true only for those terms that have a meaning that is unique to the code. In other words, the generally understood meaning of a term or phrase might not be sufficient or consistent with the meaning prescribed by the code; therefore, it is essential that the code-defined meaning be known.

Guidance regarding tense, gender and plurality of defined terms as well as guidance regarding terms not defined in this code is provided.

Chapter 3 General Requirements. Chapter 3 provides interior design conditions that are used as a basis for assumptions in heating and cooling load calculations, and provides basic material requirements for insulation materials and fenestration materials, and provides standards for residential mechanical ventilation and combustion safety

Chapter 4 Residential Energy Efficiency. Chapter 4 contains the energy-efficiency-related requirements for the design and construction of residential buildings regulated under this code. It should be noted that the definition of a *residential building* in this code is unique for this code. In this code, a *residential building* is an R-2, R-3 or R-4 building three stories or less in height. All other R-1 buildings, including residential buildings greater than three stories in height, are regulated by the energy conservation requirements in Vermont Commercial Building Energy Standards (CBES). The applicable portions of a residential building must comply with the provisions within this chapter for energy efficiency. This chapter defines requirements for the portions of the building and building systems that impact energy use in new residential construction and promotes the effective use of energy. The provisions within the chapter promote energy efficiency in the building envelope, the heating and cooling system, lighting and the service water heating system of the building. Vermont has adopted a two-tiered code structure with a "base" code that applies statewide, and a "*Stretch Code*" that is more stringent. The *Stretch Code* applies to all Act 250 development projects and is also available for municipalities that choose to adopt a higher energy standard.

Chapter 5 Existing Buildings. Chapter 5 of each set of provisions contains the technical energy efficiency requirements for existing buildings. Chapter 5 provisions address the maintenance of buildings in compliance with the code as well as how additions, alterations, repairs and changes of occupancy need to be addressed from the standpoint of energy efficiency. Specific provisions are provided for historic buildings.

Chapter 6 Referenced Standards. The code contains numerous references to standards that are used to regulate materials and methods of construction. Chapter 6 contains a comprehensive list of all standards that are referenced in the code. The standards are part of the code to the extent of the reference to the standard. Compliance with the referenced standard is necessary for compliance with this code. By providing specifically adopted standards, the construction and installation requirements necessary for compliance with the code can be readily determined. The basis for code compliance is, therefore, established and available on an equal basis to the code official or other authority having jurisdiction, where one exists, contractor, designer and owner.

Chapter 6 is organized in a manner that makes it easy to locate specific standards. It lists all of the referenced standards, alphabetically, by acronym of the promulgating agency of the standard. Each agency's standards are then listed in either alphabetical or numeric order based upon the standard identification. The list also contains the title of the standard; the edition (date) of the standard referenced; any addenda included as part of the ICC adoption; and the section or sections of this code that reference the standard.

Marginal Markings NOTE: The ICC will put in the actual margin markings when publishing. We will work out with them what format type will be used to note the Vermont additions and changes (perhaps dotted lines)

Solid vertical lines in the margins within the body of the code indicate a technical change from the 2011 edition. Vermont specific additions and changes are designated through xxx markings in the margin. Deletion indicators in the form of an arrow (➔) are provided in the margin where an entire section, paragraph, exception or table has been deleted or an item in a list of items or a table has been deleted.

Abbreviations and Notations

The following is a list of common abbreviations and units of measurement used in this code. Some of the abbreviations are for terms defined in Chapter 2. Others are terms used in various tables and text of the code.

AFUE	Annual fuel utilization efficiency
bhp	Brake horsepower (fans)
Btu	British thermal unit
Btu/h-ft ²	Btu per hour per square foot
C-factor	See Chapter 2—Definitions
CDD	Cooling degree days
cfm	Cubic feet per minute
cfm/ft ²	Cubic feet per minute per square foot
ci	Continuous insulation
COP	Coefficient of performance
DCV	Demand control ventilation
°C	Degrees Celsius
°F	Degrees Fahrenheit
DWHR	Drain water heat recovery
DX	Direct expansion
E _c	Combustion efficiency
E _v	Ventilation efficiency
E _t	Thermal efficiency

EER	Energy efficiency ratio
EF	Energy factor
ERI	Energy Rating index
<i>F</i> -factor	See Chapter 2—Definitions
FDD	Fault detection and diagnostics
FEG	Fan efficiency grade
FL	Full load
ft ²	Square foot
gpm	Gallons per minute
HDD	Heating degree days
HERS	Home Energy Rating System
hp	Horsepower
HSPF	Heating seasonal performance factor
HVAC	Heating, ventilating and air conditioning
IEER	Integrated energy efficiency ratio
IPLV	Integrated Part Load Value
Kg/m ²	Kilograms per square meter
kW	Kilowatt
LPD	Light power density (lighting power allowance)
L/s	Liters per second
Ls	Liner system
m ²	square meters
MERV	Minimum efficiency reporting value
NAECA	National Appliance Energy Conservation Act
NPLV	Nonstandard Part Load Value
Pa	Pascal
PF	Projection factor
pcf	Pounds per cubic foot
PSD	Public Service Department (Vermont)
psf	Pounds per square foot
PTAC	Packaged terminal air conditioner
PTHP	Packaged terminal heat pump
<i>R</i> -value	See Chapter 2—Definitions
SCOP	Sensible coefficient of performance
SEER	Seasonal energy efficiency ratio
SHGC	Solar Heat Gain Coefficient
SPVAC	Single packaged vertical air conditioner
SPVHP	Single packaged vertical heat pump
SRI	Solar reflectance index
SWHF	Service water heat recovery factor
<i>U</i> -factor	See Chapter 2—Definitions
VAV	Variable air volume
VRF	Variable refrigerant flow
VT	Visible transmittance

W	Watts
w.c.	Water column
w.g.	Water gauge

DRAFT

TABLE OF CONTENTS

NOTE: Table of contents and page numbering will be updated when formatting has been completed by ICC

CHAPTER 1 ADMINISTRATION R-3	
PART 1—SCOPE AND APPLICATION. R-3	
Section	
R101 Scope and General Requirements. R-3	
R102 Alternative Materials, Design and Methods of Construction and Equipment. . . R-3	
PART 2—ADMINISTRATION AND ENFORCEMENT R-3	
R103 Construction Documents R-3	
R104 Inspections R-4	
R105 Validity. R-5	
R106 Referenced Standards R-5	
R107 Fees. R-5	
R108 Stop Work Order R-5	
R109 Board of Appeals R-5	
CHAPTER 2 DEFINITIONS R-7	
Section	
R201 General R-7	
R202 General Definitions R-7	
CHAPTER 3 GENERAL REQUIREMENTS . . . R-11	
Section	
R301 Climate Zones. R-11	
R302 Design Conditions R-26	
R303 Materials, Systems and Equipment R-26	
CHAPTER 4 RESIDENTIAL ENERGY EFFICIENCY R-29	
Section	
R401 General R-29	
R402 Building Thermal Envelope R-29	
R403 Systems. R-35	
R404 Electrical Power and Lighting Systems R-37	
R405 Simulated Performance Alternative (Performance). R-37	
R406 Energy Rating Index Compliance Alternative R-41	
R407 Stretch Code	
CHAPTER 5 EXISTING BUILDINGS. R-43	
Section	
R501 General. R-43	
R502 Additions R-43	
R503 Alterations R-44	
R504 Repairs R-44	
R505 Change of Occupancy or Use. R-44	
CHAPTER 6 REFERENCED STANDARDS. . . R-45	
APPENDIX RA RECOMMENDED PROCEDURE FOR WORST-CASE TESTING OF ATMOSPHERIC VENTING SYSTEMS UNDER R402.4 OR R405 CONDITIONS □ 5ACH₅₀ . . . R-49	
Section	
RA101 Scope R-49	
RA201 General Definitions R-49	
RA301 Testing Procedure R-49	
APPENDIX RB SOLAR-READY PROVISIONS— DETACHED ONE- AND TWO- FAMILY DWELLINGS, MULTIPLE SINGLE-FAMILY DWELLINGS (TOWNHOUSES). . R-51	
Section	
RB101 Scope R-51	
RB102 General Definitions R-51	
RB103 Solar-ready Zone R-51	
INDEX. R-53	

CHAPTER 1

ADMINISTRATION

PART 1—SCOPE AND APPLICATION

SECTION R101

SCOPE AND GENERAL REQUIREMENTS

R101.1 Title. This code shall be known as the 2015 *Residential Building Energy Standards (RBES)* of Vermont, and shall be cited as such. It is referred to herein as “this code.”

R101.2 Scope. This code applies to *residential buildings* and the building sites and associated systems and equipment, including one family dwellings, two family dwellings, and multi-family housing three stories or less in height.

R101.3 Intent. This code shall regulate the design and construction of buildings for the effective use and conservation of energy over the useful life of each building. This code is intended to provide flexibility to permit the use of innovative approaches and techniques to achieve this objective. This code is not intended to abridge building science or safety, health or environmental requirements contained in other applicable codes or ordinances. This code has been designed to minimize any conflict or difference between other adopted codes and standards.

R101.4 Applicability. Where, in any specific case, different sections of this code specify different materials, methods of construction or other requirements, the most restrictive shall govern. Where there is a conflict between a general requirement and a specific requirement, the specific requirement shall govern.

101.4.1 Mixed occupancy. Where a building includes both *residential* and *commercial* occupancies, each occupancy shall be separately considered and meet the applicable provisions of Chapter 4 for *residential portions of the building and the Commercial Building Energy Standards (CBES)* for *commercial portions of the building*.

R101.4.1 Mixed occupancy. With respect to a structure that is three stories or less in height and is a mixed-use building that shares residential and commercial users, the term “residential building” shall include the living spaces in the structure and the nonliving spaces in the structure that serve only the residential users such as common hallways, laundry facilities, residential management offices, community rooms, storage rooms, and foyers. The “residential building” shall comply with all requirements of RBES, and all other aspects of the building shall comply with the *Vermont Commercial Building Energy Standards (CBES)*.

*

R101.5 Compliance. *Residential buildings* shall meet the provisions of Chapter 4.

R101.5.1 Compliance materials. The *code official* or *other authority jurisdiction* shall be permitted to approve specific computer software, work-sheets, compliance manuals and other similar materials that meet the intent of this code.

R 101.5.2 Exempt buildings. The following buildings, or

portions thereof, shall be exempt from the provisions of this code:

1. **Low Energy Use Buildings.** Those with a peak design rate of energy usage less than 3.4 Btu/h·ft² (10.7 W/m²) or 1.0 watt/ft² (10.7 W/m²) of floor area for space conditioning purposes.

2. **Unconditioned Buildings.** Those that do not contain *conditioned space*.

3. **Mobile homes.** Homes subject to Title VI of the National Manufactured Housing Construction and

Safety Standards Act of 1974 (42 U.S.C. §§ 5401-5426). On-site constructed basements and crawlspaces must comply with this code.

4. **Hunting camps.** Residential buildings shall not include hunting camps.

5. **Summer camps.** Residential buildings constructed for non-winter occupation with only a biomass (wood) or other on-site renewable heating system.

6. **Owner-built homes.** Residential construction by an owner, if all of the following apply:

1. The owner of the residential construction is the *builder*, as defined in 30 V.S.A § 51 a1, and;

2. The residential construction is used as a dwelling by the owner, and;

3. The owner in fact directs the details of construction with regard to the installation of materials not in compliance with the RBES, and;

4. The owner discloses in writing to a prospective buyer, before entering into a binding purchase and sales agreement, with respect to the nature and extent of any noncompliance with the RBES.

Any statement or certificate given to a prospective buyer shall itemize how the home does not comply with RBES, and shall itemize which measures do not meet the RBES in effect at the time construction commenced. Any certificate given under this subsection shall be recorded in the land records where the property is located, and sent to the Public Service Department (PSD), within 30 days following sale of the property by the owner. A certificate that itemizes how the home does not comply with RBES is available from the PSD.

R101.6 Authority having jurisdiction. In any instance where there is no state or local code official or other authority having jurisdiction, where one exists, the PSD is not considered to be the “other authority having jurisdiction, where one exists,” and those

sections of this code requiring involvement by that entity do not apply. All other code requirements still apply.

R101.7 Base and Stretch Code. The “Base Code” is the RBES Energy Code that is applicable throughout Vermont except for projects subject to 10 V.S.A., Chapter 151 (Act 250), and in any municipalities that have adopted the more stringent “Stretch Code”.

R101.8 Compliance options. There are three thermal efficiency compliance options:

1. **Prescriptive Packages:** For the Base Code, Table 402.2.1, and alternative packages in the accompanying 2015 RBES Handbook. For the Stretch Code, Table 407.1 and alternative packages in the 2015 RBES Handbook.

2. **REScheck™:** The U.S. Department of Energy’s REScheck™ software.

3. **Home Energy Rating System (HERS):** A HERS energy rating that demonstrates compliance with Table 406.4 for the Base Code or Table 407.2 for the Stretch Code. (All HERS Index values in this code are based on REM/Rate version 14.)

SECTION R102

ALTERNATIVE MATERIALS, DESIGN AND METHODS OF CONSTRUCTION AND EQUIPMENT

R102.1 General. This code is not intended to prevent the use of any material, method of construction, design or insulating system not specifically prescribed herein, provided that such construction, design or insulating system has been *approved by the code official or other authority having jurisdiction, where one exists*, as meeting the intent of this code.

R102.1.1 Above code programs. The *code official or other authority having jurisdiction, where one exists*, shall be permitted to deem a national, state or local energy-efficiency program to exceed the energy efficiency required by this code. Buildings *approved* in writing by such an energy-efficiency program shall be considered in compliance with this code. The requirements identified as “mandatory” in Chapter 4 shall be met.

PART 2—ADMINISTRATION AND ENFORCEMENT

SECTION R103

CONSTRUCTION DOCUMENTS

R103.1 General. Where required, construction documents, technical reports and other supporting data shall be submitted in one or more sets with each application for a permit. The construction documents and technical reports shall be prepared by a registered design professional where required by the statutes of the jurisdiction in which the project is to be constructed. Where special conditions exist, the *code official or other authority having jurisdiction, where one exists*, is authorized to require necessary construction documents to be prepared by a registered design professional.

Exception: The *code official or other authority having jurisdiction, where one exists*, is authorized to waive the requirements for construction documents or other supporting data if the *code official or other authority having jurisdiction, where one exists*, determines they are not necessary to confirm

compliance with this code.

R103.2 Information on construction documents. Where required, construction documents shall be drawn to scale upon suitable material. Electronic media documents are permitted to be submitted where *approved by the code official or other authority having jurisdiction, where one exists*. Construction documents shall be of sufficient clarity to indicate the location, nature and extent of the work proposed, and show in sufficient detail pertinent data and features of the *building*, systems and equipment as herein governed. Details shall include, but are not limited to, the following as applicable:

1. Insulation materials and their *R*-values.
2. Fenestration *U*-factors and solar heat gain coefficients (SHGC).
3. Area-weighted *U*-factor and solar heat gain coefficients (SHGC) calculations.
4. Mechanical system design criteria.
5. Mechanical and service water-heating system and equipment types, sizes and efficiencies.
6. Equipment and system controls.
7. Duct sealing, duct and pipe insulation and location.
8. Air sealing details.

R103.2.1 Building thermal envelope depiction. The *building's thermal envelope* shall be represented on the construction documents.

R103.3 Examination of documents. The *code official or other authority having jurisdiction, where one exists*, shall examine or cause to be examined the accompanying construction documents and shall ascertain whether the construction indicated and described is in accordance with the requirements of this code and other pertinent laws or ordinances. The *code official or other authority having jurisdiction, where one exists*, is authorized to utilize a registered design professional, or other *approved* entity not affiliated with the building design or construction, in conducting the review of the plans and specifications for compliance with the code.

R103.3.1 Approval of construction documents. When the *code official or other authority having jurisdiction, where one exists*, issues a permit where construction documents are required, the construction documents shall be endorsed in writing and stamped "Reviewed for Code Compliance." Such *approved* construction documents shall not be changed, modified or altered without authorization from the *code official or other authority having jurisdiction, where one exists*. Work shall be done in accordance with the *approved* construction documents.

One set of construction documents so reviewed shall be retained by the *code official or other authority having jurisdiction, where one exists*. The other set shall be returned to the applicant, kept at the site of work and shall be open to inspection by the *code official or other authority having jurisdiction, where one exists*, or a duly authorized representative.

R103.3.2 Previous approvals. This code shall not require changes in the construction documents, construction or designated occupancy of a structure for which a lawful permit has been heretofore issued or otherwise lawfully authorized, and the construction of which has been pursued in good faith within 180 days after the effective date of this code and has not been abandoned.

R103.3.3 Phased approval. The *code official or other authority having jurisdiction, where one exists*, shall have the authority to issue a permit for the construction of part of an energy conservation system before the construction documents for the entire system have been submitted or *approved*, provided adequate information and detailed statements have been filed complying with all pertinent requirements of this code. The holders of such permit shall proceed at their own risk without assurance that the permit for the entire energy conservation system will be granted.

R103.4 Amended construction documents. Work shall be installed in accordance with the approved construction documents, and any changes made during construction that are not in compliance with the *approved* construction documents shall be resubmitted for approval as an amended set of construction documents.

R103.5 Retention of construction documents. One set of *approved* construction documents shall be retained by the

code official or other authority having jurisdiction, where one exists, for a period of not less than 180 days from date of completion of the permitted work, or as required by state or local laws.

**SECTION
R104
INSPECTION
S**

R104.1 General. Where required, construction or work for which a permit is required shall be subject to inspection by the *code official or other authority having jurisdiction, where one exists*, or his or her designated agent, and such construction or work shall remain accessible and exposed for inspection purposes until *approved*. It shall be the duty of the permit applicant to cause the work to remain accessible and exposed for inspection purposes. Neither the *code official* nor the *jurisdiction* shall be liable for expense entailed in the removal or replacement of any material, product, system or building component required to allow inspection to validate compliance with this code.

R104.2 Required approvals.

Work shall not be done beyond the point indicated in each successive inspection without first obtaining the approval of

the *code official or other authority having jurisdiction, where one exists*,. The *code official or other authority having jurisdiction, where one exists*, upon notification, shall make the requested inspections and shall either indicate the portion of the construction that is satisfactory as completed, or notify the permit holder or his or her agent wherein the same fails to comply with this code. Any portions that do not comply shall be corrected and such portion shall not be covered or concealed until authorized by the *code official or other authority having jurisdiction, where one exists*,.

R104.2.5 Final inspection. The *building* shall have a final inspection and shall not be occupied until *approved*. The final inspection shall include verification of the installation of all required *building* systems, equipment and controls and their proper operation and the required number of high-efficacy lamps and fixtures. ☐

R104.3 Reinspection. A *building* shall be reinspected when determined necessary by the *code official or other authority having jurisdiction, where one exists*,.

R104.4 Approved inspection agencies. The *code official or other authority having jurisdiction, where one exists*, is authorized to accept reports of third-party inspection agencies not affiliated with the building design or construction, provided such agencies are *approved* as to qualifications and reliability relevant to the building components and systems they are inspecting.

R104.5 Inspection requests. It shall be the duty of the holder of the permit or their duly authorized agent to notify the *code official or other authority having jurisdiction, where one exists*, when work is ready for inspection. It shall be the duty of the permit holder to provide access to and means for inspections of such work that are required by this code.

R104.6 Reinspection and testing. Where any work or installation does not pass an initial test or inspection, the necessary corrections shall be made to achieve compliance with this code. The work or installation shall then be resubmitted to the *code official or other authority having jurisdiction, where one exists*, for inspection and testing.

R104.7 Approval. After the prescribed tests and inspections indicate that the work complies in all respects with this code, a notice of approval shall be issued by the *code official or other authority having jurisdiction, where one exists*.

R104.7.1 Revocation. The *code official or other authority having jurisdiction, where one exists*, is authorized to, in writing, suspend or revoke a notice of approval issued under the provisions of this code wherever the certificate is issued in error, or on the basis of incorrect information supplied, or where it is determined that the *building* or structure, premise, or portion thereof is in violation of any ordinance or regulation or any of the provisions of this code.

SECTION R105 VALIDITY

R105.1 General. If a portion of this code is held to be illegal or void, such a decision shall not affect the validity of the remainder of this code.

SECTION R106 REFERENCED STANDARDS

R106.1 Referenced codes and standards. The codes and standards referenced in this code shall be those listed in Chapter 6, and such codes and standards shall be considered as part of the requirements of this code to the prescribed extent of each such reference and as further regulated in Sections R106.1.1 and R106.1.2.

R106.1.1 Conflicts. Where conflicts occur between provisions of this code and referenced codes and standards, the provisions of this code shall apply.

R106.1.2 Provisions in referenced codes and standards. Where the extent of the reference to a referenced code or standard includes subject matter that is within the scope of this code, the provisions of this code, as applicable, shall take precedence over the provisions in the referenced code or standard.

R106.2 Application of references. References to chapter or section numbers, or to provisions not specifically identified by number, shall be construed to refer to such chapter, section or provision of this code.

R106.3 Other laws. The provisions of this code shall not be deemed to nullify any provisions of local, state or federal law.

CHAPTER 2 [RE] DEFINITIONS

SECTION R201 GENERAL

R201.1 Scope. Unless stated otherwise, the following words and terms in this code shall have the meanings indicated in this chapter.

R201.2 Interchangeability. Words used in the present tense include the future; words in the masculine gender include the feminine and neuter; the singular number includes the plural and the plural includes the singular.

R201.3 Terms defined in other codes. Terms that are not defined in this code but are defined in the *International Building Code*, *International Fire Code*, *International Fuel Gas Code*, *International Mechanical Code*, *International Plumbing Code* or the *International Residential Code* shall have the meanings ascribed to them in those codes.

R201.4 Terms not defined. Terms not defined by this chapter shall have ordinarily accepted meanings such as the context implies.

of investigation and tests conducted by him or her, or by reason of accepted principles or tests by nationally recognized organizations.

APPROVED AGENCY. An established and recognized agency regularly engaged in conducting tests or furnishing inspection services, when such agency has been approved by the *code official or other authority having jurisdiction, where one exists*.

SECTION R202 GENERAL DEFINITIONS

ABOVE-GRADE WALL. A wall more than 50 percent above grade and enclosing *conditioned space*. This includes between-floor spandrels, peripheral edges of floors, roof and basement knee walls, dormer walls, gable end walls, walls enclosing a mansard roof and skylight shafts.

ACCESSIBLE. Admitting close approach as a result of not being guarded by locked doors, elevation or other effective means (see “*Readily accessible*”).

ADDITION. An extension or increase in the *conditioned space* floor area or height of a building or structure.

AIR BARRIER. An air barrier is a durable assembly that blocks air flow between conditioned space and unconditioned space. Air barriers must be continuous, sealed at all joints, penetrations, and interruptions using durable sealants intended for such use and compatible with all adjacent materials, and able to resist pressures without displacement or damage.

ALTERATION. Any construction, retrofit or renovation to an existing structure other than repair or addition. Also, a change in a building, electrical, gas, mechanical or plumbing system that involves an extension, addition or change to the arrangement, type or purpose of the original installation.

ANNUAL FUEL UTILIZATION EFFICIENCY (AFUE). The ratio of annual output energy to annual input energy which includes any non-heating season pilot input loss, and for gas or oil-fired furnaces or boilers, does not include electrical energy.

APPROVED. Approval by the *code official or other authority having jurisdiction, where one exists*, as a result

AUTOMATIC. Self-acting, operating by its own mechanism when actuated by some impersonal influence, as, for example, a change in current strength, pressure, temperature or mechanical configuration (see “Manual”).

BASE CODE. The standard RBES Energy Code, as distinct from the higher stringency *Stretch Code*.

BASEMENT WALL. A wall 50 percent or more below grade and enclosing *conditioned space*.

BATHROOM. A room containing a bathtub, shower, spa or similar bathing fixture.

BEDROOM. A room or space 70 square feet or greater, with egress window and closet, used or intended to be used for sleeping. A "den," "library," "home office" with a closet, egress window, and 70 square feet or greater or other similar rooms shall count as a bedroom, but living rooms and foyers shall not. (Source: RESNET)

BIOMASS. The vegetation removed from the forest, usually logging slash, small-diameter trees, tops, limbs, or trees. This includes wood logs, wood pellets and wood chips.

BTU. Abbreviation for British thermal unit, which is the quantity of heat required to raise the temperature of 1 pound (0.454 kg) of water 1°F (0.56°C), (1 Btu = 1,055 J), or about the amount of energy in one wooden kitchen match burned end to end.

C-FACTOR (THERMAL CONDUCTANCE). The coefficient of heat transmission (surface to surface) through a building component or assembly, equal to the time rate of heat flow per unit area and the unit temperature difference between the warm side and cold side surfaces ($\text{Btu/h} \cdot \text{ft}^2 \cdot ^\circ\text{F}$) [$\text{W}/(\text{m}^2 \cdot \text{K})$].

CUBIC FEET PER MINUTE (CFM). The quantity of air moved in 1 minute. A measurement typically applied to ventilation equipment.

BUILDER. The general contractor or other person in charge of construction, who has the power to direct others with respect to the details to be observed in construction. (Source: VT 30 VSA 51)

BUILDING. Any structure used or intended for supporting or sheltering any use or occupancy, including any mechanical systems, service water heating systems and electric power and lighting systems located on the building site and supporting the building.

BUILDING THERMAL ENVELOPE. The basement walls, exterior walls, floor, roof, and any other building element that enclose conditioned space. This boundary also includes the boundary between conditioned space and any exempt or unconditioned space.

BUILDING SITE. A contiguous area of land that is under the ownership or control of one entity.

CATEGORY I COMBUSTION APPLIANCE. An appliance which operates with a non-positive vent static pressure and a with a vent gas temperature that avoids excessive condensate production in the vent. (Source: NFPA54)

CATEGORY II COMBUSTION APPLIANCE. An appliance which operates with a non-positive vent static pressure and a with a vent gas temperature that may cause excessive condensate production in the vent. (Source: NFPA54)

CATEGORY III COMBUSTION APPLIANCE. An appliance which operates with a positive vent static pressure and a with a vent gas temperature that avoids excessive condensate production in the vent. (Source: NFPA54)

CATEGORY IV COMBUSTION APPLIANCE. An appliance which operates with a positive vent static pressure and a with a vent gas temperature that may cause excessive condensate production in the vent. (Source: NFPA54)

CIRCULATING HOT WATER SYSTEM. A specifically designed water distribution system where one or more pumps are operated in the service hot water piping to circulate heated water from the water-heating equipment to fixtures and back to the water-heating equipment.

CLIMATE ZONE. A geographical region based on climatic criteria as specified in this code.

Vermont CODE OFFICIAL. The officer or other designated authority charged with the administration and enforcement of this code, or a duly authorized representative. The Public Service Department is not the code official and shall not be required to conduct inspections of construction or construction documents.

COEFFICIENT OF PERFORMANCE (COP)—COOLING. The ratio of the rate of heat removal to the rate of energy input in consistent units, for a complete cooling system or factory-assembled equipment, as tested under a nationally recognized standard or designated operating conditions.

COEFFICIENT OF PERFORMANCE (COP)—HEAT PUMP—HEATING. The ratio of the rate of heat delivered to the rate of energy input, in consistent units, for a complete heat pump system under designated operating conditions. Supplemental heat shall not be considered when checking compliance with the heat pump equipment.

buildings

COMMERCIAL BUILDING. For this code, all buildings that are not included in the definition of “Residential buildings, excluding mobile homes.”

COMMERCIAL BUILDING ENERGY STANDARDS (CBES). The Vermont non-residential Energy Code, based on the IECC 2015.

CONDENSER. A heat exchanger designed to liquefy refrigerant vapor by removal of heat.

CONDENSING UNIT. A specific refrigerating machine combination for a given refrigerant, consisting of one or more power-driven compressors, condensers, liquid receivers (when required), and the regularly furnished accessories.

CONDITIONED FLOOR AREA. The horizontal projection of the floors associated with the *conditioned space*.

CONDITIONED SPACE. An area, room or space that is

enclosed within the building thermal envelope and that is directly or indirectly heated or cooled. Spaces are indirectly heated or cooled where they communicate through openings with conditioned spaces, where they are separated from conditioned spaces by uninsulated walls, floors or ceilings, or where they contain uninsulated ducts,

pipng or other sources of heating or cooling.

CONTINUOUS AIR BARRIER. A combination of materials and assemblies that restrict or prevent the passage of air through the building thermal envelope.

DRAFT

CONTINUOUS INSULATION (ci). Insulating material that is continuous across all structural members without thermal bridges other than fasteners and service openings. It is installed on the interior or exterior, or is integral to any opaque surface, of the building envelope.

CRAWL SPACE WALL. The opaque portion of a wall that encloses a crawl space and is partially or totally below grade.

CURTAIN WALL. Fenestration products used to create an external nonload-bearing wall that is designed to separate the exterior and interior environments.

DAYLIGHT ZONE.

1. **Under skylights.** The area under skylights whose horizontal dimension, in each direction, is equal to the sky- light dimension in that direction plus either the floor- to-ceiling height or the dimension to a ceiling height opaque partition, or one-half the distance to adjacent skylights or vertical fenestration, whichever is least.
2. **Adjacent to vertical fenestration.** The area adjacent to vertical fenestration which receives daylight through the fenestration. For purposes of this definition and

unless more detailed analysis is provided, the daylight zone depth is assumed to extend into the space a distance of 15 feet (4572 mm) or to the nearest ceiling height opaque partition, whichever is less. The daylight zone width is assumed to be the width of the window plus 2 feet (610 mm) on each side, or the window width plus the distance to an opaque partition, or the window width plus one-half the distance to adjacent skylight or vertical fenestration, whichever is least.

DEMAND RECIRCULATION WATER SYSTEM.

A water distribution system where pump(s) prime the service hot water piping with heated water upon demand for hot water.

DEADBAND. The temperature range in which no heating or cooling is used.

DEGREE DAY, COOLING. A unit, based on temperature difference and time, used in estimating cooling energy consumption and specifying nominal cooling load of a building in summer. For any one day, when the mean temperature is more than 65°F, there are as many degree days as there are degrees Fahrenheit difference in temperature between the mean temperature for the day and 65°F. Annual cooling degree days (CDD) are the sum of the degree days over a calendar year.

DEGREE DAY, HEATING. A unit, based upon temperature difference and time, used in estimating heating energy consumption and specifying nominal heating load of a building in winter. For any one day, when the mean temperature is less than 65°F, there are as many degree days as there are degrees Fahrenheit difference in temperature between the mean temperature for the day and 65°F. Annual heating degree days are the sum of the degree days over a calendar year.

DEMAND CONTROL VENTILATION (DCV). A ventilation system capability that provides for the automatic reduction of outdoor air intake below design rates when the actual occupancy of spaces served by the system is less than design occupancy.

DIRECT-VENT APPLIANCES. Appliances that are constructed and installed so that all air for combustion is derived directly from the outside atmosphere and all flue gases are discharged directly to the outside atmosphere. See also Sealed Combustion Venting System.

DUCT. A tube or conduit utilized for conveying air. The air passages of self-contained systems are not to be construed as air ducts.

DUCT SYSTEM. A continuous passageway for the transmission of air that, in addition to ducts, includes duct fittings, dampers, plenums, fans and accessory air-handling equipment and appliances.

DWELLING UNIT. A single unit providing complete independent living facilities for one or more persons, including permanent provisions for living, sleeping, eating, cooking and sanitation.

ECONOMIZER, AIR. A duct and damper arrangement and automatic control system that allows a cooling system to sup- ply outside air to reduce or

eliminate the need for mechanical cooling during mild or cold weather.

ECONOMIZER, WATER. A system where the supply air of a cooling system is cooled indirectly with water that is itself cooled by heat or mass transfer to the environment without the use of mechanical cooling.

ENERGY ANALYSIS. A method for estimating the annual energy use of the *proposed design* and *standard reference design* based on estimates of energy use.

ENERGY COST. The total estimated annual cost for purchased energy for the building functions regulated by this code, including applicable demand charges.

ENERGY EFFICIENCY RATIO (EER). The ratio of net equipment cooling capacity in Btu/h to total rate of electric input in watts under designated operating conditions. When consistent units are used, this ratio becomes equal to COP (see also "Coefficient of performance").

ENERGY RECOVERY VENTILATION SYSTEM. Systems that employ air-to-air heat exchangers to recover energy from exhaust air for the purpose of preheating, precooling, humidifying or dehumidifying outdoor ventilation air prior to supplying the air to a space, either directly or as part of an HVAC system.

ENERGY SIMULATION TOOL. An *approved* software program or calculation-based methodology that projects the annual energy use of a building.

ENTRANCE DOOR. Fenestration products used for ingress, egress and access in nonresidential buildings, including, but not limited to, exterior entrances that utilize latching hardware and automatic closers and contain over 50-percent glass specifically designed to withstand heavy use and possibly abuse.

ERI REFERENCE DESIGN. A version of the rated design that meets the minimum requirements of the 2006 *International Energy Conservation Code*.

EVAPORATOR. That part of the system in which liquid refrigerant is vaporized to produce refrigeration.

EXTERIOR ENVELOPE. See "Building Thermal Envelope."

EXTERIOR WALL. Walls including both above-grade walls and basement walls.

FAN BRAKE HORSEPOWER (BHP). The horsepower delivered to the fan's shaft. Brake horsepower does not include the mechanical drive losses (belts, gears, etc.).

FAN SYSTEM BHP. The sum of the fan brake horsepower of all fans that are required to operate at fan system design conditions to supply air from the heating or cooling source to the *conditioned space(s)* and return it to the source or exhaust it to the outdoors.

FAN SYSTEM DESIGN CONDITIONS. Operating conditions that can be expected to occur during normal system operation that result in the highest supply fan airflow rate to conditioned spaces served by the system.

FAN SYSTEM MOTOR NAMEPLATE HP. The sum of the motor nameplate horsepower of all fans that are required

to operate at design conditions to supply air from the heating or cooling source to the *conditioned space(s)* and return it to the source or exhaust it to the outdoors.

FENESTRATION. Products classified as either *vertical fenestration* or *skylights*.

FENESTRATION PRODUCT, SITE-BUILT. A fenestration designed to be made up of field-glazed or field-assembled units using specific factory cut or otherwise factory-formed framing and glazing units. Examples of site-built fenestration include storefront systems, curtain walls and atrium roof systems.

F-FACTOR. The perimeter heat loss factor for slab-on-grade floors (Btu/h · ft · °F) [W/(m · K)].

FINISHED AREA. An enclosed area in a house that is suitable for year-round use, embodying walls, floors, and ceilings that are similar to the rest of the house.

FINISHED CONDITIONED FLOOR AREA (FCFA). The floor area in square feet of a home that is within the conditioned space of the building, and also is finished area, as measured in accordance with ANSI Standard Z765-2003 (with the exception that floor areas with ceiling heights of less than 5 feet will be included in finished square footage).

FURNACE DUCT. A furnace normally installed in distribution ducts of air-conditioning systems to supply warm air for heating and which depends on a blower not furnished as part of the duct furnace for air circulation.

FURNACE, WARM AIR. A self-contained, indirect-fired or electrically heated furnace that supplies heated air through ducts to spaces that require it.

GROSS AREA OF EXTERIOR WALLS. The normal projection of all exterior walls, including the area of all windows and doors installed therein (see "Exterior wall").

HEAT. The form of energy that is transferred by virtue of a temperature difference or a change in state of a material.

HEAT CAPACITY (HC). The amount of heat necessary to raise the temperature of a given mass by 1°F (0.6°C). The heat capacity of a building element is the sum of the heat capacities of each of its components.

HEAT PUMP. A refrigeration system that extracts heat from one substance and transfers it to another portion of the same substance or to a second substance at a higher temperature for a beneficial purpose.

HEAT RECOVERY VENTILATION SYSTEM (HRV). A factory-assembled device or combination of devices, including fans or blowers, designed to provide outdoor air for ventilation in which heat or heat and moisture is transferred between two isolated intake and exhaust air streams.

HEAT TRAP. An arrangement of piping and fittings, such as elbows, or a commercially available heat trap that prevents thermosyphoning of hot water during standby periods.

HEATED SLAB. Slab-on-grade construction in which the heating elements, hydronic tubing, or hot air

distribution system is in contact with, or placed within or under, the slab.

HEATING SEASONAL PERFORMANCE FACTOR (HSPF). The total heating output of a heat pump during its normal annual usage period for heating, in Btu's, divided by the total electric energy input during the same period, in watt hours, as determined by DOE 10 CFR Part 430, Subpart B, Test Procedures, and based on Region 4.

HIGH-EFFICACY LAMPS/ LIGHTING. Compact fluorescent lamps, T-8 or smaller diameter linear fluorescent lamps, or lamps with a minimum efficacy of:

1. 60 lumens per watt for lamps over 40 watts;
2. 50 lumens per watt for lamps over 15 watts to 40 watts; and
3. 40 lumens per watt for lamps 15 watts or less.

HISTORIC BUILDING. Any building or structure that is one or more of the following:

1. Listed, or certified as eligible for listing by the State Historic Preservation Officer or the Keeper of the National Register of Historic Places, in the National Register of Historic Places.
2. Designated as historic under an applicable state or local law.
3. Certified as a contributing resource within a National Register-listed, state-designated or locally designated historic district

HOME ENERGY RATING SYSTEM (HERS). A home energy rating system accredited by the Vermont Public Service Department that provides a numerical rating in compliance with 21 V.S.A. § 267(a). The purpose of this procedure is to ensure that accurate and consistent home energy ratings are performed by accredited HERS providers in Vermont and to promote an objective, cost-effective, sustainable home energy rating process as a compliance method for residential building energy codes; as qualification for energy programs designed to reach specific energy-saving goals; and as a way to provide Vermont's housing market the ability to differentiate residences based on their energy efficiency.

HUMIDISTAT. A regulatory device, actuated by changes in humidity, used for automatic control of relative humidity.

HVAC. Heating, ventilating and air conditioning.

HVAC SYSTEM. The equipment, distribution network and terminals that provide either collectively or individually the processes of heating, ventilating or air conditioning to a building.

HVAC SYSTEM COMPONENTS. HVAC system components provide, in one or more factory-assembled packages, means for chilling or heating water, or both, with controlled temperature for delivery to terminal units serving the conditioned spaces of the building. Types of HVAC system components include, but are not limited to, water chiller packages, reciprocating condensing units and water source (hydronic) heat pumps (see "HVAC system equipment").

HVAC SYSTEM EQUIPMENT. HVAC system equipment provides, in one (single package) or more (split system) factory-assembled packages, means for air circulation, air cleaning, air cooling with controlled temperature and dehumidification and, optionally, either alone or in combination with a heating plant, the functions of heating and humidifying. The cooling function is either electrically or heat operated and the refrigerant condenser is air, water or evaporatively cooled. Where the equipment is provided in more than one package, the separate packages shall be designed by the manufacturer to be used together. The

equipment shall be permitted to provide the heating function as a heat pump or by the use of electric or fossil-fuel-fired elements. (The word "equipment" used without a modifying adjective, in accordance with common industry usage, applies either to HVAC system equipment or HVAC system components.)

HUNTING CAMP. A seasonal building used as a temporary residence only during hunting season.

INFILTRATION. The uncontrolled inward air leakage into a building caused by the pressure effects of wind or the effect of differences in the indoor and outdoor air density or both.

INSULATED SIDING. A type of continuous insulation with manufacturer-installed insulating material as an integral part of the cladding product having a minimum *R*-value of R-2.

INSULATING SHEATHING. An insulating board with a core material having a minimum *R*-value of R-2.

LABELED. Equipment, materials or products to which have been affixed a label, seal, symbol or other identifying mark of a nationally recognized testing laboratory, inspection agency or other organization concerned with product evaluation that maintains periodic inspection of the production of the above-labeled items and where labeling indicates either that the equipment, material or product meets identified standards or has been tested and found suitable for a specified purpose.

LEVEL 1 ELECTRIC VEHICLE CHARGING STATION. Level 1 charging uses a standard 120V outlet.

LEVEL 2 ELECTRIC VEHICLE CHARGING STATION. Level 2 uses a 240 volt AC charging.

LIGHTING. See "High-Efficacy Lamps/Lighting".

LISTED. Equipment, materials, products or services included in a list published by an organization acceptable to the *code official or other authority having jurisdiction, where one exists*, and concerned with evaluation of products or services that maintains periodic inspection of production of *listed* equipment or materials or periodic evaluation of services and where the listing states either that the equipment, material, product or service meets identified standards or has been tested and found suitable for a specified purpose.

LOCAL VENTILATION. A mechanical ventilation system including fans, controls and ducts, dedicated to exhausting moisture-laden air to the outside of the building from the room or space in which the moisture is generated.

LOW-VOLTAGE LIGHTING. Lighting equipment powered through a transformer such as a cable conductor, a rail conductor and track lighting.

MANUAL. Capable of being operated by personal intervention (see "Automatic").

MECHANICAL VENTILATION. The mechanical process of supplying conditioned or unconditioned air to, or removing such air from, any space by powered fans. For purposes of this standard, mechanical ventilation does not include processes driven by wind, such as turbine ventilators.

MIXED-USE. With respect to a structure that is three stories or less in height and is a mixed-use building that shares residential and commercial users, the term "residential building" shall include the living spaces in the structure and the nonliving spaces in the structure that serve only the residential users such as common hallways, laundry facilities, residential management offices, community rooms, storage rooms, and foyers. (From

Vermont 30 VSA § 51.)

MULTIFAMILY DWELLING. A building containing three or more dwelling units.

NAMEPLATE HORSEPOWER. The nominal motor horse power rating stamped on the motor nameplate.

OCCUPANCY. The purpose for which a building, or portion thereof, is utilized or occupied.

OCCUPANCY CLASSIFICATIONS. Residential Group R is the occupancy group used for buildings that include sleeping rooms and are not institutional and are not generally regulated by the International Residential Code. The IRC typically regulates single family homes and duplexes, any structure with more than two units is in the IBC. There are four different occupancy groups within R.

The first occupancy group is **R-1**. This group is for transient uses like hotels, motels and boarding houses.

The next group is **R-2**. R-2 is the group we see most often and it for residences where occupants are primarily permanent. This includes apartments, dormitories, fraternities and sororities. It also includes vacation timeshares (again with more than two units) and convents and monasteries. Congregate living facilities with 16 or fewer occupants go into group R-3.

R-3 is for permanent occupancies that aren't R-1, R-2, R-4 or I. These include buildings that are in the IBC but have no more than two units. Adult facilities and child care facilities that provide accommodation for five or less people less than 24 hours a day are R-3. Where these facilities are in a single family home they must comply with the IRC.

R-4 is for residential care/assisted living facilities including more than five and not more than 16 occupants

OPAQUE AREAS. All exposed areas of a building envelope which enclose conditioned space, except openings for windows, skylights, doors and building service systems.

OUTDOOR AIR. Air taken from the outdoors and, therefore, not previously circulated through the building.

OWNER BUILDER. If all of the following apply:

(A) The owner of the residential construction is the builder, as defined under this chapter.

(B) The residential construction is used as a dwelling by the owner.

(C) The owner in fact directs the details of construction with regard to the installation of materials not in compliance with RBES.

(D) The owner discloses in writing to a prospective buyer, before entering into a binding purchase and sales agreement, with respect to the nature and extent of any noncompliance

with RBES. Any statement or certificate given to a prospective buyer shall itemize how the home does not comply with RBES, and shall itemize which measures do not meet the RBES standards in effect at the time construction commenced. Any certificate shall be recorded in the land records where the property is located, and sent to the Department of Public Service, within 30 days following sale of the property by the owner.

PACKAGED TERMINAL AIR CONDITIONER (PTAC). A factory-selected wall sleeve and separate unencased combination of heating and cooling components, assemblies or sections (intended for mounting through the wall to serve a single room or zone). It includes heating capability by hot water, steam or electricity. (For the complete technical definition, see ARI 310/380.)

PACKAGED TERMINAL HEAT PUMP. A PTAC capable of using the refrigeration system in a reverse cycle or heat pump mode to provide heat. (For the complete technical definition, see ARI 310/380.)

POSITIVE COOLING SUPPLY. Mechanical cooling deliberately supplied to a space, such as through a supply register.

Additionally, mechanical cooling indirectly supplied to a space through uninsulated surfaces of space-cooling components, such as evaporator coil cases and cooling distribution systems which continually maintain air temperatures within the space of 85°F (29°C) or lower during normal operation. To be considered exempt from inclusion in this definition, such surfaces shall comply with the insulation requirements of this code.

POSITIVE HEAT SUPPLY. Heat deliberately supplied to a space by design, such as a supply register, radiator or heating element. Additionally, heat indirectly supplied to a space through uninsulated surfaces of service water heaters and space-heating components, such as furnaces, boilers and heating and cooling distribution systems which continually maintain air temperature within the space of 50°F (10°C) or higher during normal operation. To be considered exempt from inclusion in this definition, such surfaces shall comply with the insulation requirements of this code.

POWER-VENTED APPLIANCE. Appliances that operate with a positive vent static pressure (Category III) and utilize a mechanical fan to exhaust combustion gases from the appliance to the outside atmosphere.

PROPOSED DESIGN. A description of the proposed *building* used to estimate annual energy use for determining compliance

based on total building performance.

RATED CAPACITY. In terms of ventilation, the volume of air (in cfm) that the fan can move against a given static pressure (in inches or water gage). Prescriptive compliance with the *Vermont Residential Building Energy Standards* requires that all fan capacities be rated at 0.1 inch (25 Pa) of water gage.

RATED DESIGN. A description of the proposed *building* used to determine the energy rating index.

RBES. *Vermont Residential Building Energy Standards.*

READILY ACCESSIBLE. Capable of being reached quickly for operation, renewal or inspection without requiring those to whom ready access is requisite to climb over or remove obstacles or to resort to portable ladders or access equipment (see “*Accessible*”).

REFRIGERANT. A substance utilized to produce refrigeration by its expansion or vaporization or absorption.

RENEWABLE ENERGY. Means energy produced using a technology that relies on a resource that is being consumed at a harvest rate at or below its natural regeneration rate including, but not limited to, solar hot water, solar hot air, solar photovoltaics, wind, and hydro.

(A) Methane gas and other flammable gases produced by the decay of sewage treatment plant wastes or landfill wastes and anaerobic digestion of agricultural products, byproducts, or wastes shall be considered renewable energy resources, but no form of solid waste, other than agricultural or silvicultural waste, shall be considered renewable.

(B) The only portion of electricity produced by a system of generating resources that shall be considered renewable is that portion generated by a technology that qualifies as renewable.

(C) Technologies using the following fuels shall not be considered renewable energy supplies: coal, oil, propane, and natural gas.

(D) Biomass is considered renewable.

REPAIR. The reconstruction or renewal of any part of an existing building for the purpose of its maintenance or to correct damage.

REROOFING. The process of recovering or replacing an existing *roof covering*. See “Roof recover” and “Roof replacement.”

RESIDENTIAL BUILDING. For this code, includes detached one- and two-family dwellings, multifamily housing and multiple single- family dwellings (townhouses) as well as Group R-2, R-3 and R-4 buildings, three stories or less in height above grade plane. (See Occupancy Classifications)

ROOF ASSEMBLY. A system designed to provide weather protection and resistance to design loads. The system consists of a roof covering and roof deck or a single component serving as both the roof covering and the roof deck. A roof assembly includes the roof covering, underlayment, roof deck, insulation, vapor retarder and interior finish. The gross area of a roof assembly consists of the total interior surface of all roof/ceiling components, including opaque surfaces, dormer and bay window roofs, treyed ceilings, overhead portions of an interior stairway to an unconditioned attic, doors and hatches, glazing and skylights exposed to conditioned space, that are horizontal or sloped at an angle less than 60 degrees (1.1 rad) from the horizontal (see “Exterior wall”). A roof assembly, or portions thereof, having a slope of 60 degrees (1.1 rad) or greater from horizontal shall be considered in the

gross area of exterior walls and thereby excluded from consideration in the roof assembly. Skylight shaft walls 12 inches (305 mm) in depth or greater (as measured from the ceiling plane to the roof deck) shall be considered in the gross area of exterior walls and are thereby excluded from consideration in the roof assembly

ROOF RECOVER. The process of installing an additional *roof covering* over a prepared existing *roof covering* without removing the existing *roof covering*.

ROOF REPAIR. Reconstruction or renewal of any part of an existing roof for the purposes of its maintenance.

ROOF REPLACEMENT. The process of removing the existing *roof covering*, repairing any damaged substrate and installing a new *roof covering*.

ROOM AIR CONDITIONER. An encased assembly designed as a unit for mounting in a window or through a wall, or as a console. It is designed primarily to provide free delivery of conditioned air to an enclosed space, room or zone. It includes a prime source of refrigeration for cooling and dehumidification and means for circulating and cleaning air, and shall be permitted to also include means for ventilating and heating.

R-VALUE (THERMAL RESISTANCE). The inverse of the time rate of heat flow through a body from one of its bounding surfaces to the other surface for a unit temperature difference between the two surfaces, under steady state conditions, per unit area ($h \cdot \text{ft}^2 \cdot ^\circ\text{F}/\text{Btu}$) [$(\text{m}^2 \cdot \text{K})/\text{W}$].

SASH CRACK. The sum of all perimeters of all window sashes, based on overall dimensions of such parts, expressed in feet. If a portion of one sash perimeter overlaps a portion of another sash perimeter, only count the length of the overlap- ping portions once.

SCREW LAMP HOLDERS. A lamp base that requires a screw-in-type lamp, such as a compact-fluorescent, incandescent, or tungsten-halogen bulb.

SEALED COMBUSTION VENTING SYSTEM. A venting system designed so that all air for combustion is

derived directly from the outside atmosphere and all flue gases are discharged directly to the outside atmosphere. (See also “Direct-vent Appliances.”)

SEASONAL ENERGY EFFICIENCY RATIO (SEER). The total cooling output of an air conditioner during its normal annual usage period for cooling, in Btu/h, divided by the total electric energy input during the same period, in watt- hours, as determined by DOE 10 CFR Part 430, Subpart B, Test Procedures.

SERVICE SYSTEMS. All energy-using systems in a building that are operated to provide services for the occupants or processes housed therein, including HVAC, service water heating, illumination, transportation, cooking or food preparation, laundering and similar functions.

SERVICE WATER HEATING. Supply of hot water for purposes other than comfort heating.

SKYLIGHT. Glass or other transparent or translucent glazing material installed at a slope of less than 60 degrees (1.05 rad) from horizontal.

SIMULATION TOOL. An approved software program or calculation-based methodology that projects the hour-by-hour loads and annual energy use of a building.

SLAB-ON-GRADE EDGE INSULATION. Insulation around, or underneath, the perimeter of the floor slab when

the top edge of the floor perimeter slab is above the finished grade or 12 inches (305 mm) or less below the finished grade.

SLEEPING UNIT. A room or space in which people sleep, which can also include permanent provisions for living, eating, and either sanitation or kitchen facilities but not both. Such rooms and spaces that are also part of a dwelling unit are not *sleeping units*.

SOLAR ENERGY SOURCE. Source of natural daylighting and of thermal, chemical or electrical energy derived directly from conversion of incident solar radiation.

SOLAR HEAT GAIN COEFFICIENT (SHGC). The ratio of the solar heat gain entering the space through the fenestration assembly to the incident solar radiation. Solar heat gain includes directly transmitted solar heat and absorbed solar radiation that is then reradiated, conducted or convected into the space.

SONE. A subjective unit of loudness for an average listener equal to the loudness of a 1,000-hertz (cycles per second) sound that has an intensity 40 decibels above the listener's own threshold of hearing.

STANDARD REFERENCE DESIGN. A version of the *proposed design* that meets the minimum requirements of this code and is used to determine the maximum annual energy use requirement for compliance based on total building performance.

STANDARD TRUSS. Any construction that does not permit the roof/ceiling insulation to achieve the required *R*-value over the exterior walls.

STOREFRONT. A nonresidential system of doors and windows mullied as a composite fenestration structure that has been designed to resist heavy use. *Storefront* systems include, but are not limited to, exterior fenestration systems that span from the floor level or above to the ceiling of the same story on commercial buildings.

STRETCH CODE. A building energy code that achieves greater energy savings than the base RBES. The Stretch Code is required for Act 250 projects and may be adopted by municipalities.

SUMMER CAMPS. Residential buildings constructed for non-winter occupation with only a biomass (wood) or other on-site renewable heating system.

SUNROOM. A one-story structure attached to a dwelling with a glazing area in excess of 40 percent of the gross area of the structure's exterior walls and roof.

SYSTEM. A combination of central or terminal equipment or components or controls, accessories, interconnecting means and terminal devices by which energy is transformed so as to perform a specific function, such as HVAC, service water heating or illumination.

THERMAL CONDUCTANCE. Time rate of heat flow through a body (frequently per unit area) from one of its bounding surfaces to the other for a unit temperature difference between surfaces, under steady conditions ($\text{Btu/h} \cdot \text{ft}^2 \cdot \text{F}$) [$\text{W}/(\text{m}^2 \cdot \text{K})$].

THERMAL ISOLATION. Physical and space conditioning separation from *conditioned space(s)*. The *conditioned space(s)* shall be controlled as separate zones for heating and cooling or conditioned by separate equipment.

THERMAL RESISTANCE (*R*). The reciprocal of thermal conductance ($\text{h} \cdot \text{ft}^2 \cdot ^\circ\text{F}/\text{Btu}$) [$(\text{m}^2 \cdot \text{K})/\text{W}$].

THERMAL RESISTANCE, OVERALL (*R_o*). The reciprocal of overall thermal conductance ($\text{h} \cdot \text{ft}^2 \cdot ^\circ\text{F}/\text{Btu}$) [$(\text{m}^2 \cdot \text{K})/\text{W}$]. The overall thermal resistance of the gross area or individual component of the exterior building envelope (such as roof/ceiling, exterior wall, floor, crawl space wall, foundation, window, skylight, door, opaque wall, etc.), which includes the area-weighted *R*-values of the specific component assemblies (such as air film, insulation, drywall, framing, glazing, etc.).

THERMAL TRANSMITTANCE (*U*). The coefficient of heat transmission (air to air). It is the time rate of heat flow per unit area and unit temperature difference between the warm-side and cold-side air films ($\text{Btu/hr} \cdot \text{ft}^2 \cdot ^\circ\text{F}$) [$\text{W}/(\text{m}^2 \cdot \text{K})$].

The *U*-factor applies to combinations of different materials used in series along the heat flow path, single materials that comprise a building section, cavity airspaces and surface air films on both sides of a building element.

THERMAL TRANSMITTANCE, OVERALL (*U_o*). The overall (average) heat transmission of a gross area of the exterior building envelope ($\text{Btu/h} \cdot \text{ft}^2 \cdot ^\circ\text{F}$) [$\text{W}/(\text{m}^2 \cdot \text{K})$].

The *U_o*-factor applies to the combined effect of the time rate of heat flow through the various parallel paths, such as windows, doors and opaque construction areas, comprising the gross area of one or more exterior building components, such as walls, floors or roof/ceilings.

THERMOSTAT. An automatic control device used to maintain temperature at a fixed or adjustable set point.

TOILET ROOM. A room containing a water closet and, frequently, a lavatory, but not a bathtub, shower, spa or similar bathing fixture.

U-FACTOR (THERMAL TRANSMITTANCE). The coefficient of heat transmission (air to air) through a building component or assembly, equal to the time rate of heat flow per unit

area and unit temperature difference between the warm side and cold side air films ($\text{Btu/h} \cdot \text{ft}^2 \cdot ^\circ\text{F}$) [$\text{W}/(\text{m}^2 \cdot \text{K})$].

UNITARY COOLING AND HEATING EQUIPMENT.

One or more factory-made assemblies which include an evaporator or cooling coil, a compressor and condenser combination, and which shall be permitted to include a heating function as well. When heating and cooling equipment is provided in more than one assembly, the separate assemblies shall be designed to be used together.

UNITARY HEAT PUMP. One or more factory-made assemblies which include an indoor conditioning coil, compressor(s) and outdoor coil or refrigerant-to-water heat exchanger, including means to provide both heating and cooling functions. When heat pump equipment is provided in more than one assembly, the separate assemblies shall be designed to be used together.

UNUSUALLY TIGHT CONSTRUCTION. Construction meeting the following requirements:

1. Storm windows or weatherstripping on openable windows and doors; and
2. Caulking or sealants applied to areas, such as joints around window and door frames, between sole plates and floors, between wall-ceiling joints, between wall panels, at penetrations for plumbing, electrical and gas lines, and at other openings.
3. Buildings constructed in compliance with the RBES shall be considered built of unusually tight construction.

VAPOR PERMEABLE MEMBRANE. A material or covering having a permeance rating of 5 perms ($2.9 \cdot 1040$

$\cdot \text{s} \cdot \text{m}^2$) or greater, when tested in accordance with the desiccant method using Procedure A of ASTM E 96. A vapor permeable material permits the passage of moisture vapor.

VAPOR RETARDER. A vapor-resistant material, membrane or covering such as foil, plastic sheeting or insulation facing. Vapor retarders limit the amount of moisture vapor that passes through a material or wall assembly.

VAPOR RETARDER CLASS. A measure of the ability of a material or assembly to limit the amount of moisture that passes through that material or assembly. Vapor retarder class shall be defined using the desiccant method with Procedure A of ASTM E 96 as follows:

Class 1: 0.1 perm or less,
such as sheet
polyethylene,
unperforated aluminum
foil.

Class 2: $0.1 < \text{perm} < 1.0$ perm,
such as kraft-faced fiberglass
batts.

Class 3: $1.0 < \text{perm} < 10$ perm,
such as latex or enamel paint.

VENTING SYSTEM. A continuous open passageway from the flue collar or draft hood of a solid fuel, gas-burning, kerosene or oil-burning appliance to the outside atmosphere for the purpose of removing flue or vent gases. A venting system is usually composed of a vent or a chimney and vent connector, if used, assembled to form the open passageway.

Mechanical draft venting system. A venting system designed to remove flue or vent gases by mechanical means, that consists of an induced draft portion under nonpositive static pressure or a forced draft portion under positive static pressure.

1. Forced-draft or power venting system. A portion of a venting system using a fan or other mechanical means to cause the removal of flue or vent gases under positive static vent pressure.
2. Induced draft venting system. A portion of a venting system using a fan or other mechanical means to cause the removal of flue or vent gases under non-positive static vent pressure.

Natural draft venting system. A venting system designed to remove flue or vent gases under nonpositive static vent pressure entirely by natural draft.

Sealed combustion venting system. A venting system designed so that all air for combustion is derived directly from the outside atmosphere and all flue gases are discharged directly to the outside atmosphere.

VENTILATION. The natural or mechanical process of supplying conditioned or unconditioned air to, or removing such air from, any space.

VENTILATION AIR. That portion of supply air that comes from outside (outdoors) plus any recirculated air that has been treated to maintain the desired quality of air within a designated space.

VERTICAL FENESTRATION. Windows (fixed or moveable), opaque doors, glazed doors, glazed block and combination opaque/glazed doors composed of glass or other transparent or translucent glazing materials and installed at a slope of a least 60 degrees (1.05 rad) from horizontal.

VISIBLE TRANSMITTANCE [VT]. The ratio of visible light entering the space through the fenestration product assembly to the incident visible light, Visible Transmittance, includes the effects of glazing material and frame and is expressed as a number between 0 and 1.

WHOLE HOUSE MECHANICAL VENTILATION SYSTEM. An exhaust system, supply system, or combination thereof that is designed to mechanically exchange indoor air with outdoor air when operating continuously or through a programmed intermittent schedule to satisfy the whole house ventilation rates.

WHOLE HOUSE VENTILATION SYSTEM, BALANCED. Balanced systems provide outdoor air for ventilation such that supply and exhaust air quantities are of equal capacity to achieve pressure equalization, such as heat recovery

ventilator, an air-to-air heat exchanger or any other system that is designed to provide mechanical supply as well as mechanical exhaust.

WHOLE HOUSE VENTILATION SYSTEM, EXHAUST ONLY. Exhaust only systems exhaust stale indoor air via a single fan, multiple fans or the installation of dual-purpose fans (i.e., serving both localized and whole house ventilation functions). Fresh incoming air may be provided by installed inlet ports or from typical leaks in the building envelope. Exhaust only systems may depressurize the indoor environment.

WHOLE HOUSE VENTILATION SYSTEM, MULTI-PORT. A whole house ventilation system that has more than one exhaust or supply port inside the house.

WHOLE HOUSE VENTILATION SYSTEM, SINGLE-PORT. A whole house ventilation system that has only one connection to the conditioned space and one connection to outdoor air.

WINDOW PROJECTION FACTOR. A measure of the portion of glazing that is shaded by an eave or overhang.

ZONE. A space or group of spaces within a building with heating or cooling requirements that are sufficiently similar so that desired conditions can be maintained throughout using a single controlling device.

DRAFT

CHAPTER 3

GENERAL REQUIREMENTS

SECTION R301 RESERVED

SECTION R302 DESIGN CONDITIONS

R302.1 Interior design conditions. The interior design temperatures used for heating and cooling load calculations shall be a maximum of 72°F (22°C) for heating and minimum of 75°F (24°C) for cooling.

302.2 Exterior design conditions. The following design parameters in Table 302.2 shall be used for calculations required under this code.

TABLE 302.2
THERMAL DESIGN PARAMETERS

CONDITION	VALUE
Winter ^a , Design Dry-Bulb	-11°F
Summer ^a , Design Dry-Bulb	84°F
Summer, Design Wet Bulb	69°F
Degree Days Heating ^b	7,771
Degree Days Cooling ^b	2,228

For SI: °C = [(°F) - 32]/1.8.

- The outdoor design temperature is selected from the columns of 97½-percent values for winter and 2½-percent values for summer from tables in the ASHRAE *Handbook of Fundamentals*. Adjustments shall be permitted to reflect local climates which differ from the tabulated temperatures, or local weather experience determined by the code official or other authority having jurisdiction, where one exists.
- The degree days heating (base 65°F) and cooling (base 65°F) shall be selected from NOAA "Annual Degree Days to Selected Bases Derived from the 1971-2000 Normals," the ASHRAE *Handbook of Fundamentals*, data available from adjacent military installations or other sources of local weather data acceptable to the code official or other authority having jurisdiction, where one exists.

SECTION R303 MATERIALS, SYSTEMS AND EQUIPMENT

R303.1 Identification. Materials, systems and equipment shall be identified in a manner that will allow a determination of compliance with the applicable provisions of this code.

R303.1.1 Building thermal envelope insulation. An *R*-value identification mark shall be applied by the manufacturer to each piece of *building thermal envelope* insulation 12 inches (305 mm) or greater in width. Alternately, the insulation installers shall provide a certification listing the type, manufacturer and *R*-value of insulation installed in each element of the *building thermal envelope*. For blown or sprayed insulation (fiberglass or cellulose), the initial installed thickness, settled thickness, settled *R*-value, installed density, coverage area and number of bags installed shall be *listed* on the certification. For sprayed polyurethane foam (SPF) insulation, the installed thickness of the areas covered and *R*-value of installed thickness shall be *listed* on the certification. For insulated siding, the *R*-value shall be labeled on the product's package and shall be *listed* on the certification. The insulation installer

shall sign, date and post the certification in a conspicuous location on the job site.

R303.1.1.1 Blown or sprayed roof/ceiling insulation. The thickness of blown-in or sprayed roof/ceiling insulation (fiberglass or cellulose) shall be written in inches (mm) on markers that are installed at least one for every 300 square feet (28 m²) throughout the attic space. The markers shall be affixed to the trusses or joists and marked with the minimum initial installed thickness with numbers not less than 1 inch (25 mm) in height. Each marker shall face the attic access opening. Spray

polyurethane foam thickness and installed *R*-value shall be *listed* on certification provided by the insulation installer.

R303.1.2 Insulation mark installation. Insulating materials shall be installed such that the manufacturer's *R*-value mark is readily observable upon inspection.

R303.1.3 Fenestration product rating. *U*-factors of fenestration products (windows, doors and skylights) shall be determined in accordance with NFRC 100.

Exception: Where required, garage door *U*-factors shall be determined in accordance with either NFRC 100 or ANSI/DASMA 105.

U-factors shall be determined by an accredited, independent laboratory, and *labeled* and certified by the manufacturer.

Products lacking such a *labeled U*-factor shall be assigned a default *U*-factor from Table R303.1.3(1) or

R303.1.3(2). The solar heat gain coefficient (SHGC) and *visible transmittance* (VT) of glazed fenestration products (windows, glazed doors and skylights) shall

**TABLE R303.1.3(1)
DEFAULT GLAZED FENESTRATION U-FACTORS**

FRAME TYPE	SINGLE PANE	DOUBLE PANE	SKYLIGHT	
			Single	Double
Metal	1.20	0.80	2.00	1.30
Metal with Thermal Break	1.10	0.65	1.90	1.10
Nonmetal or Metal Clad	0.95	0.55	1.75	1.05
Glazed Block	0.60			

**TABLE R303.1.3(2)
DEFAULT DOOR U-FACTORS**

DOOR TYPE	U-FACTOR
Uninsulated Metal	1.20
Insulated Metal	0.60
Wood	0.50
Insulated, nonmetal edge, max 45% glazing, any glazing double pane	0.35

be determined in accordance with NFRC 200 by an accredited, independent laboratory, and *labeled* and certified by the manufacturer. Products lacking such a *labeled* SHGC or VT shall be assigned a default SHGC or VT from Table R303.1.3(3).

TABLE R303.1.3(3)
DEFAULT GLAZED FENESTRATION SHGC AND VT

	SINGLE GLAZED		DOUBLE GLAZED		GLAZED BLOCK
	Clear	Tinted	Clear	Tinted	
SHGC	0.8	0.7	0.7	0.6	0.6
VT	0.6	0.3	0.6	0.3	0.6

R303.1.4 Insulation product rating. The thermal resistance (*R*-value) of insulation shall be determined in accordance with the U.S. Federal Trade Commission *R*-value rule (CFR Title 16, Part 460) in units of $\text{h} \cdot \text{ft}^2 \cdot ^\circ\text{F}/\text{Btu}$ at a mean temperature of 75°F (24°C).

R303.1.4.1 Insulated siding. The thermal resistance (*R*-value) of insulated siding shall be determined in accordance with ASTM C 1363. Installation for testing shall be in accordance with the manufacturer's instructions.

R303.2 Installation. Materials, systems and equipment shall be installed in accordance with the manufacturer's instructions.

R303.2.1 Protection of exposed foundation insulation. Insulation applied to the exterior of basement walls, crawl-space walls and the perimeter of slab-on-grade floors shall have a rigid, opaque and weather-resistant protective covering to prevent the degradation of the insulation's thermal performance. The protective covering shall cover the exposed exterior insulation and extend not less than 6 inches (153 mm) below grade.

R303.3 Maintenance information. Maintenance instructions shall be furnished for equipment and systems that require preventive maintenance. Required regular maintenance actions shall be clearly stated and incorporated on a readily accessible label. The label shall include the title or publication number for the operation and maintenance manual for that particular model and type of product.

SECTION 304 DESIGN CRITERIA FOR RESIDENTIAL VENTILATION SYSTEMS

304.1 Scope. This section shall govern ventilation of the dwelling unit(s) within Type R-1 residential buildings, Type R-2 residential buildings and multiple single-family attached dwellings (townhouses) not more than three stories in height.

304.1.1 Compliance. Compliance with Section 304 shall be achieved by meeting Section 304.2 and 304.3 or demonstrating compliance with ASHRAE Standard 62.2-2013 (Ventilation and Acceptable Indoor Air Quality in Low-Rise Residential Buildings).

304.2 Local ventilation. Bathrooms containing a bathtub, shower, spa or similar bathing fixture and not included in the whole house ventilation system shall be sized to meet the net capacity rates as required in Table 304.2. Whole house ventilation fans serving both localized and whole house ventilation functions shall be sized to meet the net capacity rates as required by Section 304.6 and must meet all other requirements listed in Section 304.3, as applicable.

TABLE 304.2
MINIMUM REQUIRED LOCAL EXHAUST

OCCUPANCY CLASSIFICATION	MECHANICAL EXHAUST CAPACITY (CFM)
Bathrooms	50 cfm intermittent or 20 cfm continuous

304.3 Whole house ventilation (MANDATORY). Every home and dwelling unit built to RBES shall be mechanically ventilated by a whole house ventilation system as defined in Chapter 2. The whole house ventilation system shall be one of two types: “exhaust only” or “balanced.”

304.4 Whole house air circulation. Provisions shall be made to allow air flow to all finished living spaces by installation of

distribution ducts, undercutting doors, installation of grilles, transoms or equivalent means. Door undercuts shall be at least 1/2 inch (12.7 mm) above the surface of the finished floor covering.

304.5 Fan motor requirements. Fans installed for the purpose of providing whole house ventilation must meet the minimum requirements as specified in this section.

Exception: Fans installed exclusively for local ventilation purposes are exempted from meeting the fan motor requirements listed in section 304.5.

304.5.1 Fan durability. Whole house ventilation fan motors shall be rated for “continuous duty” and have manufacturer flow ratings as listed in HVI 911.

304.5.2 Fan power consumption. Single-port whole house ventilation equipment shall not exceed 50 watts as listed by the manufacturer on the fan motor or as listed in accordance with HVI 911. Power used for lights, sensors, heaters, timers or night lights shall not be included in the determination of power consumption.

304.5.3 Fan noise. Whole house ventilation equipment located less than 4 feet (1219 mm) from louvers, grilles or openings shall have a sound rating no greater than 1.5 sones as determined in accordance with HVI 911.

304.5.4 Performance verification. In-field measurements of exhaust fan flows shall be conducted using a manufactured flow-measuring device in accordance with the manufacturer’s instructions. Acceptable devices include a calibrated orifice combined with a digital manometer or a flow hood. All measuring devices shall be accurate to within 10 percent of measured flow.

304.6 Net capacity requirements. Whole house ventilation system fans shall be installed according to the manufacturer’s installation instructions and shall have the manufacturer’s fan flow ratings as listed in accordance with HVI 911. Unless the whole house system is tested according to procedures in Section 304.6.1, the minimum continuous flow rate that the ventilation system must be capable of supplying during its operation shall be based on the rate per bedroom as specified in Table 304.6.

304.6.1 Testing option. Testing may be done to verify that the whole house ventilation system satisfies the ventilation requirements of this section in accordance with Sections 304.6.1.1 and 304.6.1.2.

304.6.1.1 Minimum Outdoor Air. Automatic operation of the ventilation system shall not reduce the minimum continuous ventilation rate below 15 cfm of outdoor air per bedroom plus 15 cfm during occupancy.

304.6.1.2 Performance Verification. In-field measurements of exhaust fan flows shall be conducted using a manufactured flow-measuring device in accordance with the manufacturer’s instructions. Acceptable devices include a calibrated orifice combined with a digital manometer or a flow hood. All measuring devices shall be accurate to within 10 percent of measured flow.

**TABLE 304.6
PRESCRIPTIVE FAN CAPACITY REQUIREMENTS**

NUMBER OF BEDROOMS	MINIMUM NOMINAL RATED TOTAL FAN CAPACITY^a (at 0.1 inches w.g.)	MINIMUM NUMBER OF FANS TO MEET WHOLE HOUSE AIRFLOW RATES
1	50 cfm	1
2	75 cfm	1
3	100 cfm	1
4	125 cfm	All other systems—2 or more, or Centrally ducted systems—1
5	150 cfm	All other systems—2 or more, or Centrally ducted systems—1
Homes > 3,000 ft ²	cfm = 0.05 · ft ²	All other systems—2 or more, or Centrally ducted systems—1

For SI: 1 cubic foot per minute = 0.0004719 m³/s, 1 cubic foot per minute per square foot = 0.00508 m³/(s · m²).

a. Represents the total installed rated capacity of all fans designed for whole house ventilation.

304.7 Ventilation required during periods of occupancy. Ventilation shall be provided continuously or intermittently during the period that the building is occupied.

304.8 Controls. Whole house ventilation systems shall be capable of being set remotely for continuous operation or shall be provided with an automatic control for intermittent operation. All whole house ventilation controls shall be readily accessible.

Exception: Fans installed expressly for local ventilation purposes.

304.8.1 Intermittent operation. Intermittently operated whole house ventilation systems shall be capable of being set remotely for continuous operation; or shall be provided with an automatic control capable of operating without the need for occupant intervention, such as a time switch or some other control device. Twist or crank-style timers are prohibited as control devices for whole house ventilation systems. Operation controlled solely by a humidity sensor (humidistat or dehumidistat) does not qualify.

304.8.2 Continuous operation. Continuously operated whole house ventilation systems shall not be provided with local controls unless that control only operates the whole house ventilation system both intermittently at high speed and continuously at low speed.

304.8.2.1 On/off switch for continuous operation. An on/off switch for continuously operated whole-house ventilation systems shall be remotely installed and appropriately labeled.

304.9 Installation requirements. Ventilation equipment shall be installed according to the manufacturer's instructions and in accordance with Sections 304.9.1 through 304.9.8.

304.9.1 Fan housings. Fan housings for single-port exhaust only systems must be sealed to the ceiling or wall.

304.9.2 Inlet grills. Inlet grills for multiport exhaust ventilation systems or balanced whole house ventilation systems must be sealed to the ceiling or wall.

304.9.3 Ducts. Smooth wall ducts (PVC or metal) must be used for all duct runs longer than 8 feet (2438 mm). Ducts shall be insulated when installed in an unheated location.

304.9.4 Fasteners. Mechanical fasteners must be used to connect all ducts to the fan(s) without impeding the operation of the fan or any internal backdraft damper.

304.9.5 Joints and connections. All joints, seams and connections shall be securely fastened and sealed with welds, gaskets, mastics (adhesives), mastic embedded fabric systems or approved tapes.

304.9.6 Noise abatement. Remote whole house ventilation fans shall be acoustically isolated from the structural elements of the building and from attached ducts using at least 1 foot (305 mm), but not more than 2 feet (610 mm) of insulated flexible duct.

304.9.7 Intake openings. Mechanical and gravity outside air intake openings for balanced whole house systems, integrated supply systems or heat recovery ventilating systems that are installed in accordance with Section 304 shall be located a minimum of 10 feet (3048 mm) from any hazardous or noxious contaminant, such as vents, chimneys, plumbing vents, fuel fills and vents, streets, alleys, parking lots and loading docks, except as otherwise specified in this code.

The bottom of the intake termination shall be located at least 12 inches (305 mm) above the normally expected snow accumulation level.

304.9.8 Outside opening protection. Air exhaust and intake openings located in exterior walls shall be protected with corrosion-resistant screens, louvers or grilles having a minimum opening size of $\frac{1}{4}$ inch (6.4 mm) and a maximum opening size of $\frac{1}{2}$ inch (12.7 mm), in any dimension. Openings shall be protected against local weather conditions.

304.10 Clothes dryer exhaust. Clothes dryers shall be exhausted in accordance with the manufacturer's instructions. Dryer exhaust systems shall be independent of all other systems and shall convey the moisture and any products of combustion to the outside of the building.

Exception: This section shall not apply to listed and labeled condensing (ductless) clothes dryers

304.11 Makeup air required. Exhaust hood systems capable of exhausting in excess of 400 cubic feet per minute (0.19 m³/s) shall be provided with makeup air at a rate approximately equal to the exhaust air rate. Such makeup air systems shall be equipped with a means of closure and shall be automatically controlled to start and operate simultaneously with the exhaust system.

SECTION 305 COMBUSTION SAFETY (MANDATORY)

305.1 General. The provisions of this section shall govern the requirements for combustion and dilution air for fuel-burning appliances in every new home built to RBES, whenever a new heating system is installed, or whenever alteration, renovation or repair work creates *unusually tight construction* as defined in NFPA 54 and NFPA 31.

305.2 Unusually tight construction. For the purpose of applying the provisions of Section 305 to fuel gas, kerosene and oil-burning equipment, buildings constructed in compliance with the RBES shall be considered so tight that normal infiltration does not meet combustion air requirements, and therefore, of unusually tight construction as defined in NFPA 54 and NFPA 31.

305.3 Fuel gas, kerosene and oil-burning equipment. Every new home built to the RBES that contains Category I or II natural draft venting fuel-burning appliances shall be provided with combustion and dilution air as required by NFPA 54 for fuel-gas utilization equipment or NFPA 31 for oil-burning equipment. Direct vent appliances that do not draw combustion air from inside of the building are not required to be considered in the determination of the combustion and dilution air requirements.

Exception: Where all combustion devices in the home have a sealed combustion venting system, a mechanical draft venting system or are direct-vent appliances, then the combustion and dilution air requirements of this section do not apply.

305.3.1 Crawl space and attic space. For the purposes of applying the provisions of Section 305, an opening to a naturally ventilated crawl space or attic space is not considered equivalent to an opening outdoors and is therefore prohibited for the purposes of supplying combustion and dilution air.

305.3.2 Unvented Room Heaters. Unvented fuel-fired heaters, including room heaters and unvented fireplaces are prohibited.

305.4 Solid fuel-burning appliances and fireplaces. All solid fuel-burning appliances and fireplaces shall meet the provisions of this section.

305.4.1 Gasketed Doors. All solid fuel-burning appliances and fireplaces shall have tight-fitting (defined as gasketed doors with compression closure or compression latch system) metal glass or ceramic doors.

Exception: Any home certified to have passed the Canadian General Standards Board 51.71 "Spillage Test" is not required to have tight-fitting doors. The CGSB Spillage Test creates a "worst-case" condition to determine whether the appliances can vent properly even with the house closed tight and all the exhaust equipment running.

305.4.2 Spillage Testing. All chimney-vented equipment shall establish complete draft without spillage under "worst-case" conditions within two minutes. If any chimney-vented equipment fails this requirement, mechanically

induced pressure relief shall be provided such that the requirement is met.

305.4.2 Exterior air supply requirements. Solid fuel-burning appliances and fireplaces shall be equipped with an exterior air supply according to the provisions of sections 305.4.2.1 through 305.4.2.7.

Exception: Factory-built fireplaces, masonry fireplaces and solid fuel-burning appliances that list exterior air supply ducts as optional or required for proper installation are permitted to be installed with those exterior air supply ducts according to the manufacturer's installation instructions.

305.4.2.1 Combustion air shall not be taken from within the garage, attic, or basement.

305.4.2.2 The exterior air inlet shall not terminate to the exterior higher than the firebox and shall not rise vertically within 18 inches of the firebox.

Exception: Where woodstove or fireplace is installed below grade (in a basement), air intake is permitted to terminate above the firebox if the combustion air supply point is below the firebox and the combustion air intake point is greater than 15 inches below the top of the wood stove or fireplace chimney.

305.4.2.3 The exterior air intake must deliver combustion air to the firebox.

Exception: For older woodstoves and cookstoves where direct connection of combustion air is not possible, combustion air may be delivered within 24 inches of the stove's air intake opening.

305.4.2.4 The air inlet shall be screened with $\frac{1}{4}$ inch mesh.

305.4.2.5 The air inlet shall be closable and designed to prevent debris from dropping into the air intake.

305.4.2.6 The exterior air inlet shall be installed so as to remain free of obstruction from snow.

305.4.2.7 Passageway. The combustion air passageway for unlisted exterior air supply ducts shall be a minimum of 6 square inches (3870 mm²) and not more than 55 square inches (0.035 m²). The passageway shall be non-combustible, masonry or 30 gauge (or thicker) metal, have 1 inch clearance to combustibles for the length of the combustion air intake. Combustion air systems for listed fireplaces shall be constructed according to the fireplace manufacturer's instructions.

DRAFT

CHAPTER 4 [RE]

RESIDENTIAL ENERGY EFFICIENCY

SECTION R401 GENERAL

R401.1 Scope. This chapter applies to residential buildings.

R401.2 Compliance. Projects shall comply with one of the following:

1. “*Prescriptive packages*”: Sections R401 through R404. The 2015 RBES Handbook includes alternative prescriptive packages.
2. “*RESheckTM software*”: Section R405 and the provisions of Sections R401 through R404 labeled “Mandatory.”
3. “*Home Energy Rating System (HERS)*”: An energy rating index (ERI) approach in Section R406.

401.3 Certificate of compliance. A certification may be issued and signed by a builder, a licensed professional engineer, a licensed architect or an accredited home energy rating organization. If certification is not issued by a licensed professional engineer, a licensed architect or an accredited home energy rating organization, it shall be issued by the builder. Any certification shall certify that residential construction meets the RBES. The Department of Public Service will develop and make available to the public a certificate that lists key features of the RBES. Any person certifying shall use this certificate or one substantially like it to certify compliance with the RBES. Certification shall be issued by completing and signing a certificate and permanently affixing it to the electrical service panel, without covering or obstructing the visibility of the circuit directory label, service disconnect label or other required labels. The certificate shall certify that the residential building has been constructed in compliance with the requirements of the RBES. The person certifying under this subsection shall provide a copy of the certificate to the Department of Public Service and shall assure that a certificate is recorded and indexed in the town land records. A builder may contract with a licensed professional engineer, a licensed architect or an accredited home energy rating organization to issue certification and to indemnify the builder from any liability to the owner of the residential construction caused by noncompliance with the RBES.

SECTION R402 BUILDING THERMAL ENVELOPE

R402.1 General (Prescriptive). The *building thermal envelope* shall meet the requirements of Sections R402.1.1 through R402.1.5.

Exemptions: From Section 101.5.2 the following buildings, or portions thereof, shall be exempt from the provisions of this code:

1. **Low Energy Use Buildings.** Those with a peak design rate of energy usage less than 3.4 Btu/h·ft² (10.7 W/m²) or 1.0 watt/ft² (10.7 W/m²) of floor area for space conditioning purposes.
2. **Unconditioned Buildings.** Those that do not contain *conditioned space*.
3. **Mobile homes.** Homes subject to Title VI of the National Manufactured Housing Construction and Safety Standards Act of 1974 (42 U.S.C. §§ 5401- 5426).
4. **Hunting camps.** Residential buildings shall not include hunting camps.
5. **Summer camps.** Residential buildings

constructed for non-winter occupation with only a biomass (wood) or other on-site renewable heating system.

6. **Owner-built homes.** Residential construction by an owner, if all of the following apply:

1. The owner of the residential construction is the *builder*, as defined in 30 V.S.A. § 51, and;
2. The residential construction is used as a dwelling by the owner, and;
3. The owner in fact directs the details of construction with regard to the installation of materials not in compliance with the RBES, and;
4. The owner discloses in writing to a prospective buyer, before entering into a binding purchase and sales agreement, with respect to the nature and extent of any noncompliance with the RBES. Any statement or certificate given to a

prospective buyer shall itemize how the home does not comply with RBES, and shall itemize which measures do not meet the RBES in effect at the time construction commenced.

R402.1.1 Vapor retarder. Wall assemblies in the *building thermal envelope* shall comply with the vapor retarder requirements of Section R702.7 of the *International Residential Code* or Section 1405.3 of the *International Building Code*, as applicable.

R402.1.2 Insulation and fenestration criteria. The *building thermal envelope* shall meet the requirements of Table R402.1.2, R402.1.4 or 402.1.5,

R402.1.3 R-value computation. Insulation material used in layers, such as framing cavity insulation, or continuous insulation shall be summed to compute the corresponding component *R*-value. The manufacturer's settled *R*-value shall be used for blown insulation. Computed *R*-values

shall not include an *R*-value for other building materials or air films. Where insulated siding is used for the purpose of complying with the continuous insulation requirements of Table R402.1.2, the manufacturer's labeled *R*-value for insulated siding shall be reduced by R-0.6.

R402.1.4 *U*-factor alternative. An assembly with a *U*-factor equal to or less than that specified in Table R402.1.4 shall be permitted as an alternative to the *R*-value in Table R402.1.2.

R402.1.5 Total UA alternative. If the total *building thermal envelope* UA (sum of *U*-factor times assembly area) is less than or equal to the total UA resulting from using the *U*-factors in Table R402.1.4 (multiplied by the same

assembly area as in the proposed building), the building shall be considered in compliance with Table R402.1.2. The UA calculation shall be done using a method consistent with the ASHRAE *Handbook of Fundamentals* and shall include the thermal bridging effects of framing materials. The SHGC requirements shall be met in addition to UA compliance.

R402.2 Specific insulation requirements (Prescriptive). In addition to the requirements of Section R402.1, insulation shall meet the specific requirements of Sections R402.2.1 through R402.2.13.

Table 402.1.2 defines the reference conditions for a code compliant home in Vermont. The specific *R*-values and *U*-factors are not necessarily required as long as the home can demonstrate equivalent or lower energy use as compared to the same home built with these components installed. This equivalency can be demonstrated by selecting one of the packages in Table 402.1.2, selecting an alternative package in the 2015 RBES Handbook, using REScheckTM software to demonstrate equivalency, or obtaining a Home Energy Rating System (HERS) rating that meets Section 406.

**TABLE R402.1.2
INSULATION AND FENESTRATION REQUIREMENTS BY COMPONENT^a**

PACK AGE# ⁱ	FENES- TRATION U-FACTOR ^b	SKY- LIGHT ^b U- FACTOR	CEILING R- VALUE ^h	WOOD FRAME WALL R- VALUE ^f	MASS WALL R- VALUE ^g	FLOOR R- VALUE	BASE- MENT ^c & CRAWL- SPACE WALL R-VALUE	SLAB ^d R-VALUE & DEPTH	HEAT- ED SLAB ^d R-VALUE
1	0.32	0.55	49	13+10	15/20	30°	15 continuous or 20 cavity	15, 4 ft	15, edge and under
2	0.28	0.55	49	25	15/20	30°	15 continuous or 20 cavity	15, 4 ft	15, edge and under

For SI: 1 foot = 304.8 mm.

- R-values are minimums. U-factors are maximums. When insulation is installed in a cavity which is less than the label or design thickness of the insulation, the installed R-value of the insulation shall not be less than the R-value specified in the table. Insulation R-value layers can be added to meet the required R-value.
- The fenestration U-factor column excludes skylights.
- Basement and crawlspace insulation can be met through either R-15 continuous insulation or R-20 cavity insulation, either interior or exterior.
- "4 ft" can be horizontal or vertical coverage including slab edge. "Edge and under" requires complete coverage. Up to 8 lineal feet of exposed slab edge may be insulated to R-10.
- Or insulation sufficient to fill the framing cavity.
- The first value is cavity insulation, the second value is continuous insulation, so "13+10" means R-13 cavity insulation plus R-10 continuous insulation. R-25 can be met through any combination of insulation R-values, cavity, or cavity and continuous insulation.
- The second R-value applies when more than half the insulation is on the interior of the mass wall.
- Installing R-38 over 100 percent of the ceiling area requiring insulation shall be deemed to satisfy the requirement for R-49 insulation wherever the full height of uncompressed R-38 insulation extends over the wall top plate at the eaves. (See section R402.2.1).
- The Public Service Department has developed alternative prescriptive packages deemed to be equivalent, provided in the accompanying 2015 RBES Handbook.

TABLE R402.1.4 EQUIVALENT U-FACTORS^a

FENES- TRATION U-FACTOR	SKYLIGH T U- FACTOR	CEILING U- FACTOR	FRAME WALL U-FACTOR	MASS WALL U- FACTOR ^b	FLOOR U-FACTOR	BASEMENT WALL U-FACTOR	CRAWL SPACE WALL U-FACTOR	SLAB & UNHEATED SLAB U-FACTOR & DEPTH
0.32	0	0.026	0.045	0.060	0.033	0.05	0.050	0.066, 4 ft

- Nonfenestration U-factors shall be obtained from measurement, calculation or an approved source.
- When more than half the insulation is on the interior, the mass wall U-factors shall be a maximum of 0.057 in Climate Zones 6 through 8.

**TABLE 402.1.5
LOG HOME INSULATION, FENESTRATION AND HEATING REQUIREMENTS BY COMPONENT^a**

FENESTRATION U-FACTOR ^b	SKYLIGHT U-FACTOR	MAXIMUM GLAZING AREA ^c	CEILING R-VALUE	LOG WALL ^d	FLOOR R-VALUE ^e	BASEMENT/ CRAWL SPACE WALL R-VALUE ^f	SLAB R-VALUE & DEPTH	HEATED SLAB R-VALUE ^g	HEATING SYSTEM AFUE ^h
0.30	0.55	20%	R-49	≥5" Log	R-38	R-15	R-15, 4 ft.	R-15 edge and under	90% gas/LP, 85% oil

For SI: 1 foot = 304.8 mm.

- U-factors are maximums, R-values are minimums.
- The fenestration U-factor column excludes skylights.
- Glazing area includes window and skylight opening area, plus actual glazed area of glass in doors, as a percentage of wall area. Sunrooms are exempt from this requirement.
- Log walls must comply with ICC400 with an average minimum average wall thickness of 5" or greater. Non-log exterior walls shall be insulated in accordance with Table 402.2.1.
- Or insulation sufficient to fill the framing cavity, with R-38 as the absolute maximum.
- Basement walls shall be R-15 continuous insulation or R-20 cavity full basement height.
- Heated slabs shall be completely insulated around the perimeter and under the entire slab.
- Boilers must have an outdoor temperature reset or thermal purge control.

R402.2.1 Ceilings with attic spaces.

Where Section R402.1.2 would require R-49 insulation in the ceiling, installing R-38 over 100 percent of the ceiling area requiring insulation shall be deemed to satisfy the requirement for R-49 insulation wherever the

full height of uncompressed R-38 insulation extends over the wall top plate at the eaves. Where Section R402.1.2 would require R-60 insulation in the ceiling, installing R-49 over 100 percent of the ceiling area requiring insulation shall be deemed to satisfy the requirement for R-60 insulation wherever the full height of uncompressed R-49 insulation extends over the wall

top plate at the eaves. This reduction shall not apply to the *U*-factor alternative approach in Section R402.1.4 and the total UA alternative in Section R402.1.5.

R402.2.2 Ceilings without attic spaces. Where Section R402.1.2 would require insulation levels above R-30 and the design of the roof/ceiling assembly does not allow sufficient space for the required insulation, the minimum required insulation for such roof/ceiling assemblies shall be R-30. This reduction of insulation from the requirements of Section R402.1.2 shall be limited to 500 square feet (46 m²) or 20 percent of the total insulated ceiling area, whichever is less. This reduction shall not apply to the *U*-factor alternative approach in Section R402.1.4 and the total UA alternative in Section R402.1.5.

402.2.1.1 Unvented attic assemblies. Unvented attic assemblies (spaces between the ceiling joists of the top story and the roof rafters) shall be permitted in one- and two-family dwellings and multiple single-family dwellings (townhouses) if all the following conditions are met:

1. The unvented attic space is completely contained within the building thermal envelope.
2. No interior vapor retarders (Class I or II) are installed on the ceiling side (attic floor) of the unvented attic assembly.
3. Where wood shingles or shakes are used, a minimum $\frac{1}{4}$ inch (6 mm) vented air space separates the shingles or shakes and the roofing underlayment above the structural sheathing.
4. Any air-impermeable (e.g., spray foam) insulation shall be a Class III vapor retarder, or shall have a vapor retarder coating, or covering in direct contact with the underside of the insulation.
5. Either Item 5.1, 5.2 or 5.3 shall be met, depending on the air permeability of the insulation directly under the structural roof sheathing.

5.1. Air-impermeable (e.g., spray foam) insulation only. Insulation shall be applied in direct contact with the underside of the structural roof sheathing.

5.2. Air-permeable (e.g., fiberglass or cellulose) insulation only. In addition to the air-permeable insulation installed directly below the structural sheathing, rigid board sheet insulation shall be installed directly above the structural roof sheathing as specified in Table R402.4.1.1 for condensation control.

5.3. Air-impermeable and air-permeable insulation. The air-impermeable (e.g., spray foam) insulation shall be applied in direct contact with the underside of the structural roof sheathing as specified in Table R402.4.1.1 for condensation control. The air-permeable (e.g., fiberglass or cellulose) insulation shall be installed directly under the air-impermeable (e.g., spray foam) insulation.

R402.2.3 Eave baffle. For air-permeable insulations in vented attics, a baffle shall be installed adjacent to soffit and eave vents. Baffles shall maintain an opening equal or greater than the size of the vent. The baffle shall extend over the top of the attic insulation. The baffle shall be permitted to be any solid material.

R402.2.4 Access hatches and doors. Access doors from conditioned spaces to unconditioned spaces such as attics and crawl spaces shall be weatherstripped and insulated to a level equivalent to the insulation on the surrounding surfaces. Access shall be provided to all equipment that pre-vents damaging or compressing the insulation. A wood-framed or equivalent baffle or retainer is required to be provided when loose-fill insulation is installed, the purpose of which is to prevent the loose-fill insulation from spilling into the living space when the attic access is opened, and to provide a permanent means of maintaining the installed *R*-value of the loose-fill insulation.

Exception: Vertical doors that provide access from conditioned to unconditioned spaces shall be permitted to meet the fenestration requirements of Table R402.1.2

R402.2.5 Mass walls. Mass walls for the purposes of this chapter shall be considered above-grade walls of concrete block, concrete, insulated concrete form (ICF), masonry cavity, brick (other than brick veneer), earth (adobe, compressed earth block, rammed earth) and solid timber/logs, or any other walls having a heat capacity greater than or equal to 6 Btu/ft² × °F (123 kJ/m² × K).

R402.2.6 Steel-frame ceilings, walls and floors. Steel-frame ceilings, walls, and floors shall meet the insulation requirements of Table R402.2.6 or shall meet the *U*-factor requirements of Table R402.1.4. The calculation of

the *U*-factor for a steel-frame envelope assembly shall use a series-parallel path calculation method.

R402.2.7 Walls with partial structural sheathing. Where Section R402.1.2 would require continuous insulation on exterior walls and structural sheathing covers 40 percent or less of the gross area of all exterior walls, the continuous insulation *R*-value shall be permitted to be reduced by an amount necessary to result in a consistent total sheathing thickness, but not more than R-3, on areas of the walls covered by structural sheathing. This reduction shall not apply to the *U*-factor alternative approach in Section R402.1.4 and the total UA alternative in Section R402.1.5.

TABLE R402.2.6
STEEL-FRAME CEILING, WALL AND FLOOR INSULATION
(*R*-VALUE)

	Steel Truss Ceilings
WOOD FRAME <i>R</i>-VALUE REQUIREMENT	COLD-FORMED STEEL EQUIVALENT <i>R</i>-VALUE^a
	^b
R-30	R-38 or R-30 + 3 or R-26 + 5
R-38	R-49 or R-38 + 3
R-49	R-38 + 5
	Steel Joist Ceilings^b
R-30	R-38 in 2 × 4 or 2 × 6 or 2 × 8 R-49 in any framing
R-38	R-49 in 2 × 4 or 2 × 6 or 2 × 8 or 2 × 10
	Steel-Framed Wall, 16" on center
R-13	R-13 + 4.2 or R-19 + 2.1 or R-21 + 2.8 or R-0 + 9.3 or R-15 + 3.8 or R-21 + 3.1
R-13 + 3	R-0 + 11.2 or R-13 + 6.1 or R-15 + 5.7 or R-19 + 5.0 or R-21 + 4.7
R-20	R-0 + 14.0 or R-13 + 8.9 or R-15 + 8.5 or R-19 + 7.8 or R-19 + 6.2 or R-21 + 7.5
R-20 + 5 or R-25	R-13 + 12.7 or R-15 + 12.3 or R-19 + 11.6 or R-21 + 11.3 or R-25 + 10.9
R-21	R-0 + 14.6 or R-13 + 9.5 or R-15 + 9.1 or R-19 + 8.4 or R-21 + 8.1 or R-25 + 7.7
	Steel Framed Wall, 24" on center
R-13	R-0 + 9.3 or R-13 + 3.0 or R-15 + 2.4
R-13 + 3	R-0 + 11.2 or R-13 + 4.9 or R-15 + 4.3 or R-19 + 3.5 or R-21 + 3.1
R-20	R-0 + 14.0 or R-13 + 7.7 or R-15 + 7.1 or R-19 + 6.3 or R-21 + 5.9
R-20 + 5	R-13 + 11.5 or R-15 + 10.9 or R-19 + 10.1 or R-21 + 9.7 or R-25 + 9.1
R-21	R-0 + 14.6 or R-13 + 8.3 or R-15 + 7.7 or R-19 + 6.9 or R-21 + 6.5 or R-25 + 5.9
	Steel Joist Floor
R-13	R-19 in 2 × 6, or R-19 + 6 in 2 × 8 or 2 × 10
R-19	R-19 + 6 in 2 × 6, or R-19 + 12 in 2 × 8 or 2 × 10

a. Cavity insulation *R*-value is listed first, followed by continuous insulation *R*-value.

b. Insulation exceeding the height of the framing shall cover the framing.

R402.2.8 Floors. Floor framing-cavity insulation shall be installed to maintain permanent contact with the underside of the subfloor decking.

Exception: The floor framing-cavity insulation shall be permitted to be in contact with the topside of sheathing or continuous insulation installed on the bottom side of floor framing where combined with insulation that meets or exceeds the minimum wood frame wall *R*-value in Table 402.1.2 and that extends from the bottom to the top of all perimeter floor framing members.

R402.2.9 Basement walls. Walls associated with conditioned basements shall be insulated from the top of the *basement wall* down to 10 feet (3048 mm) below grade or to the basement floor, whichever is less. Walls associated with unconditioned basements shall meet this requirement unless the floor overhead is insulated in accordance with Sections R402.1.2 and R402.2.8.

R402.2.10 Slab-on-grade floors. Slab-on-grade floors with a floor surface less than 12 inches (305 mm) below grade shall be insulated in accordance with Table R402.1.2. The insulation shall extend downward from the top of the slab on the outside or inside of the foundation wall. Insulation located below grade shall be extended the distance provided in Table R402.1.2 by any combination of vertical insulation, insulation extending under the slab or insulation extending out from the building. Insulation extending away from the building shall be protected by pavement or by not less than 10 inches (254 mm) of soil. The top edge of the insulation installed between the *exterior wall* and the edge of the interior slab shall be permitted to be cut at a 45-degree (0.79 rad) angle away from the *exterior wall*. Slab-edge insulation is not required in jurisdictions designated by the *code official or other authority having jurisdiction, where one exists*, as having a very heavy termite infestation.

R402.2.11 Crawl space walls. As an alternative to insulating floors over crawl spaces, crawl space walls shall be permitted to be insulated when the crawl space is not vented to the outside. Crawl space wall insulation shall be permanently fastened to the wall and extend downward from the floor to the finished grade level and then vertically and/or horizontally for at least an additional 24 inches (610 mm). Exposed earth in unvented crawl space foundations shall be covered with a continuous Class I vapor retarder in accordance with the *International Building Code* or *International Residential Code*, as applicable. All joints of the vapor retarder shall overlap by 6 inches (153 mm) and be sealed or taped. The edges of the vapor retarder shall extend not less than 6 inches (153 mm) up the stem wall and shall be attached to the stem wall.

R402.2.12 Masonry veneer. Insulation shall not be required on the horizontal portion of the foundation that supports a masonry veneer.

R402.2.13 Sunroom insulation. *Sunrooms* enclosing conditioned space shall meet the insulation requirements of this code.

Exception: For *sunrooms* with *thermal isolation*, and enclosing conditioned space, the following exceptions to the insulation requirements of this code shall apply:

1. The minimum ceiling insulation *R*-value shall be R-30
2. The minimum wall *R*-value shall be R-13. Walls separating a *sunroom* with a *thermal isolation* from *conditioned space* shall meet the *building thermal envelope* requirements of this code.

R402.2.14 Common, party, and fire walls. Whenever continuity of the *building thermal envelope* is broken at walls separating dwelling units in Group R-2 building, including common, party, and fire walls, such walls shall be insulated to a minimum of R-10 on each side of the break in insulation continuity, and the walls shall be air sealed in accordance with Section 402.4.

R402.2.15 Wood framed walls. Efforts must be made to protect insulated cavities from airborne water vapor and condensation. Air sealing the interior face of the assembly, controlled mechanical ventilation (targeting 30% relative humidity), exterior continuous insulation and proper consideration of the vapor permeance of materials are all design elements that can contribute to this protection. Adequate protection from condensation within a standard 6" assembly is likely with R-11.25 or higher exterior insulating sheathing; R-5 exterior insulating sheathing likely does not prevent condensation within a standard 6" assembly and may increase its likelihood. Consultation with design professionals on these details is strongly encouraged.

R402.3 Fenestration (Prescriptive). In addition to the requirements of Section R402, fenestration shall comply with Sections R402.3.1 through R402.3.6.

R402.3.1 U-factor. An area-weighted average of fenestration products shall be permitted to satisfy the *U*-factor requirements.

R402.3.2 Glazed fenestration SHGC. An area-weighted average of fenestration products more than 50-percent glazed shall be permitted to satisfy the SHGC requirements.

Dynamic glazing shall be permitted to satisfy the SHGC requirements of Table R402.1.2 provided the ratio of the higher to lower labeled SHGC is greater than or equal to 2.4, and the *dynamic glazing* is automatically controlled to modulate the amount of solar gain into the space in multiple steps. *Dynamic glazing* shall be considered separately from other fenestration, and area-weighted averaging with other fenestration that is not *dynamic glazing* shall not be permitted.

Exception: *Dynamic glazing* is not required to comply with this section when both the lower and higher labeled SHGC already comply with the requirements of Table R402.1.1.

R402.3.3 Glazed fenestration exemption. Up to 15 square feet (1.4 m²) of glazed fenestration per dwelling unit shall be permitted to be exempt from *U*-factor and SHGC requirements in Section R402.1.2. This exemption shall not apply to the *U*-factor alternative approach in Section R402.1.4 and the Total UA alternative in Section R402.1.5.

R402.3.4 Opaque door exemption. One side-hinged opaque door assembly up to 24 square feet (2.22 m²) in area is exempted from the *U*-factor requirement in Section R402.1.4. This exemption shall not apply to the *U*-factor alternative approach in Section R402.1.4 and the total UA alternative in Section R402.1.5.

R402.3.5 Sunroom fenestration. *Sunrooms* enclosing *conditioned space* shall meet the

fenestration requirements of this code.

Exception: For *sunrooms* with *thermal isolation* and enclosing *conditioned space*, the maximum fenestration *U*-factor shall be 0.45 and the maximum skylight *U*-factor shall be 0.55.

New fenestration separating the *sunroom* with *thermal isolation* from *conditioned space* shall meet the *building thermal envelope* requirements of this code.

DRAFT

R402.4 Air leakage (Mandatory). The *building thermal envelope* shall be constructed to limit air leakage in accordance with the requirements of Sections R402.4.1 through R402.4.4. Installing these air leakage measures should result in an air leakage rate, if tested with a blower door, to not exceed three air changes per hour, if tested in accordance with ASTM E 779 or ASTM E 1827 and reported at a pressure of 0.2 inch w.g. (50 Pascals). Alternatively, the building may be tested with a blower door to not exceed three air changes per hour at 50 Pascals.

R402.4.1 Building thermal envelope. The *building thermal envelope* shall comply with Sections R402.4.1.1 and R402.4.1.2. The sealing methods between dissimilar materials shall allow for differential expansion and contraction.

R402.4.1.1 Installation. The components of the *building thermal envelope* as listed in Table R402.4.1.1 shall be installed in accordance with the manufacturer's instructions and the criteria listed in Table R402.4.1.1, as applicable to the method of construction.

R402.4.2 Fireplaces. New wood-burning fireplaces shall have tight-fitting flue dampers or doors, and outdoor combustion air. Where using tight-fitting doors on factory-built fireplaces listed and labeled in accordance with UL 127, the doors shall be tested and listed for the fireplace.

Where using tight-fitting doors on masonry fireplaces, the doors shall be listed and labeled in accordance with UL 907.

R402.4.3 Fenestration air leakage. Windows, skylights and sliding glass doors shall have an air infiltration rate of no more than 0.3 cfm per square foot (1.5 L/s/m²), and swinging doors no more than 0.5 cfm per square foot (2.6 L/s/m²), when tested according to NFRC 400 or AAMA/WDMA/CSA 101/I.S.2/A440 by an accredited, independent laboratory and *listed* and *labeled* by the manufacturer.

Exception: Site-built windows, skylights and doors.

R402.4.4 Rooms containing fuel-burning appliances. Where open combustion air ducts provide combustion air to open combustion fuel burning appliances, the appliances and combustion air opening shall be located outside the building thermal envelope or enclosed in a room, isolated from inside the thermal envelope. Such rooms shall be sealed and insulated in accordance with the envelope requirements of Table R402.1.2, where the walls, floors and ceilings shall meet not less than the basement wall *R*-value requirement. The door into the room shall be fully gasketed and any water lines and ducts in the room insulated in accordance with Section R403. The combustion air duct shall be insulated where it passes through conditioned space to a minimum of R-8.

Exceptions:

1. Direct vent appliances with both intake and exhaust pipes installed continuous to the outside.
2. Fireplaces and stoves complying with Section R402.4.2 and Section R1006 of the *International Residential Code*.

R402.4.5 Recessed lighting. Recessed luminaires installed in the *building thermal envelope* shall be sealed to limit air leakage between conditioned and unconditioned spaces. All recessed luminaires shall be IC-rated and *labeled* as having an air leakage rate not more than 2.0 cfm (0.944 L/s) when tested in accordance with ASTM E 283 at a 1.57 psf (75 Pa) pressure differential. All recessed luminaires shall be sealed with a gasket or caulk between the housing and the interior wall or ceiling covering.

R402.5 Maximum fenestration *U*-factor and SHGC (Mandatory). The area-weighted average maximum fenestration *U*-factor permitted using tradeoffs from Section R402.1.5 or R405 shall be 0.32 for vertical fenestration, and 0.55 for skylights.

402.6 Vapor retarders. Class I or II vapor retarders are required on the interior side of frame walls.

Exceptions:

1. Basement walls.
2. Below *grade* portion of any wall.
3. Construction where moisture or its freezing will not damage the materials

402.7 Class III vapor retarders. Class III vapor retarders shall be permitted where any one of the following conditions is met:

1. Vented cladding over fiberboard.
2. Vented cladding over gypsum.
3. Insulated sheathing with *R*-value 7.5 over 2×4 wall.
4. Insulated sheathing with *R*-value 11.25 over 2×6 wall.

402.8 Material vapor retarder class. The *vapor retarder class* shall be based on the manufacturer's certified testing or

a tested assembly. The following shall be deemed to meet the class specified:

Class I: Sheet polyethylene, unperforated aluminum foil.

Class II: Kraft-faced fiberglass batts.

Class III: Latex or enamel paint.

DRAFT

**TABLE R402.4.1.1
AIR BARRIER AND INSULATION INSTALLATION**

COMPONENT	AIR BARRIER CRITERIA	INSULATION INSTALLATION CRITERIA
General requirements	<p>A continuous, durable air barrier shall be installed in the building envelope.</p> <p>The exterior thermal envelope contains a continuous, durable air barrier.</p> <p>Breaks or joints in the air barrier shall be sealed.</p> <p>An air barrier is defined as any durable solid (non-porous) material that completely blocks air flow between conditioned space and unconditioned space, including necessary accessories to provide adequate support to resist positive and negative pressures without displacement or damage. The air barrier should be continuous and be durably connected to all penetrations, windows and other (structural) interruptions.</p> <p>Open-cell or closed-cell foam shall have a finished thickness ≥ 5.5 in. or 1.5 in., respectively, to qualify as an air barrier unless the manufacturer indicates otherwise.</p> <p>If flexible air barriers are used, they shall be fully sealed at all seams and edges and supported per manufacturer's installation instructions. Flexible air barriers shall not be made of kraft paper, or other materials that are easily torn. If polyethylene is used, its thickness shall be ≥ 6 mil.</p> <p>Materials meeting ASTM E2357 Standard Test Method for Determining Air Leakage of Air Barrier Assemblies are acceptable.</p>	<p>Air-permeable insulation shall not be used as a sealing material and shall be installed in all vertical walls, sloped ceilings, and floors within the thermal envelope shall be enclosed on all six sides and in contact with a durable, air barrier.</p>
Ceiling/attic	<p>The air barrier in any dropped ceiling/soffit shall be aligned with the insulation and any gaps in the air barrier shall be sealed.</p> <p>Access openings, drop down stairs or knee wall doors to unconditioned attic spaces shall be sealed, insulated and gasketed.</p>	<p>The insulation in any dropped ceiling/soffit shall be aligned with the air barrier and shall be enclosed on five sides and in contact with a durable, interior air barrier. A top-side air barrier is not required in a flat attic.</p>
Walls	<p>The junction of the foundation and sill plate shall be sealed.</p> <p>The junction of the top plate and the top of exterior walls shall be sealed.</p> <p>Knee walls shall be sealed. When part of the thermal envelope, knee wall insulation shall be enclosed on all six sides and in contact with a durable, interior air barrier.</p>	<p>Cavities within corners and headers of frame walls shall be insulated by completely filling the cavity with a material having a thermal resistance of R-3 per inch minimum.</p> <p>Exterior thermal envelope insulation for framed walls shall be installed in substantial contact and continuous alignment with the air barrier.</p> <p>Exterior thermal envelope insulation for framed walls shall be enclosed on all six sides and in contact with a durable, air barrier.^a</p>
Windows, skylights and doors	<p>The space between window/door jambs and framing, and skylights and framing shall be sealed with minimally-expanding foam.</p>	
Rim joists	<p>Rim joists shall include the air barrier. Junctions of the foundation and sill plate, sill plate and rim-band, and rim band and subfloor shall be sealed. When air permeable insulation is installed a durable, interior air barrier shall be installed at the rim joist.</p>	<p>Rim joists shall be insulated.</p>

Floors (including above garage and cantilevered floors)	The air barrier shall be installed at any exposed edge of insulation.	Floor framing cavity insulation shall be installed to maintain permanent contact with the underside of subfloor decking, or floor framing cavity insulation shall be permitted to be in contact with the top side of sheathing, or continuous insulation installed on the underside of floor framing and extends from the bottom to the top of all perimeter floor framing members.
Crawl space walls	Exposed earth in unvented crawl spaces shall be covered with a Class I vapor retarder with overlapping joints taped.	Where provided instead of floor insulation, insulation shall be permanently attached to the crawlspace walls.
Shafts, penetrations	Duct shafts, utility penetrations, and flue shafts opening to exterior or unconditioned space shall be sealed. Doors or hatches in knee walls opening to exterior or unconditioned space shall be insulated and gasketed.	
Narrow cavities		Batts in narrow cavities shall be cut to fit, or narrow cavities shall be filled by insulation that on installation readily conforms to the available cavity space.
Garage separation	Air sealing shall be provided between the garage and conditioned spaces.	
Recessed lighting and appliances	Recessed light fixtures and other appliances (speakers, exhaust fans, light shafts, etc.) installed in the building thermal envelope shall be IC rated, airtight labeled (or "Washington State Approved") and sealed with a gasket or caulk between the housing and the interior wall or ceiling cover. Fixtures and appliances shall maintain required clearances of not less than 1/2" from combustible material and not less than 3" from insulation material, or as required by manufacturer's installation requirements.	Recessed light fixtures installed in the building thermal envelope shall be air tight and IC rated.
Plumbing and wiring	All plumbing and wiring penetrations shall be sealed to the air barrier.	Insulation shall be placed between the exterior of the wall assembly and pipes. Batt insulation shall be cut neatly to fit around wiring and plumbing in exterior walls, or insulation that on installation readily conforms to available space shall extend behind piping and wiring and shall be in full contact with all air barriers.
Shower/tub on exterior wall	Exterior walls adjacent to showers and tubs shall have insulation filling any gaps or voids between tub or shower walls and unconditioned space.	Exterior walls adjacent to showers and tubs shall have a durable, air barrier separating the exterior wall from the shower and tubs and be insulated.
Electrical/phone box on exterior walls	The air barrier shall be installed behind electrical or communication boxes or air-sealed boxes shall be installed.	Insulation completely fills voids between the box and exterior sheathing.
Common wall	Whenever continuity of the building thermal envelope is broken at walls separating dwelling units in Group R-2 building, including common, party, and fire walls, such walls shall be insulated to a minimum of R-10 on each side of the break in insulation continuity.	Air barrier shall be installed in common wall between dwelling units. Common walls shall be sealed at junctions with outside walls and at the top pressure plane of the house.
HVAC register boots	HVAC register boots that penetrate building thermal envelope shall be sealed to the subfloor or drywall.	
Concealed sprinklers	When required to be sealed, concealed fire sprinklers shall only be sealed in a manner that is recommended by the manufacturer. Caulking or other adhesive sealants shall not be used to fill voids between fire sprinkler cover plates and walls or	
Fireplace	A durable air barrier shall be installed in contact with insulation. Fireplace shall have compression closure doors and combustion air supplied from the outdoors.	

a. In addition, inspection of log walls shall be in accordance with the provisions of ICC-400.

DRAFT

DRAFT

SECTION R403 SYSTEMS

R403.1 Controls (Mandatory). At least one thermostat shall be provided for each separate heating and cooling system.

R403.1.1 Programmable thermostat. The thermostat controlling the primary heating or cooling system of the dwelling unit shall be capable of controlling the heating and cooling system on a daily schedule to maintain different temperature set points at different times of the day. This thermostat shall include the capability to set back or temporarily operate the system to maintain *zone* temperatures down to 55°F (13°C) or up to 85°F (29°C). The thermostat shall initially be programmed by the manufacturer with a heating temperature set point no higher than 70°F (21°C) and a cooling temperature set point no lower than 78°F (26°C). Adjustments to these settings for elderly, disabled or those with special needs is permissible.

R403.1.2 Heat pump supplementary heat (Mandatory). Ductless air-source heat pumps shall not have supplementary electric-resistance heat integral to the unit.

R403.2 Hot water boiler outdoor temperature setback. Hot water boilers that supply heat to the building through one- or two-pipe heating systems shall have an outdoor set- back control that lowers the boiler water temperature based on the outdoor temperature.

R403.3 Ducts. Ducts and air handlers for space conditioning shall be in accordance with Sections R403.3.1 through R403.3.5.

R403.3.1 Insulation (Prescriptive). All supply and return ducts shall be insulated to meet the same R-value requirement that applies to immediately proximal surfaces. **Exception:** Ducts or portions thereof located completely inside the *building thermal envelope*.

R403.3.2 Sealing (Mandatory). Ducts, air handlers and filter boxes shall be sealed. Joints and seams shall comply with either the *International Mechanical Code* or *International Residential Code*, as applicable.

Exceptions:

1. Air-impermeable spray foam products shall be permitted to be applied without additional joint seals.
2. For ducts having a static pressure classification of less than 2 inches of water column (500 Pa), additional closure systems shall not be required for continuously welded joints and seams, and locking-type joints and seams of other than the snap-lock and button-lock types.

R403.3.2.1 Sealed air handler. Air handlers shall have a manufacturer's designation for an air leakage of no more than 2 percent of the design air flow rate when tested in accordance with ASHRAE 193.

R403.3.3 Duct testing (Mandatory). Ducts shall be pressure tested to determine air leakage by one of the following methods:

1. Rough-in test: Total leakage shall be measured with a pressure differential of 0.1 inch w.g. (25 Pa) across the system, including the manufacturer's air handler enclosure if installed at the time of the test. All registers shall be taped or otherwise sealed during the test.
2. Postconstruction test: Total leakage shall be measured with a pressure differential of 0.1 inch w.g. (25 Pa) across the entire system, including the manufacturer's air handler enclosure. Registers shall be taped or otherwise sealed during the test.

Exception: A duct air leakage test shall not be required where the ducts and air handlers are located entirely within the building thermal envelope.

A written report of the results of the test shall be signed by an individual certified as either a Building Performance Institute (BPI) Heating Professional or Air Conditioning/Heat Pump Professional, a Home Energy Rating System (HERS) Energy Rater or HERS Field Inspector or a

Vermont Public Service Department approved duct leakage tester, and provided to the *code official or other authority having jurisdiction, where one exists, and to the Public Service Department along with the RBES certificate upon completion of the construction project.*

R403.3.4 Duct leakage (Prescriptive). The total leakage of the ducts, where measured in accordance with Section R403.3.3, shall be as follows:

1. Rough-in test: The total leakage shall be less than or equal to 3 cubic feet per minute (85.0 L/min) per 100 square feet (9.29 m²) of conditioned floor area where the air handler is installed at the time of the test. Where the air handler is not installed at the time of the test, the total leakage shall be less than or equal to 3 cubic feet per minute (85 L/min) per 100 square feet (9.29 m²) of conditioned floor area.
2. Postconstruction test: Total leakage shall be less than or equal to 4 cubic feet per minute (113.3 L/min) per 100 square feet (9.29 m²) of conditioned floor area.

R403.3.5 Building cavities (Mandatory). Building framing cavities shall not be used as ducts or plenums.

R403.4 Mechanical system piping insulation (Mandatory). Mechanical system piping capable of carrying fluids above 105°F (41°C) or below 55°F (13°C) shall be insulated to a minimum of R-3.

R403.4.1 Protection of piping insulation. Piping insulation exposed to weather shall be protected from damage, including that caused by sunlight, moisture, equipment maintenance and wind, and shall provide shielding from solar radiation that can cause degradation of the material. Adhesive tape shall not be permitted.

R403.5 Service hot water systems. Energy conservation measures for service hot water systems shall be in accordance with Sections R403.5.1 and R403.5.4.

R403.5.1 Heated water circulation and temperature maintenance systems (Mandatory). Heated water circulation systems shall be in accordance with Section R403.5.1.1. Heat trace temperature maintenance systems shall be in accordance with Section R403.5.1.2. Automatic

controls, temperature sensors and pumps shall be accessible. Manual controls shall be readily accessible.

R403.5.1.1 Circulation systems. Heated water circulation systems shall be provided with a circulation pump. The system return pipe shall be a dedicated return pipe or a cold water supply pipe. Gravity and thermo-syphon circulation systems shall be prohibited. Controls for circulating hot water system pumps shall start the pump based on the identification of a demand for hot water within the occupancy. The controls shall automatically turn off the pump when the water in the circulation loop is at the desired temperature and when there is no demand for hot water.

R403.5.1.2 Heat trace systems. Electric heat trace systems shall comply with IEEE 515.1 or UL 515. Controls for such systems shall automatically adjust the energy input to the heat tracing to maintain the desired water temperature in the piping in accordance with the times when heated water is used in the occupancy.

R403.5.2 Demand recirculation systems. A water distribution system having one or more recirculation pumps that pump water from a heated water supply pipe back to the heated water source through a cold water supply pipe shall be a *demand recirculation water system*. Pumps shall have controls that comply with both of the following:

1. The control shall start the pump upon receiving a signal from the action of a user of a fixture or appliance, sensing the presence of a user of a fixture or sensing the flow of hot or tempered water to a fixture fitting or appliance.
2. The control shall limit the temperature of the water entering the cold water piping to 104°F (40°C).

R403.5.3 Hot water pipe insulation (Prescriptive). Insulation for hot water pipe with a minimum thermal resistance (*R*-value) of R-3 shall be applied to the following:

1. Piping $\frac{3}{4}$ inch (19.1 mm) and larger in nominal diameter.
2. Piping serving more than one dwelling unit.
3. Piping located outside the conditioned space.
4. Piping from the water heater to a distribution manifold.
5. Piping located under a floor slab.
6. Buried in piping.

7. Supply and return piping in recirculation systems other than demand recirculation systems.

R403.5.4 Drain water heat recovery units. Where installed, drain water heat recovery units shall comply with CSA B55.2. Drain water heat recovery units shall be tested in accordance with CSA B55.1. Potable water-side pressure loss of drain water heat recovery units shall be less than 3 psi (20.7 kPa) for individual units connected to one or two showers. Potable water-side pressure loss of drain water heat recovery units shall be less than 2 psi (13.8 kPa) for individual units connected to three or more showers.

R403.6 Mechanical ventilation (Mandatory). The building shall be provided with ventilation that meets the requirements of the *International Residential Code* or *International Mechanical Code*, as applicable, or with other approved means of ventilation. Outdoor air intakes and exhausts shall have automatic or gravity dampers that close when the ventilation system is not operating.

R403.6.1 Whole-house mechanical ventilation system fan efficacy. Mechanical ventilation system fans shall meet the efficacy requirements of Table R403.6.1.

Exception: Where mechanical ventilation fans are integral to tested and listed HVAC equipment, they shall be powered by an electronically commutated motor.

R403.7 Equipment sizing and efficiency rating (Mandatory). Heating and cooling equipment shall be sized in accordance with ACCA Manual S based on building loads calculated in accordance with ACCA Manual J or other *approved* heating and cooling calculation methodologies. New or replacement heating and cooling equipment shall have an efficiency rating equal to or greater than the minimum required by federal law for the geographic location where the equipment is installed for Climate Zone 6.

R403.8 Systems serving multiple dwelling units (Mandatory). Systems serving multiple dwelling units shall comply with Sections C403 and C404 of the 2015 *Vermont Commercial Building Energy Standards* (CBES) in lieu of Section R403.

R403.9 Snow melt and ice system controls (Mandatory). Snow- and ice-melting systems, supplied through energy service to the building, shall include automatic controls capable of shutting off the system when the pavement temperature is above 50°F (10°C), and no precipitation is falling and an automatic or manual control that will allow shutoff when the outdoor temperature is above 40°F (4.8°C).

**TABLE R403.6.1
MECHANICAL VENTILATION SYSTEM FAN EFFICACY**

FAN LOCATION	AIR FLOW RATE MINIMUM (CFM)	MINIMUM EFFICACY (CFM/WATT)	AIR FLOW RATE MAXIMUM (CFM)
Range hoods	Any	2.8 cfm/watt	Any
In-line fan	Any	2.8 cfm/watt	Any
Bathroom, utility room	10	1.4 cfm/watt	< 90
Bathroom, utility room	90	2.8 cfm/watt	Any

For SI: 1 cfm = 28.3 L/min.

R403.10 Pools and permanent spa energy consumption (Mandatory). The energy consumption of pools and permanent spas shall be in accordance with Sections R403.10.1 through R403.10.4.

R403.10.1 Residential pools and permanent residential spas. Swimming pools and permanent spas that are accessory to detached one- and two-family dwellings and town- houses three stories or less in height above grade plane and that are available only to the household and its guests shall be in accordance with APSP-145.

R403.10.2 Heaters. The heaters shall be controlled by a readily *accessible* on-off switch that is an integral part of the heater mounted on the exterior of the heater, or external to and within 3 feet (914 mm) of the heater. Operation of such switch shall not change the set- ting of the heater thermostat. Such switches shall be in addition to a circuit breaker for the power to the heater. Gas-fired heaters shall not be equipped with continuously burning ignition pilots.

R403.10.3 Time switches. Time switches or other control methods that can automatically turn off and on according to a preset schedule shall be installed for heaters and pump motors. Heaters and pump motors that have built-in time switches shall be in compliance with this section.

Exceptions:

1. Where public health standards require 24-hour pump operation.
2. Pumps that operate solar- and waste-heat- recovery pool heating systems.

R403.10.4 Covers. Outdoor heated pools and outdoor permanent spas shall be provided with an insulated vapor-retardant cover of at least R-12 or other *approved* vapor-retardant means.

Exception: Where more than 70 percent of the energy for heating, computed over an operation season, is from site-recovered energy, such as from a heat pump or solar energy source, covers or other vapor-retardant means shall not be required.

R403.11 Portable spas (Mandatory). The energy consumption of electric-powered portable spas shall be controlled by the requirements of APSP-14.

R403.12 Residential pools and permanent residential spas. Residential swimming pools and permanent residential spas that are accessory to detached one- and two-family dwellings and townhouses three stories or less in height above grade plane and that are available only to the household and its guests shall be in accordance with APSP-15.

R404.1.1 Lighting equipment (Mandatory). Fuel gas lighting systems shall not have continuously burning pilot lights.

404.2 Electric Resistance Heating Equipment. In the City of Burlington, the use of electric resistance heating equipment is prohibited, except where such equipment can be shown to exhibit the lowest life-cycle cost.

SECTION R405 SIMULATED PERFORMANCE ALTERNATIVE USING RESCHECK™ SOFTWARE (PERFORMANCE)

R405.1 Scope. This section establishes criteria for compliance using simulated energy performance analysis. Such analysis shall include heating, cooling and service water heating energy only.

405.2 Mandatory requirements. Compliance with this section requires that the mandatory provisions identified in Section 401.2 be met. All supply and return ducts not completely inside the *building thermal envelope* shall be insulated to meet the same R-value requirement that applies to immediately proximal surfaces.

R405.3 Performance-based compliance. Compliance is based on documentation from REScheck™ modeling software that indicates the home meets or exceeds the target UA for that building.

SECTION R404 ELECTRICAL POWER AND LIGHTING SYSTEMS

R404.1 Lighting equipment (Mandatory). Not less than 75 percent of the lamps in permanently installed lighting fixtures shall be high-efficacy lamps or not less than 75 percent of the permanently installed lighting fixtures shall contain only high-efficacy lamps.

DRAFT

SECTION R406
ENERGY RATING INDEX
COMPLIANCE ALTERNATIVE

R406.1 Scope. This section establishes criteria for compliance using an Energy Rating Index (ERI) analysis. This approach uses a Home Energy Rating System (HERS) Energy Rating provided by a Vermont Public Service Department-approved accredited HERS provider. The “ERI” referenced herein is the same as the RESNET HERS Index.

R406.2 Mandatory requirements. Compliance with this section requires that the mandatory provisions identified in Sections R401.2 and R403.5.3 be met. The building thermal envelope shall be greater than or equal to levels of efficiency and Solar Heat Gain Coefficient in Table 402.1.2 or 402.1.4 of the 2009 *International Energy Conservation Code*.

Exception: Supply and return ducts not completely inside the building thermal envelope shall be insulated to a minimum of R-6.

R406.3 Energy Rating Index. The Energy Rating Index (ERI) shall be a numerical integer value that is based on a linear scale constructed such that the *ERI reference design* has an Index value of 100 and a *residential building* that uses no net purchased energy has an Index value of 0. Each integer value on the scale shall represent a 1-percent change in the total energy use of the rated design relative to the total energy use of the *ERI reference design*. The ERI shall consider all energy used in the *residential building*.

R406.3.1 ERI reference design. The *ERI reference design* shall be configured such that it meets the minimum requirements of the 2006 *International Energy Conservation Code* prescriptive requirements.

The proposed *residential building* shall be shown to have an annual total normalized modified load less than or equal to the annual total loads of the *ERI reference design*.

R406.4 ERI-based compliance. Compliance based on an ERI analysis requires that the *rated design* be shown to have an ERI less than or equal to the appropriate value listed in Table R406.4 when compared to the *ERI reference design*.

R406.5 Verification by approved agency. Verification of compliance with Section R406 shall be completed by a *certified HERS Rater working under the authority of a Vermont PSD-approved accredited HERS Provider*.

R406.6 Documentation. Documentation of the software used to determine the ERI and the parameters for the residential building shall be in accordance with Sections R406.6.1 through R406.6.3.

R406.6.1 Compliance software tools. Documentation verifying that the methods and accuracy of the compliance software tools conform to the provisions of this section shall be provided to the *code official or other authority having jurisdiction, where one exists*.

R406.6.2 Compliance report. Compliance software tools shall generate a report that documents that the ERI of the *rated design* complies with Sections R406.3 and R406.4. The compliance documentation shall include the following information:

1. Address or other identification of the residential building.
2. An inspection checklist documenting the building component characteristics of the *rated design*. The inspection checklist shall show results for both the *ERI reference design* and the *rated design*, and shall document all inputs entered by the user necessary to reproduce the results.
3. Name of individual completing the compliance report.
4. Name and version of the compliance software tool.

Exception: Multiple orientations. Where an otherwise identical building model is offered in multiple orientations, compliance for any orientation shall be permitted by documenting that the building meets the performance requirements in each of the four (north, east, south and west) cardinal orientations.

TABLE R406.4 MAXIMUM BASE CODE ENERGY RATING INDEX

Base Code Target	60	Maximum HERS Index to demonstrate code compliance
Sub-Target	65	Maximum HERS Index without any renewables incorporated
Renewables Adder	5	Maximum HERS Index points that can be counted towards Code Target

Note: Includes all residential structures, including log homes.
Based on REM/Rate version 14. If the HERS Index scale is revised, the Public Service Department may update these Index points.

R406.6.3 Additional documentation. The *code official or other authority having jurisdiction, where one exists*, shall be permitted to require the following documents:

1. Documentation of the building component characteristics of the *ERI reference design*.
2. A certification signed by the builder providing the building component characteristics of the *rated design*.
3. Documentation of the actual values used in the software calculations for the *rated design*.

R406.7 Calculation software tools. Calculation software, where used, shall be in accordance with Sections R406.7.1 through R406.7.3.

R406.7.1 Minimum capabilities. Calculation procedures used to comply with this section shall be software tools capable of calculating the ERI as described in Section R406.3, and shall include the following capabilities:

1. Computer generation of the *ERI reference design* using only the input for the *rated design*.

The calculation procedure shall not allow the user to directly modify the building component characteristics of the *ERI reference design*.

2. Calculation of whole building, as a single *zone*, sizing for the heating and cooling equipment in the *ERI reference design* residence in accordance with Section R403.7.
3. Calculations that account for the effects of indoor and outdoor temperatures and part-load ratios on the performance of heating, ventilating and air-conditioning equipment based on climate and equipment sizing.
4. Printed *code official or other authority having jurisdiction, where one exists*, inspection checklist listing each of the *rated design* component characteristics determined by the analysis to provide compliance, along with their respective performance ratings.

R406.7.2 Specific approval. Performance analysis tools meeting the applicable sections of Section R406 shall be *approved*. Tools are permitted to be *approved* based on meeting a specified threshold for a jurisdiction. The *code official or other authority having jurisdiction, where one exists*, shall approve tools for a specified application or limited scope.

R406.7.3 Input values. When calculations require input values not specified by Sections R402, R403, R404 and R405, those input values shall be taken from an approved source.

SECTION R407

VERMONT STRETCH CODE

R407.1 Scope. This section establishes criteria for compliance with Vermont’s “Stretch Code”, as defined in 30 V.S.A. § 51. Act 250 residential projects and residential buildings in municipalities that adopt the Stretch Code shall demonstrate compliance with one of the packages in Table R407.1, alternative packages in the 2015 RBES Handbook or the maximum ERI values in Table R407.2. All other requirements in the RBES shall apply.

**TABLE R407.1
STRETCH CODE REQUIREMENTS BY COMPONENT^a**

PKG # ⁱ	FENESTRATION U-FACTOR ^b	SKY-LIGHT ^b U-FACTOR	CEILING R-VALUE ^h	WOOD FRAME WALL R-VALUE ^f	MASS WALL R-VALUE ^g	FLOOR R-VALUE	BASEMENT ^{c,f} & CRAWL-SPACE WALL R-VALUE	SLAB ^d R-VALUE & DEPTH	HEATED SLAB ^d R-VALUE	DUCT LEAK-AGE ^j	MECHANICAL SYSTEM ^k EFFICIENCIES
1	0.28	0.55	60 flats / 49 slopes	13+10	15/20	30°	20 continuous or 13+10	15, 4 ft	15, edge and under	4 CFM/ 100 sq. ft.	ENERGY STAR ^l
2	0.28	0.55	60 flats / 49 slopes	25	15/20	30°	20 continuous or 13+10	15, 4 ft	15, edge and under	Ducts inside thermal boundary	ENERGY STAR ^l
3	0.30	0.55	28 continuous	21 continuous	15/20	30°	20 continuous or 13+10	15, 4 ft	15, edge and under	Ducts inside thermal boundary	NAECA ^m minimum compliant

For SI: 1 foot = 304.8 mm.

- R-values, ACH50 and mechanical system efficiencies are minimums. U-factors are maximums. When insulation is installed in a cavity which is less than the label or design thickness of the insulation, the installed R-value of the insulation shall not be less than the R-value specified in the table. Insulation R-value layers can be added to meet the required R-value.
- The fenestration U-factor column excludes skylights.
- Basement and crawlspace insulation can be met through either continuous insulation or a combination of cavity and continuous insulation, either interior or exterior.
- “4 ft” can be horizontal or vertical coverage including slab edge. “Edge and under” requires complete coverage.
- Or insulation sufficient to fill the framing cavity. Up to 8 lineal feet of exposed slab edge may be insulated to R-10.
- The first value is cavity insulation, the second value is continuous insulation, so “13+10” means R-13 cavity insulation plus R-10 continuous insulation. R-25 can be met through any combination of insulation R-values, cavity, or cavity and continuous insulation.
- The second R-value applies when more than half the insulation is on the interior of the mass wall.
- Installing R-38 over 100 percent of the ceiling area requiring insulation shall be deemed to satisfy the requirement for R-49 insulation wherever the full height of uncompressed R-38 insulation extends over the wall top plate at the eaves. (See section R402.2.1). Installing R-49 over 100 percent of the ceiling area requiring insulation shall be deemed to satisfy the requirement for R-60 insulation wherever the full height of uncompressed R-49 insulation extends over the wall top plate at the eaves.
- The Public Service Department has developed alternative prescriptive packages deemed to be equivalent, provided in the accompanying 2015 RBES Handbook.
- See https://www.energystar.gov/products/certified-products?c=products.pr_find_es_products
- Mechanical systems include heating, air conditioning and domestic hot water equipment.
- See Section R403.3.3 and R403.3.4 for duct leakage requirements.
- See http://www1.eere.energy.gov/buildings/appliance_standards/product.aspx/productid/72

TABLE R407.2 MAXIMUM STRETCH CODE ENERGY RATING INDEX

Stretch Code Target	54	Maximum HERS Index to demonstrate code compliance
Sub-Target	65	Maximum HERS Index without any renewables incorporated
Renewables Adder	11	Maximum HERS Index points that can be counted towards Code Target

Note: Based on REM/Rate version 14. If the HERS Index scale is revised, the Public Service Department may update these Index points.

R407.2 Testing. For the *Stretch Code*, the building or dwelling unit shall be tested and verified as having an air leakage rate not exceeding three air changes per hour. Testing shall be conducted in accordance with ASTM E 779 or ASTM E 1827 and reported at a pressure of 0.2 inch w.g. (50 Pascals). Testing and verification shall be conducted by an applicable Building Performance Institutes (BPI) Professional, a Home Energy Rating System (HERS) Energy Rater, HERS Field Inspector, or a Vermont Public Service Department approved air leakage tester. A written report of the results of the test shall be signed by the party conducting the test and provided to the *code official or other authority having jurisdiction, where one exists., and to the Public Service Department along with the RBES certificate upon completion of the construction project..* Testing shall be performed at any time after creation of all penetrations of the *building thermal envelope*.

During testing:

1. Exterior windows and doors, fireplace and stove doors shall be closed, but not sealed, beyond the intended weatherstripping or other infiltration control measures.
2. Dampers including exhaust, intake, makeup air, backdraft and flue dampers shall be closed, but not sealed beyond intended infiltration control measures.
3. Interior doors, if installed at the time of the test, shall be open.
4. Exterior doors for continuous ventilation systems and heat recovery ventilators shall be closed and sealed.
5. Heating and cooling systems, if installed at the time of the test, shall be turned off.
6. Supply and return registers, if installed at the time of the test, shall be fully open.

R407.3 Electric Vehicle Charging. For multifamily developments of 10 or more dwelling units, 4% of parking spaces (rounded up to the nearest whole number) shall have a socket capable of providing either a level 1 or level 2 charge (see below) within 5 feet of the centerline of the parking space ("EV Charging Parking Space").

Level 1 requires one 120V 20 amp grounded AC outlet, or equivalent, for each EV Charging Parking Space

Level 2 requires one 208/240V 40 amp grounded AC outlet, or equivalent, for each EV Charging Parking Space

Table 407.3

Number of parking spots	Required number of EV Charging Parking Spaces
10-25	1
26-50	2
51-75	3
76-100	4, etc.

CHAPTER 5 (RE) EXISTING BUILDINGS

SECTION R501 GENERAL

R501.1 Scope. The provisions of this chapter shall control the *alteration*, repair, addition and change of occupancy of existing buildings and structures.

R501.1.1 Additions, alterations, or repairs: General.

Additions, alterations, or repairs to an existing building, building system or portion thereof shall comply with Section R502, R503 or R504. Unaltered portions of the existing building or building supply system shall not be required to comply with this code. Connections or repairs to, or maintenance of existing mechanical systems do not constitute an alteration to that system.

R501.1.2 Compliance Approaches. Thermal efficiency can be achieved through any of the compliance paths including any one of the following approaches: prescriptive packages, REScheckTM software or a Home Energy Rating System (HERS) rating.

R501.2 Existing buildings. Except as specified in this chapter, this code shall not be used to require the removal, *alteration* or abandonment of, nor prevent the continued use and maintenance of, an existing building or building system law- fully in existence at the time of adoption of this code.

R501.3 Maintenance. Buildings and structures, and parts thereof, shall be maintained in a safe and sanitary condition. Devices and systems that are required by this code shall be maintained in conformance to the code edition under which installed. The owner or the owner's authorized agent shall be responsible for the maintenance of buildings and structures. The requirements of this chapter shall not provide the basis for removal or abrogation of energy conservation, fire protection and safety systems and devices in existing structures.

R501.4 Compliance. *Alterations, repairs, additions* and changes of occupancy to, or relocation of, existing buildings and structures shall comply with the provisions for *alterations, repairs, additions* and changes of occupancy or relocation, respectively, in the *International Residential Code, International Building Code, International Fire Code, International Fuel Gas Code, International Mechanical Code, International Plumbing Code, International Property Maintenance Code, International Private Sewage Disposal Code* and NFPA 70.

R501.5 New and replacement materials. Except as otherwise required or permitted by this code, materials permitted by the applicable code for new construction shall be used. Like materials shall be permitted for repairs, provided hazards to life, health or property are not created. Hazardous materials shall not be used where the code for new construction would not permit their use in buildings of similar occupancy, purpose and location.

R501.6 Historic buildings. No provision of this code relating to the construction, *repair, alteration*, restoration and movement of structures, and *change of occupancy* shall be mandatory for *historic buildings* provided a "Historic Building Exemption Report" obtained from the State Historic Preservation Office, has been submitted to the State Historic Preservation Office and signed by either the owner, an owner's agent, a registered design professional, or a representative of the historic preservation authority having jurisdiction, demonstrating that compliance with that provision would threaten, degrade or destroy the historic fabric or function of the *building*. The State Historic Preservation Office, upon receipt of the report, will review and validate the exemption request. Upon request, a copy of the report shall be provided to the local authority having jurisdiction.

**SECTION
R502
ADDITIONS**

R502.1 General. Additions to an existing building, building system or portion thereof shall conform to the provisions of this code as those provisions relate to new construction without requiring the unaltered portion of the existing building or building system to comply with this code. Additions shall not create an unsafe or hazardous condition or overload existing building systems. An addition shall be deemed to comply with this code where the addition alone complies, where the existing building and addition comply with this code as a single building, or where the building with the addition uses no more energy than the existing building. Additions shall be in accordance with Section R502.1.1 or R502.1.2.

R502.1.1 Prescriptive compliance. Additions shall comply with Sections R502.1.1.1 through R502.1.1.4.

R502.1.1.1 Building envelope. New building envelope assemblies that are part of the addition shall comply with Sections R402.1, R402.2, R402.3.1 through R402.3.5, and R402.4.

Exception: Where *nonconditioned* space is changed to conditioned space, the building envelope of the addition shall comply where the UA, as determined in Section 402.1.4, of the existing building and the addition, and any alterations that are part of the project, is less than or equal to UA generated for the existing building.

R502.1.1.2 Heating and cooling systems. New heating, cooling and duct systems that are part of the addition shall comply with Sections R403.1, R403.2, R403.3, R403.5 and R403.6. Connections or repairs to, or maintenance of existing mechanical systems do not constitute an alteration to that system.

Exception: Where ducts from an existing heating and cooling system are extended to an addition, duct systems with less than 40 linear feet (12.19 m) in unconditioned spaces shall not be required to be tested in accordance with Section R403.3.3.

R502.1.1.3 Service hot water systems. New service hot water systems that are part of the addition shall comply with Section R403.4. Connections or repairs to, or maintenance of existing mechanical systems do not constitute an alteration to that system.

R502.1.1.4 Lighting. New lighting systems that are part of the addition shall comply with Section R404.1.

R502.1.2 Existing plus addition compliance (Simulated Performance Alternative). Where *nonconditioned* space is changed to conditioned space, the addition shall comply where the annual energy cost or energy use of the addition and the existing building, and any alterations that are part of the project, is less than or equal to the annual energy cost of the existing building when modeled in accordance with Section R406. The addition and any alterations that are part of the project shall comply with any of the Chapter 4 compliance options in its entirety.

SECTION R503 ALTERATIONS

R503.1 General. *Alterations* to any building or structure shall comply with the requirements of the code for new construction. *Alterations* shall be such that the existing building or structure is no less conforming to the provisions of this code than the existing building or structure was prior to the *alteration*.

Alterations to an existing building, building system or portion thereof shall conform to the provisions of this code as they relate to new construction without requiring the unaltered portions of the existing building or building system to comply with this code. Alterations shall not create an unsafe or hazardous condition or overload existing building systems. *Alterations* shall be such that the existing building or structure uses no more energy than the existing building or structure prior to the *alteration*. Alterations to existing buildings shall comply with Sections R503.1.1 through R503.2.

R503.1.1 Building envelope. Building envelope assemblies that are part of the alteration shall comply with Section R402.1.2 or R402.1.4, Sections R402.2.1 through R402.2.12, R402.3.1, R402.3.2, R402.4.3 and R402.4.4. Uninsulated or under-insulated wall, floor and roof building cavities that are filled with insulation only need to fill that cavity with insulation and are not required to meet the R-value requirements in Table R402.1.2 or R407.1.

Exception: The following alterations need not comply with the requirements for new construction provided the energy use of the building is not increased:

1. Storm windows installed over existing fenestration.
2. Existing ceiling, wall or floor cavities exposed during construction provided that these cavities are filled with insulation.
3. Construction where the existing roof, wall or floor cavity is not exposed.
4. Roof recover.
5. Roofs without insulation in the cavity and where the sheathing or insulation is exposed during reroofing shall be insulated either above or below the sheathing.
6. Surface-applied window film installed on existing single pane fenestration assemblies to reduce solar heat gain provided the code does not require the glazing or fenestration assembly to be replaced.

R503.1.1.1 Replacement fenestration. Where some or all of an existing fenestration unit is replaced with a new fenestration product, including sash and glazing, the replacement fenestration unit shall meet the applicable requirements for *U*-factor and SHGC as provided in Table R402.1.4.

R503.1.2 Heating and cooling systems. New heating, cooling and duct systems that are part of the alteration shall comply with Sections R403.1, R403.2, R403.3 and R403.6. Connections or repairs to, or maintenance of existing mechanical systems do not constitute an

alteration to that system.

Exception: Where ducts from an existing heating and cooling system are extended, duct systems with less than 40 linear feet (12.19 m) in unconditioned spaces shall

not be required to be tested in accordance with Section R403.3.3.

R503.1.3 Service hot water systems. New service hot water systems that are part of the alteration shall comply with Section R403.4.

R503.1.4 Lighting. New lighting systems that are part of the alteration shall comply with Section 404.1.

Exception: Alterations that replace less than 50 percent of the luminaires in a space, provided that such alterations do not increase the installed interior lighting power.

R503.2 Change in space conditioning. Any nonconditioned or low-energy space that is altered to become *conditioned space* shall be required to be brought into full compliance with this code.

Exception: Where the simulated performance option in Section R405 is used to comply with this section, the annual energy cost of the proposed design is permitted to be 110 percent of the annual energy cost otherwise allowed by Section R405.3.

SECTION R504 REPAIRS

R504.1 General. Buildings, structures and parts thereof shall be repaired in compliance with Section R501.3 and this section. Work on nondamaged components necessary for the required *repair* of damaged components shall be considered part of the *repair* and shall not be subject to the requirements for *alterations* in this chapter. Routine maintenance required by Section R501.3, ordinary repairs exempt from *permit*, and abatement of wear are exempt from meeting RBES requirements.

R504.2 Application. For the purposes of this code, the following shall be considered repairs:

1. Glass-only replacements in an existing sash and frame.
2. Roof repairs.
3. Repairs where only the bulb and/or ballast within the existing luminaires in a space are replaced provided that the replacement does not increase the installed interior lighting power.

SECTION R505 CHANGE OF USE

R505.1 General. Spaces undergoing a change in use that would result in an increase in demand for either fossil fuel or electrical energy shall comply with this code.

R505.2 General. Any space that is converted to a dwelling unit or portion thereof from another use shall comply with this code.

Exception: Where the simulated performance option in Section R405 is used to comply with this section, the annual energy cost of the proposed design is permitted to be 110 percent of the annual energy cost otherwise allowed by Section R405.3.

DRAFT

CHAPTER 6

REFERENCED STANDARDS

This chapter lists the standards that are referenced in various sections of this document. The standards are listed herein by the promulgating agency of the standard, the standard identification, the effective date and title, and the section or sections of this document that reference the standard. The application of the referenced standards shall be as specified in Section 106.

AAMA American Architectural Manufacturers Association
1827 Walden Office Square
Suite 550
Schaumburg, IL 60173-4268

Standard reference number	Title	Referenced in code section number
AAMA/WDMA/CSA 101/IS.2/A C440—11	North American Fenestration Standard/ Specifications for Windows, Doors and Unit Skylights	R402.4.3

ACCA Air Conditioning Contractors of America
2800 Shirlington Road, Suite 300
Arlington, VA 22206

Standard reference number	Title	Referenced in code section number
Manual J—2011	Residential Load Calculation Eighth Edition.	R403.7
Manual S—13	Residential Equipment Selection	R403.7

APSP The Association of Pool and Spa Professionals
2111 Eisenhower Avenue
Alexandria, VA 22314

Standard reference number	Title	Referenced in code section number
APSP 14—11	American National Standard for Portable Electric Spa Energy Efficiency	R403.10.1, 403.11
APSP 15a—2013	American National Standard for Residential Swimming Pool and Spa Energy Efficiency.	R403.12

ASHRAE American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc.
1791 Tullie Circle, NE
Atlanta, GA 30329-2305

Standard reference number	Title	Referenced in code section number
ASHRAE—2013	ASHRAE Handbook of Fundamentals	R402.1.5, Table R405.5.2(1)
ASHRAE 193—2010	Method of Test for Determining the Airtightness of HVAC Equipment.	R403.3.2.1

REFERENCED STANDARDS

ASTM

ASTM International
100 Barr Harbor Drive
West Conshohocken, PA 19428-2859

Standard reference number	Title	Referenced in code section number
C 1363—11	Standard Test Method for Thermal Performance of Building Materials and Envelope Assemblies by Means of a Hot Box Apparatus	R303.1.4.1
E 283—04	Test Method for Determining the Rate of Air Leakage Through Exterior Windows, Curtain Walls and Doors Under Specified Pressure Differences Across the Specimen	R402.4.4
E 779—10	Standard Test Method for Determining Air Leakage Rate by Fan Pressurization	R402.4.1.2
E 1827—11	Standard Test Methods for Determining Airtightness of Building Using an Orifice Blower Door	R402.4.1.2

CSA

CSA Group
8501 East Pleasant Valley
Cleveland, OH 44131-5575

Standard reference number	Title	Referenced in code section number
AAMA/WDMA/CSA 101/1.S.2/A440—11	North American Fenestration Standard/Specification for Windows, Doors and Unit Skylights.	R402.4.3
CSA 55.1—2012	Test Method for measuring efficiency and pressure loss of drain water heat recovery units.	R403.5.4
CSA 55.2—2012	Drain water heat recover units	R403.5.4

DASMA

Door and Access Systems Manufacturers Association
1300 Sumner Avenue
Cleveland, OH 44115-2851

Standard reference number	Title	Referenced in code section number
105—92(R2004)—13	Test Method for Thermal Transmittance and Air Infiltration of Garage Doors	R303.1.3

ICC

International Code Council, Inc.
500 New Jersey Avenue, NW
6th Floor
Washington, DC 20001

Standard reference number	Title	Referenced in code section number
IBC—15	International Building Code®	R201.3, R303.2, R402.1.1, R501.4
ICC 400—12	Standard on the Design and Construction of Log Structures	Table R402.5.1.1
IECC—15	International Energy Conservation Code®	R101.4.1, 403.8
IECC—09	2009 International Energy Conservation Code®	R406.2
ECC—06	2006 International Energy Conservation Code®	R202, R406.3.1
IFC—15	International Fire Code®	R201.3, R501.4
IFGC—15	International Fuel Gas Code®	R201.3, R501.4
IMC—15	International Mechanical Code®	R201.3, R403.3.2, R403.6, R501.4
IPC—15	International Plumbing Code®	R201.3, R501.4
IPSDC—15	International Private Sewage Disposal Code®	501.4
IPMC—15	International Property Maintenance Code®	501.4
IRC—15	International Residential Code®	R201.3, R303.2, R402.1.1, R402.2.11, R403.3.2, R403.6, R501.4

REFERENCED STANDARDS

IEEE

The Institute of Electrical and Electronic Engineers, Inc.
3 Park Avenue
New York, NY 1016-5997

Standard reference number	Title	Referenced in code section number
515.1—2012	IEEE Standard for the Testing, Design, Installation, and Maintenance of Electrical Resistance Trace Heating for Commercial Applications	R403.5.1.2

NFPA

National Fire Protection
Association. 1 Batterymarch Park
Quincy, MA 02169-7471

Standard reference number	Title	Referenced in code section number
70—14	National Electrical Code	R501.4

NFRC

National Fenestration Rating Council,
Inc. 6305 Ivy Lane, Suite 140
Greenbelt, MD 20770

Standard reference number	Title	Referenced in code section number
100—2009	Procedure for Determining Fenestration Products <i>U</i> -factors—Second Edition	
R303.1.3 200—2009	Procedure for Determining Fenestration Product Solar Heat Gain Coefficients and Visible Transmittance at Normal Incidence—Second Edition	R303.1.3
400—2009	Procedure for Determining Fenestration Product Air Leakage—Second Edition	R402.4.3

UL

UL LLC
333 Pfingsten Road
Northbrook, IL 60062

Standard reference number	Title	Referenced in code section number
127—11	Standard for Factory Built Fireplaces	R402.4.2
515—11	Electrical Resistance Heat Tracing for Commercial and Industrial Applications including revisions through November 30, 2011.	R403.5.1.2

US-FTC

United States-Federal Trade Commission
600 Pennsylvania Avenue NW
Washington, DC 20580

Standard reference number	Title	Referenced in code section number
CFR Title 16 R303.1.4 (May 31, 2005)	R-value Rule.	

REFERENCED STANDARDS

WDMA

Window and Door Manufacturers Association
2025 M Street, NW Suite 800
Washington, DC 20036-3309

Standard reference number	Title	Referenced in code section number
AAMA/WDMA/CSA 101/1.S.2/A440—11	North American Fenestration Standard/Specification for Windows, Doors and Unit Skylights.	R402.4.3

DRAFT

APPENDIX RA

RECOMMENDED PROCEDURE FOR WORST-CASE TESTING OF ATMOSPHERIC VENTING SYSTEMS UNDER R402.4 OR R405 CONDITIONS □ 5ACH₅₀

(This appendix is informative and is not part of the code.)

SECTION RA101 SCOPE

RA101.1 General. This appendix is intended to provide guidelines for worst-case testing of atmospheric venting systems. Worst-case testing is recommended to identify problems that weaken draft and restrict combustion air.

SECTION RA201 GENERAL DEFINITIONS

COMBUSTION APPLIANCE ZONE (CAZ). A contiguous air volume within a building that contains a Category I or II atmospherically vented appliance or a Category III or IV direct-vent or integral vent appliance drawing combustion air from inside the building or dwelling unit. The CAZ includes, but is not limited to, a mechanical closet, a mechanical room, or the main body of a house or dwelling unit.

DRAFT. The pressure difference existing between the *appliance* or any component part and the atmosphere that causes a continuous flow of air and products of *combustion* through the gas passages of the *appliance* to the atmosphere.

Mechanical or induced draft. The pressure difference created by the action of a fan, blower or ejector that is located between the *appliance* and the *chimney* or vent termination.

Natural draft. The pressure difference created by a vent or *chimney* because of its height and the temperature difference between the *flue* gases and the atmosphere.

SPILLAGE. Combustion gases emerging from an appliance or venting system into the combustion appliance zone during burner operation.

SECTION RA301 TESTING PROCEDURE

RA301.1 Worst-case testing of atmospheric venting systems. Buildings or dwelling units containing a Category I or II atmospherically vented appliance; or a Category III or IV direct-vent or integral vent appliance drawing combustion air from inside of the building or dwelling unit, shall have the Combustion Appliance Zone (CAZ) tested for spillage, acceptable draft and carbon monoxide (CO) in accordance with this section. Where required by the *code official or other authority having jurisdiction, where one exists*, testing shall be conducted by an *approved third party*. A written report of the results of the test shall be signed by the party conducting the test and provided to the *code official or other authority having jurisdiction, where one exists*. Testing shall be per-

formed at any time after creation of all penetrations of the *building thermal envelope* and prior to final inspection.

Exception: Buildings or dwelling units containing only Category III or IV direct-vent or integral vent appliances that do not draw combustion air from inside of the building or dwelling unit.

The enumerated test procedure as follows shall be complied with during testing:

1. Set combustion appliances to the pilot setting or turn off the service disconnects for combustion appliances. Close exterior doors and windows and the fireplace damper. With the building or dwelling unit in this configuration, measure and record the baseline ambient pressure inside the building or dwelling unit CAZ. Compare the baseline ambient pressure of the CAZ to that of the outside ambient pressure and record the difference (Pa).
2. Establish worst case by turning on the *clothes dryer* and all exhaust fans. Close all interior doors that make the CAZ pressure more negative. Turn on the air handler, where present, and leave on if, as a result, the pressure in the CAZ becomes more negative. Check interior door positions again, closing only the interior doors that make the CAZ pressure more negative. Measure net change in pressure from the CAZ to outdoor ambient pressure, correcting for the base ambient pressure inside the home. Record "worst case depressurization" pressure and compare to Table RA301.1(1).

Where CAZ depressurization limits are exceeded under worst-case conditions in accordance with Table A301.1(1), additional combustion air shall be provided or other modifications to building air-leakage performance or exhaust appliances such that depressurization is brought within the limits prescribed in Table RA301.1(1).

3. Measure worst-case spillage, acceptable draft and carbon monoxide (CO) by firing the fuel-fired appliance with the smallest Btu capacity first.
 - a. Test for spillage at the draft diverter with a mirror or smoke puffer. An appliance that continues to spill flue gases for more than 60 seconds fails the spillage test.
 - b. Test for CO measuring undiluted flue gases in the throat or flue of the appliance using a digital gauge in parts per million (ppm) at the 10-minute mark. Record CO ppm readings to be compared with Table

RA301.1(3) upon completion of Step 4. Where the spillage test fails under worst case, go to Step 4.

- c. Where spillage ends within 60 seconds, test for acceptable draft in the connector not less than 1 foot (305 mm), but not more than 2 feet (610 mm) downstream of the draft diverter. Record draft pressure and compare to Table RA301.1(2).
 - d. Fire all other connected appliances simultaneously and test again at the draft diverter of each appliance for spillage, CO and acceptable draft using procedures 3a through 3c.
4. Measure spillage, acceptable draft, and carbon monoxide (CO) under natural conditions—without *clothes dryer* and exhaust fans on—in accordance with the pro

cedure outlined in Step 3, measuring the net change in pressure from worst case condition in Step 3 to natural in the CAZ to confirm the worst case depressurization taken in Step 2. Repeat the process for each appliance, allowing each vent system to cool between tests.

5. Monitor indoor ambient CO in the breathing zone continuously during testing, and abort the test where indoor ambient CO exceeds 35 ppm by turning off the appliance, ventilating the space, and evacuating the building. The CO problem shall be corrected prior to completing combustion safety diagnostics.
6. Make recommendations based on test results and the retrofit action prescribed in Table RA301.1(3).

TABLE RA301.1(1)
CAZ DEPRESSURIZATION LIMITS

VENTING CONDITION	LIMIT (Pa)
Category I, atmospherically vented water heater	-2.0
Category I or II atmospherically vented boiler or furnace common-vented with a Category I atmospherically vented water heater	-3.0
Category I or II atmospherically vented boiler or furnace, equipped with a flue damper, and common vented with a Category I atmospherically vented water heater	-5.0
Category I or II atmospherically vented boiler or furnace alone	
Category I or II atmospherically vented, fan-assisted boiler or furnace common vented with a Category I atmospherically vented water heater	
Decorative vented, gas appliance	
Power-vented or induced-draft boiler or furnace alone, or fan-assisted water heater alone	-15.0
Category IV direct-vented appliances and sealed combustion appliances	-50.0

For SI: 6894.76 Pa = 1.0 psi.

TABLE RA301.1(2)
ACCEPTABLE DRAFT TEST CORRECTION

OUTSIDE TEMPERATURE (°F)	MINIMUM DRAFT PRESSURE REQUIRED (Pa)
< 10	-2.5
10 – 90	(Outside Temperature ÷ 40) – 2.75
> 90	-0.5

For SI: 6894.76 Pa = 1.0 psi.

TABLE RA301.1(3)
ACCEPTABLE DRAFT TEST CORRECTION

CARBON DIOXIDE LEVEL (ppm)	AND OR	SPILLAGE AND ACCEPTABLE DRAFT TEST RESULTS	RETROFIT ACTION
0 – 25	and	Passes	Proceed with work
25 < □ □ 100	and	Passes	Recommend that CO problem be resolved
25 < □ □ 100	and	Fails in worst case only	Recommend an appliance service call and repairs to resolve the problem
100 < □ □ 400	or	Fails under natural conditions	Stop! Work shall not proceed until appliance is serviced and problem resolved
> 400	and	Passes	Stop! Work shall not proceed until appliance is serviced and problem resolved
> 400	and	Fails under any condition	Emergency! Shut off fuel to appliance and call for service immediately

INDEX

A

ACCESS HATCHES	R402.2.4
ADDITIONS	
Defined	R202
Requirements	R501.1.1, R502
ALTERATIONS	
Defined	R202
Requirements	503
ADMINISTRATION	Chapter 1
AIR BARRIER	
Installation	R402.4.1.1, Table R402.4.1.1
Testing	???
AIR ECONOMIZERS	
Defined	R202
AIR INFILTRATION	
Defined	R202
Requirements	R402.8
AIR LEAKAGE	R402.4, R403.3.3, R403.3.4
ALTERNATE MATERIALS	R102
APPROVED	
Defined	R202
AUTOMATIC	
Defined	R202
ATMOSPHERIC VENTING	Appendix RA
Worst case testing	RA103

B

BASEMENT WALLS	
Defined	R202
Requirements	R303.2.1, Table R402.1.2, Table R402.1.3, R402.2.8, Table R405.5.2(1)
BELOW-GRADE WALLS (see BASEMENT WALLS)	
BOARD OF APPEALS	R109
Qualifications of members	R109.3
BUILDING	
Defined	R202
BUILDING THERMAL ENVELOPE	
Air tightness	R402.4.1
Compliance documentation	R103.2, R401.2
Defined	R202
Insulation	R303.1.1
Insulation and fenestration criteria	R402.1.2
Performance method	Table R405.5.2(1)
Requirements	R102.1.1, R402

C

CEILINGS	R402.2.1, R402.2.2
Specification for standard reference design	Table R405.5.2(1)
CERTIFICATE	R401.3, B103.8
CHANGE OF OCCUPANCY	R505
CIRCULATON SYSTEMS	R403.5.1
CLIMATE TYPES	
Defined	Table R301.3(1)
CLIMATE ZONES	R301, Figure R301.1, Table R301.1
By state or territory	Figure R301.1, Table R301.1
International climate zones	R301.3, Table R301.3(1), Table R301.3(2)
Tropical	R301.4
Warm humid	R301.2, Table R301.2, R301.3.1
CODE OFFICIAL	
Defined	R202
COMMERCIAL BUILDINGS	
Compliance	R101.5
Defined	R202
COMPLIANCE AND ENFORCEMENT	R101.5
Compliance Report	R405.4.2.2
CONDITIONED FLOOR AREA	
Defined	R202
CONDITIONED SPACE	
Defined	R202
CONSTRUCTION DOCUMENTS	R103
Amended	R103.4
Approval	R103.3.1
Examination	R103.3
Information required	R103.2
Phased	R103.3.3
Previous	R103.3.2
Retention	R103.5
Thermal envelope depiction	R405.4.2.2
CONTINUOUS AIR BARRIER	
Defined	R202
CONTROLS	
Heat pump	R403.1.1
Heating and cooling	R403.1
Service water heating	R403.5
CRAWL SPACE WALLS	
Defined	R202
Requirements	R303.2.1, Table R402.1.2, Table R402.1.3, R402.1.4, R402.2.10, Table R405.5.2(1)

D

DEFAULT DISTRIBUTION SYSTEM EFFICIENCIES	Table R405.5.2(2)
DEFINITIONS	Chapter 2
DEGREE DAY COOLING	Table R301.3(2)
DEGREE DAY HEATING	Table R301.3(2)
DEMAND RECIRCULATION WATER SYSTEM	
Defined	R202
Requirements	R403.5.2
DESIGN CONDITIONS	Chapter 3, R302
DOORS	
Attics and crawl spaces	R402.2.4
Default <i>U</i> -factors	Table R303.1.3(2)
Opaque	R402.3.4
Performance requirements	Table R405.5.2(1)
SHGC values	Table R402.1.2
<i>U</i> -values	Table R402.1.4
DUCTS	
Defined	R202
Insulation	R103.2, R401.3, R403.3, R403.3.1
Sealing	R103.2, R403.3.2
Tightness verification	
Postconstruction test	R403.3.2
Rough-in test	R403.3.2
DUCT SYSTEM	
Defined	R202
DWELLING UNIT	
Defined	R202
Multiple units	R403.8
DYNAMIC GLAZING	R402.3.2
Defined	R202

E

EAVE BAFFLE	
Installation	R402.2.3
ELECTRICAL POWER AND LIGHTING	R404
ENERGY ANALYSIS, ANNUAL	
Defined	R202
Documentation	R405.4
Requirements	R405.3
ENERGY COST	
Defined	R202
Energy rating index compliance alternative	R406
Energy rating index	R406.3
ERI-based compliance	R406.4
ENERGY RECOVERY VENTILATION SYSTEMS	
Defined	R202
Requirements	Table R405.5.2(1)

ENERGY SIMULATION TOOL

Defined	R202
---------	------

ENTRANCE DOOR

Defined	R202
---------	------

ENVELOPE, BUILDING THERMAL

Defined	R202
---------	------

ENVELOPE DESIGN PROCEDURES

EQUIPMENT EFFICIENCIES

EQUIPMENT ROOM

Defined	R202
---------	------

EXISTING BUILDINGS

EXTERIOR WALLS

Defined	R202
---------	------

Thermal performance	R402, R402.1.2, Table R405.5.2(1)
---------------------	-----------------------------------

F

FEEES

Refunds	R107.5
---------	--------

Related fees	R107.4
--------------	--------

Schedule of permit fees	R107.2
-------------------------	--------

FENESTRATION

Default <i>U</i> -factors	Table R303.1.3(1)
---------------------------	-------------------

Defined	R202
---------	------

Rating and labeling	R303.1.3, R402.1.1
---------------------	--------------------

Replacement	R402.3.6
-------------	----------

Requirements	Table R402.1.2
--------------	----------------

FENESTRATION PRODUCT, FIELD-FABRICATED

Defined	R202
---------	------

FENESTRATION PRODUCT, SITE-BUILT

Defined	R202
---------	------

FIREPLACES

FLOORS

Above-grade	Table R405.5.2(1)
-------------	-------------------

Insulation	R402.2.7
------------	----------

Slab-on-grade insulation requirements	R402.2.9
---------------------------------------	----------

FOUNDATIONS

Requirements	Table R402.5.1.1, Table R405.5.2(1)
--------------	-------------------------------------

FURNACE EFFICIENCY

G

GLAZED FENESTRATION

R402.3.2, R402.3.3	
--------------------	--

H

HEAT PUMP	R403.1.2
HEAT TRAPS	
Defined	R202
HEATED SLAB	
Defined	R202
HEATING AND COOLING LOADS ..	R302.1, R403.1.2
HIGH-EFFICACY LAMPS	
Defined	R202
HISTORIC BUILDINGS	R101.4.2
HOT WATER	
Piping insulation	R403.4.2, Table R403.4.2
HOT WATER BOILER	
Outdoor temperature setback	R403.2
HVAC SYSTEMS	
Tests	
Postconstruction	R403.3.4
Rough-in-test	R403.3.4

I

IDENTIFICATION (MATERIALS, EQUIPMENT AND SYSTEM)	R303.1
INDIRECTLY CONDITIONED SPACE (see CONDITIONED SPACE)	
INFILTRATION, AIR LEAKAGE	R402.4, Table R405.5.2(1)
Defined	R202
INSPECTIONS	R104
INSULATION	
Basement walls	R402.2.9
Ceilings with attic spaces	R402.2.1
Ceilings without attic spaces	R402.2.2
Crawl space walls	R402.2.10
Duct	R403.2.1
Eave baffle	R402.2.3
Floors	R402.2.8
Hot water piping	R403.4.2
Identification	R303.1, R303.1.2
Installation	R303.1.1, R303.1.1.1, R303.1.2, R303.2, Table R402.4.1.2
Masonry veneer	R402.2.11
Mass walls	R402.2.5
Mechanical system piping	R403.3
Product rating	R303.1.4
Protection of exposed foundation	R303.2.1
Protection of piping insulation	R403.3.1
Requirements	Table R402.1.1, R402.2
Slab-on-grade floors	R402.2.9
Steel-frame ceilings, walls and floors	R402.2.6, Table R402.2.6

Sunroom	R402.2.12
---------------	-----------

INSULATING SHEATHING

Defined	R202
Requirements	Table R402.1.2, R402.1.2

L**LABELED**

Defined	R202
Requirements	R303.1.3, R303.3, R402.4.3

LIGHTING POWER

Manufacturer's information	R102.2, R102.3
----------------------------------	----------------

LIGHTING SYSTEMS

Recessed	R402.4.4, R404
----------------	----------------

LISTED

Defined	R202
---------------	------

LOW ENERGY BUILDINGS

Defined	R101.5.2
---------------	----------

LOW-VOLTAGE LIGHTING

Defined	R202
---------------	------

LUMINAIRE

Sealed	R402.4.3
--------------	----------

M**MAINTENANCE INFORMATION**

Defined	R102.3
---------------	--------

MANUALS

Defined	R101.5.1, R102.3
---------------	------------------

MASONRY VENEER

Insulation	R402.2.12
------------------	-----------

MASS

Wall	402.1.2, R402.1.3, R402.2.5, Table R402.2.6
------------	---

MATERIALS AND EQUIPMENT**MECHANICAL SYSTEMS AND EQUIPMENT**

Defined	R403, R405.1
Mechanical ventilation	R403.6, Table R403.5.1, Table R405.5.2(1)

MULTIPLE DWELLING UNITS**O****OCCUPANCY**

Requirements	R101.4.4, R101.4.6, R101.5
--------------------	----------------------------

OPAQUE DOORS

Defined	R402.3.4
---------------	----------

P**PERFORMANCE ANALYSIS****PERMIT****(see FEES)**

Work commencing before permit	R107.3
-------------------------------------	--------

PIPE INSULATION

Defined	R403.4, R403.5
---------------	----------------

PLANS AND SPECIFICATIONS	R103
POOLS	R403.10
Covers	R403.10.4
Heaters	R403.10.2
Time switches	R403.10.3
PROPOSED DESIGN	
Defined	R202
Requirements	R405, Table R405.5.2(1)
PUMPS	
Time switches	R403.10.3

R

R-VALUE	
Defined	R202
Computation	R402.1.3
Wood frame to cold formed steel frame ceiling, wall and floor insulation <i>R</i> -values	Table R402.2.6
READILY ACCESSIBLE	
Defined	R202
REFERENCED STANDARDS	R106, Chapter 6
REPAIR	
Defined	R202
Requirements	R504
RESIDENTIAL BUILDINGS	
Compliance	R101.2, R101.5
Defined	R202
Simulated performance alternative	R405
ROOF ASSEMBLY	
Defined	R202
Requirements	R101.4.3, R303.1.1.1, R402.2.2, Table R405.5.2(1)

S

SCOPE	R101.2
SERVICE HOT WATER	
Requirements	R403.5
SHEATHING, INSULATING (see INSULATING SHEATHING)	
SHGC (see SOLAR HEAT GAIN COEFFICIENT)	
SHUTOFF DAMPERS	R403.6
SIMULATED PERFORMANCE	
ALTERNATIVE	R405
Documentation	R405.4
Mandatory requirements	R405.2
Performance-based compliance	R405.3
Report	R405.4.2
Software tools	R405.4.1

SIZING

Equipment and system	R405.6.1
SKYLIGHTS	R303.1.3, R402.1.2, R402.3, Table R405.5.2(1)
Defined	R202
SNOW MELT SYSTEM CONTROLS	R403.9
SOLAR HEAT GAIN COEFFICIENT (SHGC)	R102.1.3, R104.2, Table R303.1.3(3), R401.3, Table R402.1.2, R402.1.4, R402.3.2, R402.3.3, R402.3.6, R402.5
Defined	R202
STANDARD REFERENCE DESIGN	
Defined	R202
Requirements	R405, Table R405.5.2(1)
STANDARDS, REFERENCED	R106, Chapter 5
STEEL FRAMING	R402.2.6
STOP WORK ORDER	R108
Authority	R108.1
Emergencies	R108.3
Failure to comply	R108.4
Issuance	R108.2
SUNROOM	R402.2.13, R402.3.5, Table R405.5.2(1)
Defined	R202
Insulation	R402.2.13
SWIMMING POOLS	R403.9

T

THERMAL CONDUCTANCE (see C-Factor)	
THERMAL ISOLATION	R402.2.12, R402.3.5, Table R405.5.2(1)
Defined	R202
THERMAL MASS (see MASS)	
THERMAL RESISTANCE (see R-VALUE)	
THERMAL TRANSMITTANCE (see U-FACTOR)	
THERMOSTAT	
Defined	R202
Controls	R403.1
Programmable	R403.1.1
TIME SWITCHES	R403.9.2
TOTAL BUILDING PERFORMANCE	
Residential	R405
TOWNHOUSE (see RESIDENTIAL BUILDINGS)	

U

U-FACTOR

Alternative	R402.1.3, Table R402.1.3, R402.1.4
Default door	Table R303.1.3(2)

Default glazed fenestration Table R303.1.3(1)
Defined R202, R402.3.1, R402.5
Skylights . Table R402.1.1, Table R402.1.3, R402.3.5
Sunroom R402.3.5

V

VALIDITY R105
VAPOR RETARDER R402.1.1
VENTILATION R401.2.1, R403.6,
Table R403.6.1, Table R405.5.2(1)
Defined R202
VISIBLE TRANSMITTANCE (VT)
Default glazed fenestration Table R303.1.3(3)
Defined R202

W

WALL

Above-grade, defined R202
Standard reference design Table R405.5.2(1)
Basement, defined R202
Installation R402.2.9
Standard reference design Table R405.5.2(1)
Crawlspace, defined R202
Installation R402.2.11
Standard reference design Table R405.5.2(1)
Exterior, defined R202
Mass R402.2.5
Steel-frame R402.2.6, Table R402.2.6
With partial structural sheathing R402.2.7

WALLS (see EXTERIOR WALLS AND BUILDING THERMAL ENVELOPE)

WALLS ADJACENT TO UNCONDITIONED SPACE (see BUILDING THERMAL ENVELOPE)

WATER HEATING R401.3, R403.4, R405.1,
Table R405.5.2(1)

WHOLE HOUSE MECHANICAL VENTILATION SYSTEM

Defined R202
System fan efficacy R403.6.1

WINDOW AREA

(see FENESTRATION and GLAZING AREA)

DRAFT

DRAFT

DRAFT